

**CORRIGENDUM NO. 1 IN REFERENCE TO THE RFP FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 3 NOS. LIFTS AT SBI, LOCAL HEAD OFFICE BUILDING, BHADRA, LALDARWAJA, AHMEDABAD-380 001**

S. No.	Tender ref. page no.	Ref. clause	Existing	Amendment
1	---	---	----	It has been confirmed that the center lift shall be taken up for the replacement in the first phase. The other sequence will be informed later.
2	Price Bid page No.3	C	AMC charges for maintaining existing elevators on per month per lift basis.	In the event of OTIS the existing service provider expressing their inability to continue AMC of the remaining two elevators, the successful bidder has to take responsibility to maintain and attend the break downs till the lifts are taken over for replacement.
3	----	----	-----	Bank will provide temporary lockable partition in lift machine room.
4	Page No.3	5	SBIIMS shall release Work Order for only 1 lift in the 1st phase. After completion of the 1st phase bank shall release Work Order for the next 2 lifts together/phased manner after receiving the financial approval from the SBI. Bidder should take care of additional time frame based on the price quoted by the bidder.	As discussed work order for only one elevator (Center lift) will be released. However, the price validity for acceptance by SBIIMS for balance two elevators shall be up to 18 (Eighteen) months from the date of opening of Technical Bid. SBIIMS may release the work order for all the three elevators simultaneously.
5	56	8	Position Indicators: Provide Dot Matrix type floor position indicators at each entrance as per manufacturer's standard specifications, as approved by the Bank.	Bidders to include for duplex type indicators combined with luminous buttons on all floors. Bidders to include for dot matrix type indicators on all floors.

6	53	2.12	Tripping speed of over speed governor and tripping of safety gear shall be adjusted to 90% of the rated speed.	Please read the tripping speed of governor as mentioned in the latest IS Code.
7	53	2.13	Mount the auxiliary break on suitable structural steel support.	Please delete auxiliary break from the scope of the tender.
8	55	6.5	Ventilation shall be provided at the top and bottom of the car operating panel.	Ventilation to be provided as per IS.
9	55	6.14 & 6.15	Technical parameters annexure 14 point No.1.13 (Car enclosure)	All bidders to submit the car finishes samples latest by 06.08.2019. Bidders to include for combination of finishes to cover any of the finishes selected by the Bank.
10	31	3.0	Full time supervisor at site for coordination of work.	A full time supervisor need not be present at site as far as safety norms are strictly adhere to.
11	53	3.4	It is clarified that counter weight safety mechanism shall be included in the scope by all bidders.	No change
12	83	1.17	Technical parameters annexure 14 point 1.17 car size	SBIIMS has decided the car height below false ceiling to be 2400 mm instead of 2600 mm.
13	38	10.2	The contractor shall anticipate demand and keep an inventory of spares on site in a self provided lockable metal cabinet.	SBIIMS agrees that no spares shall be stocked at site for maintenance purposes.
14	46	24.01 & 24.02	Security deposit shall be for the DLP of 12 months and 1 <sup>st</sup> year of AMC.	Security deposit shall remain valid till expiry of defect liability period of 12 (Twelve) months from the date of submission of lift license.
15	3	xii	Each page of the technical bid duly signed and stamped along with all necessary documents	Last date of submission of Technical Bid has been extended up to 3:00 pm on 16.08.2019 on request of all

			mentioned in the tender in a sealed envelope should reach to us on or before 06.08.2019 up to 3:00 PM.	bidders.
16	-----	----	-----	All other terms and conditions and technical specifications of the elevators remains unchanged.
17	57	10.6	Architraves: Retain existing centre line	Bidders to maintain existing center line to eliminate any front wall modification and Architraves work.
18	58	10.10	Landing door & surround finish Stainless steel in 18 gauge in Hairline finish on 8 floors and 3 nos mirror finish	Landing door & surround finish Stainless steel in 18 gauge in Hairline finish on 7 floors and 4 nos mirror finish
19	44	20 & 21	The Contractor shall indemnify the SBI/SBIIMS against all claims, proceedings, damages, costs, charges and expenses in respect of the matters referred to in the provision sub-clause 19 of this clause.	Contractors shall indemnify the SBI/SBIIMS against all claims, proceedings, damages, cost, charges and expenses in respect of the matters referred to in the provision of related sub-clause up to Rs.50.0 Lakh.

Circle Head & VP (Civil),  
SBIIMS, Ahmedabad  
Date:02.08.2019