

SBI INFRA MANAGEMENT SOLUTIONS PVT.LTD.

CIRCLE OFFICE, PREMISES DEPARTMENT, STATE BANK OF INDIA, LOCAL HEAD OFFICE, C-6, BLOCK G, BANDRA KURLA COMPLEX, BANDRA (E), MUMBAI 400 051

PART – A : TECHNICAL BID

TENDER ID: MUM201903020

REPLACING AND SHIFTING OF COOLING TOWERS FROM TERRACE TO GROUND FLOOR AT LHO BUILDING AT C-6, BLOCK G, BANDRA KURLA COMPLEX, BANDRA (E), MUMBAI 400 051

TENDER SUBMITTED BY :

NAME : _____

ADDRESS : _____

GSTN NO. : _____

DATE : _____

EMAIL ID. : _____

CONTACT NO. : _____

ARCHITECT :

**ARCHITECTS APPROACH,
20, SHREEDHAR BUILDING,
HANUMAN ROAD, OPP. ICICI BANK,
VILEPARLE (EAST), MUMBAI 400 057.
TEL. NO. 26146829 / 26163137
FAX NO. 26163137 MOBILE NO. 9820158656
E-mail : arch_apro@yahoo.com**



NOTICE INVITING TENDERS

SBIIMS circle office, Mumbai on behalf of SBI through its Architect **M/s. ARCHITECTS APPROACH, Mumbai** invites “online item rate E-tender” from the reputed & established **HVAC Cooling towers contractors for replacement and relocating of existing old cooling towers of centralized A.C. plant, relocating existing cooling towers of D.G. Set and allied works.**

The details of tender are as under:

S.No.	Description	
1.	Name of work	Replacement and relocating of existing old cooling towers of centralized A.C. plant, relocating existing cooling towers of D.G. Set from terrace to ground floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051
2.	Nature of Work	Replacement and relocating of existing old cooling towers of centralized A.C. plant, relocating existing cooling towers of D.G. Set from terrace to ground floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051
3.	Time allowed for completion	3 (Three) Months
4.	Cost of Tender Documents	Rs. 10,000/- (To be deposited along with Tender to be paid through State Bank Collect ONLY as detailed under; 1) login https://www.onlinesbi.com 2) Select SB Collect from Top Menu, click the check box and “Proceed” 3) Select “All India” in “State of Corporate/Institution” & Select “Commercial Services” in “Type of Corporate/Institution” then “Go” 4) Select “SBI Infra Management Solutions pvt. Ltd” in Commercial Services Name and “Submit” 5) Select “Tender Application Fee” in “Payment Category” and enter the “Tender ID” exactly as given in first page top of this tender(characters in uppercase Only). 6) Fill up all fields such as email, GST No., Mobile No, Vendor/Firm Name etc and make payment. 7) Enclose payment receipt having unique reference No. along with EMD.
5.	Earnest Money Deposit	Rs.1,21,000/- (One Lac Twenty-One Thousand Only) by means of Demand Draft / Pay Order from any scheduled Nationalized Bank drawn in favour of SBI Infra Management Solutions Pvt. Ltd. and payable in Mumbai.
6.	Initial Security Deposit	2% of contract amount including EMD
7.	Date of issue of tender documents form Bank’s website	18.05.2019 to 24.05.2019 www.sbi.co.in under <Link>procurement news.
8.	Date of Pre-Bid Meeting at Site (Expenses will be borne	22.05.2019

Seal and Signature of Contractor



	by the bidder only the Bank will not reimburse the same.	At 3 rd Floor SBI, LHO Synergy Building at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051 on 3.00 PM
9	Eligibility Criteria	<p>i) Average annual financial turnover during the last 3 years, ending 31st March of the previous financial year, should be at least Rs. 36,30,000.00 (Rupees Thirty-Six Lacs thirty thousand Only) The bidder should submit the balance sheet for last 3 years.</p> <p>ii) Experience of having successfully completed works during last 5 years ending 28.02.2019 should be either of the following: -</p> <p>a. Three similar completed works costing not less than the amount equal to Rs. 48,40,000.00 (Rupees Forty-Eight Lacs Forty Thousand Only) or</p> <p>b. Two similar completed works costing not less than the amount equal to Rs. 60,50,000.00 (Rupees Sixty Lacs fifty Thousand Only) or</p> <p>c. One similar completed work costing not less than the amount equal to Rs. 96,80,000.00 (Rupees Ninety-Six Lacs Eighty thousand Only)</p> <p>iv) The Contractor should submit the list of empanelment with Govt. /Semi. Govt/ PSU/ RBI/institutions.</p> <p>v) Satisfactory Performance Certificate of completed similar projects during last five years from client/organizations along with TDS certificate.</p> <p>vi) The vendor shall comply with GST, PF, ESIC, IT, PAN & Safety Norms.</p> <p>vii) The bidders should have office in Mumbai, Navi Mumbai or Thane</p> <p>viii) Firms who fulfill the above criteria supported with following documentary proof shall only considered for participation:</p> <p>I) List of similar works carried out by them for the last five years indicating the organisation for whom executed,</p> <p>II) Value of work, completion time (stipulated & actual)</p> <p>III) List of similar works in hand indicating the organisation for whom executed, value of work, completion time (stipulated & actual status of work)</p>
10	Last date & time for submission of Technical bid, EMD and cost of tender document	24.05.2019 by 3.00 PM
11	Date & time for Opening of Technical bid, of tender document(Part-I)	24.05.2019 by 3.30 PM

Seal and Signature of Contractor



12.	Address at which Technical bid(hard copy) along with EMD & Cost of tender document has to be submitted.	V.P. & Circle Head, SBI Infra Management Solutions Pvt. Ltd., State Bank of India, Premises Department, Local Head Office, 'Synergy', C-6, G-Block, Bandra Kurla Complex, Bandra (E), Mumbai 400 051
13	Intimation to Technically Qualified bidders	Shall be communicated by e-mail/telephone on or before 25.05.2019
14	Last date, time and Mode of submission of Price Bid (Part-2) The Price Bid to be submitted online through E-tendering Process those who are qualified in Technical bid (Part-1)).	a) Price Bid Submission through Online from 28.05.2019 to 29.05.2019 at Service Provider's portal https://tenderwizard.com b) Price Bid to be opened through Online Process on 29.05.2019 @ 3.00 PM
15.	Date & time of E-Reverse Auction	NA
16.	Place of opening tenders	V.P. & Circle Head, SBI Infra Management Solutions Pvt. Ltd. State Bank of India, Local Head Office, Synergy, Plot No. C-6, G-Block, Bandra Kurla Complex, Bandra (East), Mumbai 400 051
17.	Liquidated Damages	0.50% of contract amount per weeks subject to max. 5% of contract value or final bill value.
18.	Defects liability period	12 Months from the date of Virtual Completion
19.	Validity of offer	90 days from the date of opening of Price-bid
20.	Value of Interim Certificate	Rs. 30.00 Lakhs. No advance on materials / plant / machinery or mobilization advance shall be paid under any circumstances
21	Price Bid	Price bid can be downloaded from - https://tenderwizard.com/ (By the qualified bidder in Technical bid)

21. Tenders can be downloaded from the bank's website www.sbi.co.in (link) <Procurement News>. It shall be responsibility of the contractor to arrange and ensure that all pages of technical and financial bid are properly bound separately. Tenders in loose pages may be disqualified.

22.. The contractor shall sign and stamp each page of the tender document thereby ensuring the number and sequence of all pages.

23. No conditions other than mentioned in the tender will be considered, and if given they will have to be withdrawn before opening of the price-bid.

24. The SBIIMS Pvt. Ltd. reserve their rights to accept or reject any or all the tenders, either in whole or in part without assigning any reason(s) for doing so and no claim / correspondence shall be entertained in this regard.

25. Tenders received without EMD and Cost of Tender Documents shall be summarily rejected and such tenders shall not be allowed to participate in the online price bidding process.

Seal and Signature of Contractor



26. In case the date of opening of tenders is declared as a holiday, the tenders will be opened on the next working day at the same time.

27. SBIIMS Pvt. Ltd. has the right to accept / reject any / all tenders without assigning any reasons and no correspondence shall be entertained in this regard.

Yours Faithfully,
For M/S. ARCHITECTS APPROACH
Mr. Ramesh Shenoy
Partner
Architect & Interior Designer

FORM TENDER

To,
The V.P. Circle Head,
SBI Infra Management Solutions Pvt. Ltd.
State Bank of India, Local Head Office,
'Synergy', C-6, G-Block,
Bandra Kurla Complex,
Bandra, Mumbai- 400 021.

Dear Sir,

Having examined the drawings, specification, design and schedule of quantities relating to the works specified in the memorandum hereinafter set out and having visited and examined the site of the works specified in the said memorandum and having acquired the requisite information relating thereto as affecting the tender, I/We hereby offer to execute the works specified in the said memorandum at the rates mentioned in the attached Schedule of Quantities and in accordance in all respects with the specifications, design, drawings and instructions in writing referred to in conditions of tender, the Articles of Agreement, Special Conditions, Schedule of Quantities and Conditions of Contract and with such materials as are provided for by, and in all other respects in accordance with such conditions so far as they may be applicable.

MEMORANDUM

Description of work	Replacement and relocating of existing old cooling towers of centralized A.C. plant, relocating existing cooling towers of D.G. Set from terrace to ground floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051
Earnest Money	Rs.Rs.1,21,000/- (One Lac Twenty-One Thousand Only)) by means of Demand Draft / Pay Order from any scheduled Nationalized Bank drawn in favour of SBI Infra Management Solutions Pvt. Ltd. and payable in Mumbai.
Percentage, if any, to be deducted from Bills and total amount to be retained	10 % from Running Bills, subject to maximum Total 5% of contract amount or actual Final Bill value including EMD & Initial Security Deposit.
Time allowed for completion of the Works from fourteenth day after the date of written order or date of handing over of the site (whichever is later) to commence the work	3 (Three) months

I / We have deposited a sum of **Rs.Rs.1,21,000/- (One Lac Twenty-One Thousand Only)**) of the total tender amount as Earnest Money with the SBI Infra Management Solutions Pvt. Ltd. which

Seal and Signature of Contractor



amount is not to bear any interest. Should I / We fail to execute the Contract when called upon to do so I / We do hereby agree that this sum shall be forfeited by me/us to SBI Infra Management Solutions Pvt. Ltd.

1) Our Bankers are:

i)

ii)

The names of partners of our firm are:

i)

ii)

Name of the partner of the firm

Authorised to sign

Or

(Name of person having Power of Attorney to sign the Contract.

(Certified true copy of the Power of Attorney should be attached)

Yours faithfully,

Signature of Contractors.

Signature and addresses of Witnesses

i)

ii)

Annexure-1

APPLICATION FORM

1 Name of the organization :

Seal and Signature of Contractor



- 2 Address :
- 3 Name, Telephone Nos. including :
Mobile and e-mail id of contact
person
- 4 Fax No. :
- 5 Constitution of the Firm (whether :
Public or private company / firm /
Proprietary)
- 6 Year of Establishment :
(Supporting document to be
submitted)
- 7 Whether registered with the :
Registrar of Companies /
Registrar of firms (if so, mention
number and date and supporting
documents to be submitted)
- 8 Registration with Govt.
Authorities
- a. Income-tax (PAN) No. :
- b. Goods & Service tax no. :
(GST)
- c. EPF Registration No. :
- d. ESI Registration No. :
- e. Contract Labour :
- 9 Names of Directors / Proprietor / :
Partners / Associates
- 10 Bio-data of Directors / Partners / :
Associates, Details may be given
in the format mentioned below
- 11 Amount of service tax/GST paid :
year-wise during last 3 financial
years ending 31.03.2018
- 12 Details of Similar works :
completed during the last 7 years
(Details may be given in the
enclosed format - Form 'B')

Seal and Signature of Contractor



- 13 Details of under execution / :
awarded
(Details may be given in the
enclosed format - Form 'C')
- 14 List of Professionals / Technical / :
Non-technical Personnel
employed permanently
(Details may be given in the
enclosed format - Form 'F')
- 15 Details of Plant & Machinery / :
Manufacturing unit/ tools /
equipment owned by the company
(Details may be given in the
enclosed format - Form 'G')
- 16 Banker's Name & address :
(Enclose solvency certificate
from the bankers)
- 17 Latest Income Tax Clearance :
Certificate to be enclosed.
- 18 List of empanelment / enlistment
/ registration with other
Organizations / statutory bodies
etc. (If so, furnish their names,
category and date of registration)

Name of the Organization	Category	Year since empanelled

- 19 Annual turnover for the last 3
financial years (year-wise)
ending 31.03.2018

Financial Year	Annual Turnover
FY 2017-18	

Seal and Signature of Contractor



FY 2016-17	
FY 2015-16	

- 20 Name and address of the persons who will be in a position :
to certify about the quality as well
as performance of your firm

Note: Please enclose separate sheets for additional information, photographs, and documents

Signature of the applicant with seal

Date:

Place:

Seal and Signature of Contractor



BIO-DATA OF THE DIRECTORS/PARTNERS/ KEY ASSOCIATES

1. Name :
2. Date of Birth :
3. Associates with the organization since:
4. Professional Qualification :
5. Professional Experience :
6. Professional Affiliation :
7. Membership in :
8. Details of Published papers in Magazine / Journals (if any) :
9. Details of cost effective methods/innovative techniques adopted in the project :
- 10 Exposure to new material / technology :

Signature of Applicant with Seal

Seal and Signature of Contractor



FINANCIAL INFORMATION

I. BANK DETAILS

Name of the Bank :
 Branch with Address :

 City :
 Contact Person in the Bank :
 Contract Details :

II. DETAILS OF CHARTERED ACCOUNTANT

Name :
 Address :

 Registration details of accountant :
 Contact Number :
 E-mail address :

III. FINANCIAL ANALYSIS – Details to be furnished duly supported by figures in Balance Sheet/Profit and Loss Account for the last Five years duly certified by the Chartered Accountant, as submitted by the applicant to the Income-Tax Department (Copies to be attached).

SN	YEARS	2013-14	2014-15	2015-16	2016-17	2017-18
(i)	Gross Annual Turnover in Cooling towers Works					
(ii)	Profit/Loss					
(iii)	Financial Position					
	a. Cash					
	b. Current Assets					
	c. Current Liabilities					
	d. Working Capital (b-c)					
	e. Current Ration					
	f. Acid Test Ratio (Quick Assets/Current Liabilities (a/c))					

IV. Income Tax Clearance Certificate

V. Solvency certificate from Bankers (Schedule Bank) of Applicant.

VI. Financial arrangements for carrying out the proposed work

Signature of Chartered Accountant with seal

Signature of Applicant with Seal

Seal and Signature of Contractor



Annexure-4

DETAILS OF ALL 'SIMILAR' WORKS COMPLETED DURING THE LAST SEVEN YEARS ENDING BY 31ST JANUARY 2019.

(Enclose supporting documents i.e. Work order and Satisfactory Completion Certificate Obtained
from the Clients)

S. No.	Name of Work	Name of the Client (with Brief Address of Concerned Office & Contact No. and e-mail ID)	Type of Client / Owner Mention Govt. / Semi Govt. / PSU / Bank	Date of Agreement with Client	Location and Scope of the Work	Actual Value of the Work	Date of commencement as per contract & actual date of Commencement	Stipulated Date of completion & Actual date of completion	Litigation/ Arbitration pending/ In progress with details (if any)

(Add separate sheet if required)

Note:

1. For certificates, the issuing authority shall not be less than an Executive Engineer in charge.

Signature of Applicant with Seal

Seal and Signature of Contractor



Annexure-5

DETAILS OF ALL 'SIMILAR' WORKS ON HAND - UNDER EXECUTION OR AWARDED.

(Enclose Copies of Work Orders Issued by Clients)

S. No.	Name of Work	Name of the Client (with Brief Address of Concerned Office & Contact No. and e-mail ID)	Type of Client / Owner Mention Govt. / Semi Govt. / PSU / Bank	Date of Agreement with Client	Location and Scope of the Work	Actual Value of the Work	Date of commencement as per contract	Likely date of completion	If Work Left Incomplete or Terminated (Furnish reasons)

(Add separate sheet if required)

Note:

1. Information has to be filled up specifically in this format.
2. The projects mentioned in the above format shall be sorted in the order of cost of the project (Descending order).

Signature of Applicant with Seal

Seal and Signature of Contractor



**PERFORMANCE REPORT FOR 'SIMILAR' MAJOR COMPLETED WORKS
(REFERRED TO IN FORM 'B')**

- Name of the Work / Project & Location :
- Scope of Work :
1. Agreement No. & Date :
 2. Estimated Cost / Tendered Cost :
 3. Actual Value of Work done :
 4. Date of Commencement
 - a. Stipulated date of Commencement :
 - b. Actual date of Commencement :
 5. Date of Completion
 - a. Stipulated date of Completion :
 - b. Actual date of Completion :
 6. Amount of compensation levied for delayed completion if any. \ :
 7. Performance report based on
 - Quality of Work, : Excellent / Very Good / Good / Poor
 - Time Management, : Excellent / Very Good / Good / Poor
 - Resourcefulness, : Excellent / Very Good / Good / Poor
 - Financial Soundness, : Excellent / Very Good / Good / Poor
 - Technical Proficiency, : Excellent / Very Good / Good / Poor

Superintending Engineer / Chief Project Manager or Equivalent
Name of Organization

Note :

1. The performance report is to be submitted separately for all major works mentioned in Form 'B'.
2. The performance report preferably be submitted in the above Performa. In case, different proforma is used, the applicant shall ensure that the report / certificate shall contain all the above information / details.



DETAILS OF KEY TECHNICAL AND ADMINISTRATIVE PERSONNEL EMPLOYED IN THE ORGANIZATION

Sr. No.	Name & Adahar No.	Designation	EPF & ESIC No.	Educational Qualification	Professional Experience	Length of continuous service with employer in years
1	2	3	4	5	6	7

Note:

- Details of Technical personnel shall be provided qualification-wise
- Organization chart of the company, additional information about Technical and administrative personnel, if any, may be submitted on separate sheet

Signature of Applicant with Seal

Seal and Signature of Contractor

DECLARATION OF NEAR RELATIVES OF SBI EMPLOYEES

I/We.....S/o/D/o.....
.....Residing at
.....

..... hereby certify that none of our relatives(s) as defined in the Tender document is/are employed in SBI as per details given in tender document. In case at any stage, it is found that the information given by me is false/incorrect, SBI shall have the absolute right to take any action as deemed fit, without any prior intimation to me.

(The near relatives are members of a Hindu undivided family/husband and wife/ the one related to the other in the manner as father, mother, son(s) and son's wife (daughter- in- laws), daughter(s), husband (son-in-law), brother(s) and brother's wife, sister(s) & sister's husband (brother-in-law).

Place :

Date :

Signature of Applicant with Seal

Name in Capital Letters:

Address:

Signature of Contractor with Seal

SAMPLE BUISNESS RULE DOCUMENT

ONLINE E-TENDERING FOR REPLACING AND SHIFTING OF COOLING TOWERS FROM TERRACE TO GROUND FLOOR AT C-6, BLOCK G, BANDRA KURLA COMPLEX, BANDRA (E), MUMBAI 400 051

(A) Business rules for E-tendering:

1. Only empaneled contractors with SBIIMS PVT.LTD. under appropriate category who are invited by the project Architect/SBIIMS shall only be eligible to participate.
2. SBIIMS PVT.LTD. will engage the services of and E-tendering service provider who will provide necessary training and assistance before commencement of online bidding on Internet.
3. In case of e-tendering, SBIIMS will inform the vendor in writing, the details of service provider to enable them to contact and get trained.
4. Business rules like event date, closing and opening time etc. also will be communicated through service provider for compliance.
5. Contractors have to send by email, the compliance form in the prescribed format (provided by service provider), before start of E-tendering. Without this the vendor will not be eligible to participate in the event.
6. The Contractors will be required to submit the various documents in sealed Envelope to the office of SBI Infra Solutions Pvt Ltd. at the address mentioned hereinbefore by the stipulated date i.e. (1) Hard Copy of Technical Bid duly signed and stamped on each page (2) Demand Draft of specified amount of EMD (3) Demand Draft of Cost of Tender documents. Contractors not submitting any one or more documents shall not be eligible to participate in the on line price bidding.
7. E-tendering will be conducted on schedule date & time.
8. **The e-tendering will be treated as closed only when the bidding process gets closed in all respects for the item listed in the tender.**

(B) Terms & conditions of E-tendering:

SBIIMS PVT.LTD. shall finalize the Tender through e-tendering mode for which **M/s. Antares Systems Limited.** has been engaged by SBIIMS an authorized service provider. Please go through the guidelines given below and submit your acceptance to the same along with your Commercial Bid.

1. E-tendering shall be conducted by SBIIMS through **M/s. Antares Systems Limited.**, on pre-specified date. While the Contractors shall be quoting from their own offices/ place of their choice, Internet connectivity and other paraphernalia requirements shall have to be ensured by Contractors themselves. In the event of failure of their Internet connectivity, (due to any reason whatsoever it may be) it is the bidders' responsibility. In order to ward-off such contingent situation bidders are requested to make all the necessary arrangements/ alternatives such as back-up power supply whatever required

Signature of Contractor with Seal

so that they are able to circumvent such situation and still be able to participate in the E-tendering successfully. Failure of power at the premises of Contractors during the E-tendering cannot be the cause for not participating in the E-tendering. On account of this the time for the E-tendering cannot be extended and SBIIMS Pvt. Ltd. is not responsible for such eventualities.

2. M/s. Antares Systems Limited. shall arrange to train your nominated person(s), without any cost to you. They shall also explain you all the Rules related to the E-tendering. You are required to give your compliance on it before start of bid process.
3. BIDDING CURRENCY AND UNIT OF MEASUREMENT: Bidding will be conducted in Indian currency & Unit of Measurement will be displayed in Online E-tendering.
4. BID PRICE: The Bidder has to quote the rate as per the Tender Document provided by SBIIMS Pvt. Ltd. their appointed Architects.
5. VALIDITY OF BIDS: The Bid price shall be firm for a period specified in the tender document and shall not be subjected to any change whatsoever.
6. Procedure of E-tendering:
 - i. **Online E-tendering** :
 - (a) The hard copy of the Technical as well as Price Bid are available on the Bank's website during the period specified in the NIT.
 - (b) Online e-tendering is open to the empaneled bidders who receive NIT from the Architect and qualified for participating in the price bidding as provisions mentioned hereinabove through SBIIMS approved Service Provider.
 - (c) The Price-Bid shall be made available online by the Service Provider wherein the contractors will be required to fill-in their Item-wise rates for each item.
 - (d) The Contractors are advised not to wait till the last minute to submit their online item-wise quote in the price bid to avoid complications related with internet connectivity, network problems, system crash down, power failure, etc.
 - (e) It is mandatory to all the bidders participating in the price bid to quote their rates for each and every item.
 - (f) In case, contractor fails to quote their rates for any one or more tender items, their tender shall be treated as ***"Incomplete Tender"*** and shall be liable for rejection.
7. LOG IN NAME & PASSWORD: Each Bidder is assigned a Unique User Name & Password by M/s. Antares Systems Limited. The Bidders are requested to change the Password after the receipt of initial Password from M/s. Antares Systems Limited. All bids made from the Login ID given to the bidder will be deemed to have been made by the bidder.
8. BIDS PLACED BY BIDDER: Bids will be taken as an offer to execute the work as specified. Bids once made, cannot be cancelled / withdrawn and the Bidder shall be bound to execute the work at the quoted bid price. In case the L-1 Bidder backs out or fail to complete the work as per the rates quoted, SBIIMS shall at liberty to take action as deemed necessary including depaneling such contractors and forfeiting their EMD..
9. At the end of the E-tendering, SBIIMS Pvt. Ltd. will decide upon the winner. SBIIMS Pvt. Ltd. decision on award of Contract shall be final and binding on all the Bidders.

Signature of Contractor with Seal

10. SBIIMS shall be at liberty to cancel the E-tendering process / tender at any time, before ordering, without assigning any reason.
11. SBIIMS shall not have any liability to bidders for any interruption or delay in access to the site irrespective of the cause.
12. Other terms and conditions shall be as per your techno-commercial offers and other correspondences till date.
13. OTHER TERMS & CONDITIONS:

- The Bidder shall not involve himself or any of his representatives in Price manipulation of any kind directly or indirectly by communicating with other suppliers / bidders.
- The Bidder shall not divulge either his Bids or any other exclusive details of SBIIMS Pvt. Ltd. to any other party.
- SBIIMS Pvt. Ltd. decision on award of Contract shall be final and binding on all the Bidders.
- SBIIMS Pvt. Ltd. reserve their rights to extend, reschedule or cancel any E-tendering within its sole discretion.
- SBIIMS or its authorized service provider M/s. Antares Systems Limited shall not have any liability to Bidders for any interruption or delay in access to the site irrespective of the cause.
- SBIIMS or its authorized service provider M/s. Antares Systems Limited is not responsible for any damages, including damages that result from, but are not limited to negligence.
- SBIIMS or its authorized service M/s. Antares Systems Limited will not be held responsible for consequential damages, including but not limited to systems problems, inability to use the system, loss of electronic information etc.

N.B.

- All the Bidders are required to submit the Process Compliance Statement (Annexure II) duly signed to M/s. Antares Systems Limited.
- **All the bidders are requested to ensure that they have a valid digital signature certificate well in advance to participate in the online event.**

PROCESS COMPLIANCE STATEMENT (ANNEXURE II)

(The bidders are required to print this on their company's letter head and sign, stamp before emailing)

To,
M/s. Antares Systems Limited,
24, 3rd Stage, 4th Block,
Basaveshwaranagar, Bangalore- 560 079.
Tel: 080-4935 2000. Mobile no. 7980042472
Email: manojkumar.d@antaressystems.com

AGREEMENT TO THE PROCESS RELATED TERMS AND CONDITIONS FOR THE ONLINE E-TENDERING FOR REPLACING AND SHIFTING OF COOLING TOWERS FROM TERRACE TO GROUND FLOOR AT C-6, BLOCK G, BANDRA KURLA COMPLEX, BANDRA (E), MUMBAI 400 051

Dear Sir,

This has reference to the Terms & Conditions for the E-tendering mentioned in the Tender document

This letter is to confirm that:

- 1) The undersigned is authorized representative of the company.
- 2) We have studied the Commercial Terms and the Business rules governing the E-tendering as mentioned in RFP of SBIIMS Pvt. Ltd. as well as this document and confirm our agreement to them.
- 3) We also confirm that we have taken the training on the E-tendering tool and have understood the functionality of the same thoroughly.
- 4) We confirm that SBIIMS Pvt. Ltd. and M/s. E-tendering Technologies Ltd. shall not be liable & responsible in any manner whatsoever for my/our failure to access & bid on the e-E-tendering platform due to loss of internet connectivity, electricity failure, virus attack, problems with the PC, any other unforeseen circumstances etc. before or during the E-tendering event.
- 5) We confirm that we have a valid digital signature certificate issued by a valid Certifying Authority.

Signature of Contractor with Seal

6) We, hereby confirm that we will honor the Bids placed by us during the E-tendering process.

With regards,

Date:

Signature with company seal

Name:

Company / Organization:

Designation within Company / Organization:

Address of Company / Organization:

Scan it and send to this Document on -----

Signature of Contractor with Seal

ARTICLES OF AGREEMENT

(On non-judicial Stamp Paper of Rs. 500/- or as per latest Govt. Rules)

ARTICLES OF AGREEMENT made the _____ date of _____ between SBIIMS PVT.LTD., on behalf of SBI, having its office at Mumbai hereinafter called "the Service Provider" of _____ the _____ One _____ Part _____ and _____

WHEREAS the SBIIMS PVT.LTD. is desirous of _____

and has caused drawings and specifications describing the work to be done to be prepared by **M/s. ARCHITECTS APPROACH**, its Architects.

AND WHEREAS the said Drawings numbered _____ to _____ inclusive, the Specifications and the Schedule of Quantities have been signed by or on behalf of the parties hereto.

AND WHEREAS the Contractor has agreed to execute upon and subject to the Conditions set forth herein and to the Conditions set forth herein in the Special Conditions and in the Schedule of Quantities and Conditions of Contract (all of which are collectively hereinafter referred to as "the said conditions") the works shown upon the said Drawings and / or described in the said Specifications and included in the Schedule of Quantities at the respective rates therein set forth amounting to the sum as therein arrived at or such other sum as shall become payable there under (hereinafter referred to as "the said Contract Amount.")

NOW IT IS HEREBY AGREED AS FOLLOWS:

- 1) In consideration of the said Contract Amount to be paid at the times and in the manner set forth in the said Conditions, the Contractor shall upon and subject to the said Conditions execute and complete the work shown upon the said Drawings and described in the said Specifications and the priced Schedule of Quantities.
- 2) The Employer shall pay to the Contractor the said Contract Amount, or such other sum as shall become payable, at the times and in the manner specified in the said Conditions.
- 3) The term "the Architects" in the said Conditions shall mean the said **M/s. ARCHITECTS APPROACH**, or in the event of their ceasing to be the Architects for the purpose of this Contract for whatever reason, such other person or persons as shall be nominated for that purpose by the Employer, not being a person to whom the Contractor shall object for reasons considered to be sufficient by the Employer, PROVIDED ALWAYS that no person or persons subsequently appointed to be Architects under this Contract shall be entitled to disregard or overrule any previous decisions or approval or direction given or expressed in writing by the outgoing Architects for the time being.
- 4) The said Conditions and Appendix thereto shall be read and construed as forming part of this Agreement, and the parties hereto shall respectively abide by submit themselves to the

Signature of Contractor with Seal

said Conditions and perform the Agreements on their part respectively in the said Conditions contained.

- 5) The Plans, Agreements and Documents mentioned herein shall form the basis of this Contract.
- 6) This Contract is neither a fixed lump-sum contract nor a piece work contract but a contract to carry out the work in respect of the entire building complex to be paid for according to actual measured quantities at the rates contained in the Schedule of Quantities and Rates or as provided in the said Conditions.
- 7) The Contractor shall afford every reasonable facility for the carrying out of all works relating to civil works, installation of lifts, Telephone, electrical installations, fittings air-conditioning and other ancillary works in the manner laid down in the said Conditions, and shall make good any damages done to walls, floors, etc. after the completion of his work.
- 8) The SBIIMS Pvt. Ltd. reserves to itself the right of altering the drawings and nature of the work by adding to or omitting any items of work or having portions of the same carried out without prejudice to this Contract.
- 9) Time shall be considered as the essence of this Contract and the Contractor hereby agrees to commence the work soon after the Site is handed over to him or from 14th day after the date of issue of formal work order as provided for in the said Conditions whichever is later and to complete the entire work within **3 (Three Months)** subject to nevertheless the provisions for extension of time.
- 10) All payments by the SBI under this Contract will be made only at Mumbai.
- 11) All disputes arising out of or in any way connected with this Agreement shall be deemed to have arisen at Mumbai and only the Courts in Mumbai shall have jurisdiction to determine the same.
- 12) That the several parts of this Contract have been read by the Contractor and fully understood by the Contractor.

IN WITNESS WHEREOF THE SBIIMS PVT. LTD. and the Contractor have set their respective hands to these presents and two duplicates hereof the day and year first hereinabove written.

SIGNATURE CLAUSE

SIGNED AND DELIVERED by the

_____ By the
(Employer)

hand of Shri _____

Signature of Contractor with Seal

(Name and Designation)

(Signature of Employer)

In the presence of :

1) Shri / Smt. _____

(Signature of Witness)

Address _____

(Witness)

SIGNED AND DELIVERED by the

_____ by the
(Contractor)

(Signature of Contractors)

in the presence of :

Shri / Smt. _____

(Signature of Witness)

Address _____

(Witness)

Signature of Contractor with Seal

SECTION – 1

INSTRUCTIONS TO THE TENDERERS

1.0 Scope of work

Sealed Tenders are invited **M/s. ARCHITECTS APPROACH, Architects, & Interior Designers**, on behalf of SBIIMS PVT.LTD. for the Replacing and Shifting of Cooling Towers from Terrace to Ground Floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051 Site and its location

The proposed work is to be carried out at Terrace & Ground Floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051

2.0 Tender documents

- 2.1 The work has to be carried out strictly according to the conditions stipulated in the tender consisting of the following documents and the most workmen like manner.

Instructions to tenderers

General conditions of Contract

Special conditions of Contract

Additional specifications

Drawings

Priced bid A

- 2.2 The above documents shall be taken as complementary and mutually explanatory of one another but in case of ambiguities or discrepancies, shall take precedence in the order given below;

- a) Price Bid
- b) Additional Specifications
- c) Technical specifications
- d) Drawings
- e) Special conditions of contract
- f) General conditions of contract
- g) Instructions to Tenderers

- 2.3 Complete set of tender documents including relative drawings can be downloaded from the website www.sbi.co.in

- 2.4 The tender documents are not transferable.

Signature of Contractor with Seal

3.0 Site Visit

- 3.1 The tenderer must obtain himself on his own responsibility and his own expenses all information and data that may be required for the purpose of filling this tender document and enter into a contract for the satisfactory performance of the work. The tenderer is requested satisfy himself regarding the availability of water, power, transport and communication facilities, the character quality and quantity of the materials, labour, the law and order situation, climatic conditions local authorities requirement, traffic regulations etc;

The tenderer will be fully responsible for considering the financial effect of any or all the factors while submitting his tender.

4.0 Earnest Money

- 4.1 The tenderers are requested to submit the Earnest Money of **Rs.1,21,000/- (One Lac Twenty-One Thousand Only) by means of Demand Draft / Pay Order** (Valid for a period of 180 Days from the last date of submission of the tender) from any scheduled Nationalized Bank drawn **in favour of SBI Infra Management Solutions Pvt. Ltd. and payable in Mumbai.**
- 4.2 EMD in any other form other than as specified above will not be accepted. Tender not accompanied by the EMD in accordance with clause 4.1 above shall be rejected.
- 4.3 No interest will be paid on the EMD.
- 4.4 EMD of unsuccessful tenderer will be refunded within 30 days of award of Contract.
- 4.5 EMD of successful tenderer will be retained as a part of security deposit.

5.0 Initial/ Security Deposit

The successful tenderer will have to submit a sum equivalent to 2% of accepted tender value less EMD by means of DD drawn in favour of SBIIMS Pvt. Ltd. within a period of 15 days of acceptance of tender.

6.0 Security Deposit

- 6.1 Total security deposit shall be 5% of contract value. Out of this 2% of contract value is in the form of Initial Security Deposit (ISD) which includes the EMD. Balance 3% shall be deducted from the running account bill of the work at the rate of 10% of the respective running account bill i.e., deduction from each running bill account will be @10% till Total Security Deposit (TSD) including ISD reaches to 5% of contract value. The 50% of the Total Security Deposit shall be paid to the contract on the basis of architect's certifying the virtual completion. The balance 50% would be paid to the contractors after the defects liability period as specified in the contract.
- 6.2 **Additional Security Deposit**
In case L-1 bidder quotes abnormally low rates (i.e. 10% or more, below estimated project cost), the bank may ask such bidder to deposit additional security deposit (ASD) equivalent to difference of estimated cost vis-à-vis L-1 quoted amount for due fulfillment of contract. Such ASD could be in the form of FDR / Bank's guarantee in the Bank's name as per format approved by the Bank. On successful completion of work ASD will

Signature of Contractor with Seal

be returned to the contractor. In case contractor fails to complete the work in time or as per tender specification or leave the job incomplete, the bank will be at liberty to recover the dues from ASD or to forfeit such ASD as the case may be within its sole discretion.

6.3 No interest shall be paid to the amount retained by the Bank as Security Deposit.

7.0 **Signing of contract Documents**

The successful tenderer shall be bound to implement the contract by signing an agreement and conditions of contract attached herewith within 30 days from the receipt of intimation of acceptance of the tender by the Bank. However, the written acceptance of the tenders by the Bank will constitute a binding agreement between the Bank and successful tenderer whether such formal agreement is subsequently entered into or not.

8.0 **Completion Period**

Time is essence of the contract. The work should be completed in all respect accordance with the terms of contract within a period of **3 (Three Months)** from the date of award of work.

9.0 **Validity of tender**

Tenders shall remain valid and open for acceptance for a period of 90 days from the date of opening price bid. If the tenderer withdraws his/her offer during the value period or makes modifications in his/her original offer which are not acceptable to Bank without prejudice to any other right or remedy the Bank shall be at liberty forfeit the EMD.

10.0 **Liquidated Damages**

The liquidated damages shall be 0.50% per week subject to a maximum of 5% of contract value.

11.0 **Rate and prices:**

11.1 **In case of item rate tender**

11.1.1 The tenderers shall quote their rates for individual items both in words and figure. In case of discrepancy between the rate quoted in words and figures, the unit rate quantity in words will prevail. If no rate is quoted for a particular item the contractor shall not be paid for that item when it is executed.

The amount of each item shall be calculated and the requisite total is given. In case of discrepancy between the unit rate and the total amount calculated from multiplication of unit rate and the quantity the unit rate quoted will govern and the amount will be corrected.

11.1.2 The tenderers need not quote their rates for which no quantities have been given. In case the tenderers quote their rates for such items those rates will be ignored and will not be considered during execution.

11.1.3 The tenderers should not change the units as specified in the tender. If any unit is changed the tenders would be evaluated as per the original unit and the contractor would be paid accordingly.

Signature of Contractor with Seal

The tenderer should not change or modify or delete the description of the item. If any discrepancy is observed he should immediately bring to the knowledge of the Architect/ SBIIMS Pvt. Ltd.

11.1.4 Each page of the BOQ shall be signed by the authorized person and cutting or overwriting shall be duly attested by him.

11.1.5 Each page shall be totaled and the grand total shall be given.

11.1.6 The rate quoted shall be firm and shall include all costs, allowances, taxes, levies.

11.1.7 The SBIIMS Pvt. Ltd. reserve their rights to accept any tenders, either in whole or in part or may entrust the work in phases or may drop the part scope of work at any stage of the project within its sole discretion without assigning any reason(s) for doing so and no claim / correspondence shall be entertained in this regard.

11.1.8 In case it is decided by the SBIIMS Pvt. Ltd. to drop one or more buildings from the scope of work at any stage of the project, the contractor shall not be entitled to raise any claim / compensation for such deleted scope of work. Also, the SBIIMS Pvt. Ltd. may consider issuing work order for various buildings in phases but within a reasonable time interval and the contractor shall be bound to execute the same within the stipulated time period and as per rates quoted by them in this tender without any claim for price escalation.

SIGNATURE OF THE CONTRACTOR

WITH SEAL

Signature of Contractor with Seal

GENERAL CONDITIONS OF CONTRACT

1.0 Definitions: -

- “Contract means the documents forming the tender and the acceptance thereof and the formal agreement executed between SBI Infra Management Solutions Pvt. Ltd. (client) and the contractor, together with the documents referred there in including these conditions, the specifications, designs, drawings and instructions issued from time to time by the Architects/ Bank and all these documents taken together shall be deemed to form one contract and shall be complementary to one another.
- 1.1 In the contract the following expressions shall, unless the context otherwise requires, have the meaning hereby respectively assigned to them.
- 1.1.1 ‘SBIIMS’ shall mean V.P. & Circle Head, SBI Infra Management Solutions Pvt. Ltd., Premises Department, Local Head Office, ‘Synergy’, C-6, G-Block, Bandra Kurla Complex, Bandra (E), Mumbai 400 051 and includes the client’s representatives, successors and assigns.
- 1.1.2 ‘Architects/ Consultants’ shall mean M/s ARCHITECTS APPROACH, Architects & Interior Designers, Mumbai.
- 1.1.3 ‘Site Engineer’ shall mean an Engineer appointed by the SBIIMS at site as their representative for day-to-day supervision of work and to give instructions to the contractors.
- 1.1.4 ‘The Contractor’ shall mean the individual or firm or company whether incorporate not, undertaking the works and shall include legal personal representative of individual or the composing the firm or company and the permitted assignees of individual or firms of company.
- The expression ‘works’ or ‘work’ shall mean the permanent or temporary work description in the “Scope of work” and / or to be executed in accordance with the contract includes materials, apparatus, equipment, temporary supports, fittings and things of kinds to be provided, the obligations of the contractor hereunder and work to be done by the contractor under the contract.
- 1.1.5 ‘Engineer’ shall mean the representative of the Architect/consultant.
- 1.1.6 ‘Drawings’ shall mean the drawings prepared by the Architects and issued by the Engineer and referred to in the specifications and any modifications of such drawings as may be issued by the Engineer from time to time ‘Contract value shall mean value of the entire work as stipulated in the letter of acceptance of tender subject such additions there to or deductions there from as may be made under the provide herein after contained.
- 1.1.7 ‘Specifications’ shall mean the specifications referred to in the tender and modifications thereof as may time to time be furnished or approved by the Architect/ Consultant.
- 1.1.8 “Month” means calendar month.
- 1.1.9 “Week” means seven consecutive days.
- 1.1.10 “Day” means a calendar day beginning and ending at 00 Hrs and 24 Hrs respectively.

Signature of Contractor with Seal

- 1.1.11 "SBIIMS's Engineer" shall mean The Civil / Electrical Engineer in - charge of the Project, as nominated by the V.P. & Circle Head, SBI Infra Management Solutions Pvt. Ltd.
- 1.1.12 The following shall constitute the Joint Project Committee (herein under referred to as JPC) for assessing and reviewing the progress of the work on the project and to issue instructions or directions from time to time for being observed and followed by the Architects Site Engineer /PMC and other consultants / contractors engaged in the execution of the project.
- i) Vice President – Circle Head of SBIIMS Pvt. Ltd.
 - ii) SBIIMS Engineer (Civil and Electrical) in-charge of the Project, as may be nominated by the M.D. & CEO, SBI Infra Management Solutions Pvt. Ltd.....Members.
 - iii) Concerned partner of the Architects and their Resident Architect.... Member.

CLAUSE

1.0 Total Security Deposit

Total Security deposit comprise of

Earnest Money Deposit

Initial security deposit

Retention Money

a) Earnest Money Deposit -

The tenderer shall furnish EMD of **Rs.Rs.1,21,000/- (One Lac Twenty-One Thousand Only)** in the form of Demand draft or bankers cheque drawn in favour of SBIIMS PVT. LTD., on any Scheduled Bank. No tender shall be considered unless the EMD is so deposited in the required form. No interest shall be paid on this EMD. The EMD of the unsuccessful tenderer shall be refunded soon after the decision to award the contract is taken without interest. The EMD shall stand absolutely forfeited if the tenderer revokes his tender at any time the period when he is required to keep his tender open acceptance by the SBIIMS Pvt. Ltd. or after it is accepted by the SBIIMS Pvt. Ltd. the contractor fails to enter into a formal agreement or fails to pay the initial security deposit as stipulated or fails to commence the work within the stipulated time.

b) Initial Security Deposit (ISD)

The amount of ISD shall be 2% of accepted value of tender including the EMD in the form of DD/FDR drawn on any scheduled Bank and shall be deposited within 15 days from the date of acceptance of tender.

ADDITIONAL SECURITY DEPOSIT / PERFORMANCE GUARANTEE

In case L-1 bidder quotes abnormally low rates (i.e. 10% or more, below estimated project cost), the bank may ask such bidder to deposit additional security deposit (ASD) equivalent to difference of estimated cost vis-à-vis L-1 quoted amount for due fulfillment of contract as performance guarantee. Such ASD could be in the form of FDR / Bank's guarantee in the Bank's name as per format approved by the Bank. On successful

Signature of Contractor with Seal

completion of work ASD will be returned to the contractor. In case contractor fails to complete the work in time or as per tender specification or leave the job incomplete, the bank will be at liberty to recover the dues from ASD or to forfeit such ASD as the case may be within its sole discretion.

No interest shall be paid to the amount retained by the Bank as Security Deposit.

c) **Retention Money: -**

Besides the SD as deposited by the contractor in the above said manner, the Retention money shall be deducted from the running account bill at the rate of 10% of the gross value of work done by the contractor and claimed in each bill provided the total security deposit i.e. ISD plus EMD plus Retention Money shall both together not exceed 5% of the contract value. The 50% of the total security deposit shall be refunded to the contractor without any interest on issue of Virtual Completion certificate by the Architect/consultant. The balance 50% of the total security deposit shall be refunded to the contractors without interest within fifteen days after the end of defects liability period provided the contractor has satisfactorily attended to all defects in accordance with the conditions of contract including site clearance.

2.0 **Language**

The language in which the contract documents shall be drawn shall be in English.

3.0 **Errors, omissions and discrepancies**

In case of errors, omissions and/ or disagreement between written and scaled dimensions on the drawings or between the drawings and specifications etc., the following order shall apply.

- i) Between scaled and written dimension (or description) on a drawing, the latter shall be adopted.
- ii) Between the written or shown description or dimensions in the drawings and the corresponding one in the specification the former shall be taken as correct.
- iii) Between written description of the item in the specifications and descriptions in bills of quantities of the same item, the former shall be adopted:
 - a) In case of difference between rates written in figures and words, the rate in words shall prevail.
 - b) Between the duplicate / subsequent copies of the tender, the original tender shall be taken as correct.

4.0 **Scope of Work:**

The contractor shall carryout complete and maintain the said work in every respect strictly accordance with this contract and with the directions of and to the satisfaction Bank to be communicated through the architect/consultant. The architect/consultant at the directions of the SBIIMS from time to time issue further drawings and / or write instructions, details directions and explanations which are here after collectively references to as Architect's /consultant's instructions in regard to the variation or modification of the design, quality or quantity of any work or the addition or omission or substitution work. Any discrepancy in the drawings or between BOQ and / or drawings

Signature of Contractor with Seal

and / or specifications. The removal from the site of any material brought thereon by the Contractor and any substitution of any other materials therefore the removal and / or re-executed of any work executed by him. The dismissal from the work of any person engaged thereupon.

5.0 i) Letter of Acceptance:

Within the validity period of the tender the SBIIMS shall issue a letter of acceptance directly or through the architect by registered post or otherwise depositing at the of the contractor as given in the tender to enter into a Contract for the execution of the work as per the terms of the tender. The letter of acceptance shall constitute a bind contract between the SBIIMS and the contractor.

ii) Contract Agreement:

On receipt of intimation of the acceptance of tender from the SBIIMS Pvt. Ltd/ Architect the successful tenderer shall be bound to implement the contract and within fifteen days there of shall sign an agreement in a non-judicial stamp paper of appropriate value.

6.0 Ownership of drawings:

All drawings, specifications and copies thereof furnished by the SBIIMS Pvt. Ltd SBI through its Architect / consultants are the properties of the SBIIMS Pvt. Ltd. They are not to be used on other work.

7.0 Detailed drawings and instructions:

The SBIIMS Pvt. Ltd. through its architects / consultants shall furnish with reasonable proper additional instructions by means of drawings or otherwise necessary for the execution of the work. All such drawings and instructions shall be consistent with contract documents, true developments thereof and reasonably inferable there.

The work shall be executed in conformity therewith and the contractor prepare a detailed programme schedule indicating therein the date of start and completion of various activities on receipt of the work order and submit the same to the SBIIMS Pvt. Ltd. through the architect/consultant

7.0 Copies of agreement

Two copies of agreement duly signed by both the parties with the drawings shall be handed over to the contractors.

8.0 Liquidated damages:

If the contractor fails to maintain the required progress in terms of clause 6. 0 of GOC or to complete the work and clear the site including vacating their office on or before the contracted or extended date or completion, without justification in support of the cause of delay, he may be called upon without prejudice to any other right of remedy available under the law to the SBIIMS Pvt. Ltd. on account of such breach to pay a liquidated damages at the rate of 0.50% of the contract value which subject to a maximum of 5% of the contract value.

Signature of Contractor with Seal

9.0 Materials, Appliances and Employees

Unless or otherwise specified the contractor shall provide and pay for all materials, labour, water, power, tools, equipment transportation and any other facilities that are required for the satisfactory execution and completion of the work. Unless or otherwise specified all materials shall be new and both workmanship and materials shall be best quality. The contractor shall at all times enforce strict discipline and good order among his employees and shall not employ on the work any unfit person or anyone not skilled in the work assigned to him. Workman whose work or behavior is found to be unsatisfactory by the SBIIMS Pvt. Ltd. /Architect/ consultant he shall be removed from the site immediately.

10.0 Permits, Laws and Regulations:

Permits and licenses required for the execution of the work shall be obtained by the contractor at his own expenses. The contractor shall give notices and comply with the regulations, laws, and ordinances rules, applicable to the contract. If the contractor observes any discrepancy between the drawings and specifications, he shall promptly notify the SBIIMS Pvt. Ltd. in writing under intimation of the Architect/ Consultant. If the contractor performs any act, which is against the law, rules and regulations he shall meet all the costs arising there from and shall indemnify the SBIIMS Pvt. Ltd. any legal actions arising there from.

11.0 Setting out Work:

The contractor shall set out the work and shall be responsible for the true and perfect setting out of the same and for the correctness of the positions, levels, dimensions, and alignment of all parts thereof and get it approved by the architect / consultant before proceeding with the work. If at any time any error in this respect shall appear during the progress of the works, irrespective of the fact that the layout had been approved by, the architect / consultant the contractor shall be responsible for the same and shall his own expenses rectify such error, if so, required to satisfaction of the SBIIMS Pvt. Ltd.

12.0 Protection of works and property:

The contractor shall continuously maintain adequate protection. of all his work from damage and shall protect the SBI's properties from injury or loss arising in connection with contract. He shall make good any such damage, injury, loss, except due to causes beyond his control and due to his fault or negligence.

He shall take adequate care and steps for protection of the adjacent properties. The contractor shall take all precautions for safety and protections of his employees on the works and shall comply with all applicable provisions of Govt. and local bodies' safety laws and building codes to prevent accidents, or injuries to persons or property on about or adjacent to his place of work. The contractor shall take insurance covers as per clause 24.0 at his own cost. The policy may be taken in joint names of the contractor and the SBIIMS Pvt. Ltd. and the original policy may be lodged with the SBIIMS Pvt. Ltd.

13.0 Inspection of work:

The SBIIMS Pvt. Ltd. / Architect / Consultant or their representatives shall at all reasonable times have free access to the work site and / or to the workshop, factories, or other places where materials are lying or from where they are obtained and the

Signature of Contractor with Seal

contractor shall give every facility to the SBIIMS Pvt. Ltd./Architect/consultant and their representatives necessary for inspection and examination and test of the materials and workmanship. No person unless authorized by the SBIIMS Pvt. Ltd./ Architect /Consultant except the representative of Public authorities shall be allowed on the work at any time. The proposed work either during its construction stage or its completion can also be inspected by the Chief Technical Examiner's Organization a wing of Central Vigilance commission.

14.0 Assignment and subletting

The whole of work included in the contract shall be executed the contractor and he shall not directly entrust and engage or indirectly transfer, assign or underlet the contract or any part or share there of or interest therein without the written consent of the SBIIMS Pvt. Ltd. through the Architect and no undertaking shall relieve the contractor from the responsibility of the contractor from active & superintendence of the work during its progress.

15.0 Quality of materials, workmanship & Test

All materials and workmanship shall be best of the respective kinds described in the contract and in accordance with Architect/consultant instructions and shall be subject from time to time to such tests as the architect/consultant may direct at the place of manufacture or fabrication or on the site or an approved testing laboratory. The contractor shall provide such assistance, instruments, machinery, labor, and materials as are normally required for examining measuring sampling and testing any material or part of work before incorporation in the work for testing as may be selected and required by the architect/consultant.

ii) Samples

All samples of adequate numbers, size, shades & pattern as per specifications shall be supplied by the contractor without any extra charges. If certain items proposed to be used are of such nature that samples cannot be presented or prepared at the site detailed literature / test certificate of the same shall be provided to the satisfaction of the Architect/consultant. Before submitting the sample / literature the contractor shall satisfy himself that the material / equipment for which he is submitting the sample / literature meet with the requirement of tender specification. Only when the samples are approved in writing by the architect / consultant the contractor shall proceed with the procurement and installation of the particular material / equipment. The approved samples shall be signed by the Architect / Consultant for identification and shall be kept on record at site office until the completion of the work for inspection / comparison at any time. The Architect/Consultant shall take reasonable time to approve the sample. Any delay that might occur in approving the samples for reasons of its not meeting the specifications or other discrepancies inadequacy in furnishing samples of best qualities from various manufacturers and such other aspects causing delay on the approval of the materials / equipment etc. shall be to the account of the contractor.

iii) Cost of tests

The cost of making any test shall be borne by the contractor if such test is intended by or provided for in the specification or BOQ.

iv) Costs of tests not provided for

Signature of Contractor with Seal

If any test is ordered by the Architect/ Consultant which is either

- a) If so intended by or provided for or (in the cases above mentioned) is not so particularized, or though so intended or provided for but ordered by the Architect / Consultant to be carried out by an independent person at any place other than the site or the place of manufacture or fabrication of the materials tested or any Government / approved laboratory, then the cost of such test shall be borne by the contractor.

16.0 Obtaining information related to execution of work

No claim by the contractor for additional payment shall be entertained which is consequent upon failure on his part to obtain correct information as to any matter affecting the execution of the work nor any misunderstanding or the obtaining incorrect information or the failure to obtain correct information relieve him from any risks or from the entire responsibility for the fulfillment of contract.

17.0 Contractor's superintendence

The contractor shall give necessary personal superintendence during the execution the works and as long, thereafter, as the Architect / Consultant may consider necessary until the expiry of the defects liability period, stated here to.

18.0 Quantities

- i) The bill of quantities (BOQ) unless or otherwise stated shall be deemed to have been prepared in accordance with the Indian Standard Method of Measurements and quantities. The rate quoted shall remain valid for variation of quantity against individual item to any extent. The entire amount paid under Clause 19, 20 hereof as well as amounts of prime cost and provision sums, if any, shall be excluded.

19.0 Works to be measured

The Architect/Consultant may from time to time intimate to the contractor that he require the work to be measured and the contractor shall forthwith attend or send a quantity representative to assist the Architect in taking such measurements and calculation and to furnish all particulars or to give all assistance required by any of them. Such measurements shall be taken in accordance with the Mode of measurements detail in the specifications. The representative of the Architect / Consultant shall take measurements with the contractor's representative and the measurements shall be entered in the measurement book. The contractor or his authorised representative shall sign all the pages of the measurement book in which the measurements have been recorded in token of his acceptance. All the corrections shall be duly attested by both representatives. No over writings shall be made in the M book should the contractor not attend or neglect or omit to depute his representative to take measurements the measurements recorded by the representative of the Architect / consultant shall be final. All authorized extra work, omissions and all variations made shall be included such measurement.

20.0 Variations

Signature of Contractor with Seal

No alteration, omission or variation ordered in writing by the Architect / consultant vitiates the contract. In case the SBIIMS Pvt. Ltd. / Architect / Consultant thinks proper at any during the progress of works to make any alteration in, or additions to or omission from the works or any. alteration in the kind or quality of the materials to be used therein, the Architect / Consultant shall give notice thereof in writing to the contractor shall confirm in writing within seven days of giving such oral instructions the contract shall alter to, add to, or omit from as the case may be in accordance with such but the contractor shall not do any work extra to or make any alterations or additions to or omissions from the works or any deviation from any of the provisions of the contract, stipulations, specifications or contract drawings without previous consent in writing of the Architect/ Consultant and the value of such extras, alterations, additions or omissions shall in all cases be determined by the Architect / Consultant and the same shall be added to or deducted from the contract value, as the case may be.

21.0 Valuation of Variations

No claim for an extra shall be allowed unless it shall have been executed under the authority of the Architect / Consultant with the concurrence of the SBIIMS Pvt. Ltd. as herein mentioned. Any such extra is herein referred to as authorized extra and shall be made in accordance with the following provisions.

- a)
 - (i) The net rates or prices in the contract shall determine the valuation of the extra work where such extra work is of similar character and executed under similar conditions as the work priced herein.
 - (ii) Rates for all items, wherever possible should be derived out of the rates given in the priced BOQ.
- b) The net prices of the original tender shall determine the value of the items omitted, provided if omissions do not vary the conditions under which any remaining items of Works are carried out, otherwise the prices for the same shall be valued under sub-Clause 'c' hereunder.
- c) Where the extra works are not of similar character and/or executed under similar conditions as aforesaid or where the omissions vary the conditions under which any remaining items or works are carried out, then the contractor shall within 7 days of the receipt of the letter of acceptance inform the Architect/ consultant of the rate which he intends to charge for such items of work, duly supported by analysis of the rate or rates claimed and the Architect/ consultant shall fix such rate or prices as in the circumstances in his opinion are reasonable and proper, based on the market rate.
- d) Where extra work cannot be properly measured or valued the contractor shall be allowed day work prices at the net rates stated in the tender, of the BOQ or, if not, so stated then in accordance with the local day work rates and wages for the district; provided that in either case, vouchers specifying the daily time (and if required by the Architect/Consultant) the workman's name and materials employed be delivered for verifications to the Architect /consultant at or before the end of the week following that in which the work has been executed.
- e) It is further clarified that for all such authorized extra items where rates cannot be derived from the tender, the Contractor shall submit rates duly supported by rate analysis worked on the 'market rate basis for material, labour hire / running charges of equipment and

Signature of Contractor with Seal

wastages etc. plus 15% towards establishment charges, contractor's overheads and profit. Such items shall, not be eligible for escalation.

22.0 Final measurement

The measurement and valuation in respect of the contract shall be completed within two months of the virtual completion of the work.

23.0 Virtual Completion Certificate (VCC)

On successful completion of entire works covered by the contract to the full satisfaction of the SBIIMS Pvt. Ltd., the contractor shall ensure that the following works have been completed the satisfaction of the SBIIMS Pvt. Ltd.:

- a) Clear the site of all scaffolding, wiring, pipes, surplus materials, contractor's labour equipment and machinery.
- b) Demolish, dismantle and remove the contractor's site office, temporary works, structure including labour sheds/camps and constructions and other items and things whatsoever brought upon or erected at the site or any land allotted to the contractor by the SBIIMS Pvt. Ltd. not incorporated in the permanent works.
- c) Remove all rubbish, debris etc. from the site and the land allotted to the contractor the SBIIMS Pvt. Ltd. and shall clear, level and dress, compact the site as required by the SBIIMS Pvt. Ltd.
- d) Shall put the SBIIMS Pvt. Ltd. in undisputed custody and possession of the site and all land allot by the SBIIMS Pvt. Ltd.
- e) Shall hand over the work in a peaceful manner to the SBIIMS Pvt. Ltd.
- f) All defects / imperfections have been attended and rectified as pointed out by the Architects to the full satisfaction of SBIIMS Pvt. Ltd.

Upon the satisfactory fulfillment by the contractor as stated above, the contractor is entitled to apply to the Architect / consultant is satisfied of the completion of work. Relative to which the completion certificate has been sought, the Architect/ consultant shall within fourteen (14) days of the receipt of the application for completion certificate, issue a VCC in respect of the work for which the VCC has applied.

This issuance of a VCC shall not be without prejudice to the SBIIMS's rights and contractor liabilities under the contract including the contractor's liability for defects liability nor shall the issuance of VCC in respect of the works or work at any site be construction as a waiver of any right or claim of the SBIIMS Pvt. Ltd. against the contractor in respect of or work at the site and in respect of which the VCC has been issued.

24.0 Work by other agencies

The SBIIMS Pvt. Ltd. / Architect / consultant reserves the rights to use premises and any portion the site for execution of any work not included in the scope of this contract with may desire to have carried out by other persons simultaneously and the contractor shall not only allow but also extend reasonable facilities for the execution of such work.

Signature of Contractor with Seal

The contractor however shall not be required to provide any plant or material for the execution of such work except by special arrangement with the SBI. Such work shall be carried out in such manner as not to impede the progress of the works included in the contract.

25.0 Insurance of works

25.1 Without limiting his obligations and responsibilities under the contract the contractor shall insure in the joint names of the SBIIMS Pvt. Ltd. and the contractor against all loss of damages from whatever cause arising other than the excepted risks, for which he is responsible under the terms of contract and in such a manner that the SBIIMS Pvt. Ltd. and contractor are covered for the period stipulated I clause of GCC and are also covered during the period of maintenance for loss or damage arising from a cause, occurring prior to the commencement of the period of maintenance and for any loss or damage occasioned by the contractor in the course of any operations carried out by him for the purpose of complying with his obligations under clause.

- a) The Works for the time being executed to the estimated current Contract value thereof, or such additional sum as may be specified together with the materials for incorporation in the works at their replacement value.
- b) The constructional plant and other things brought on to the site by the contractor to the replacement value of such constructional plant and other things.
- c) Such insurance shall be effected with an insurer and in terms approved by the SBIIMS Pvt. Ltd. which approval shall not be unreasonably withheld and the contractor shall whenever required produce to the Architect / consultant the policy if insurance and the receipts for payment of the current premiums.

25.2 Damage to persons and property

The contractor shall, except if and so far as the contract provides otherwise indemnify the SBI against all losses and claims in respect of injuries or damages to any person or material or physical damage to any property whatsoever which may arise out of or in consequence of the execution and maintenance of the works and against all claims proceedings, damages, costs, charges and expenses whatsoever in respect of or in relation thereto except any compensation of damages for or with respect to:

- a) The permanent use or occupation of land by or any part thereof.
- b) The right of SBIIMS Pvt. Ltd. to execute the works or any part thereof on, over, under, in or through any lands.
- c) Injuries or damages to persons or properties which are unavoidable result of the execution or maintenance of the works in accordance with the contract
- d) Injuries or damage to persons or property resulting from any act or neglect of the SBIIMS Pvt. Ltd. their agents, employees or other contractors not being employed by the contractor or for or in respect of any claims, proceedings, damages, costs, charges and expenses in respect thereof or in relation thereto or where the injury or damage was contributed to by the contractor, his servants or agents such part of the compensation as may be just and equitable having regard to the extent of the responsibility of the

Signature of Contractor with Seal

SBIIMS Pvt. Ltd., their employees, or agents or other employees, or agents or other contractors for the damage or injury.

25.3 Contractor to indemnify SBIIMS Pvt. Ltd.

The contractor shall indemnify the SBIIMS Pvt. Ltd. against all claims, proceedings, damages, costs, charges and expenses in respect of the matters referred to in the provision sub-clause 25.2 of this clause.

25.4 Contractor's superintendence

The contractor shall fully indemnify and keep indemnified the SBIIMS Pvt. Ltd. against any action, claim, or proceeding relating to infringement or use of any patent or design or any alleged patent or design rights and shall pay any royalties which may be payable in respect of any article or part thereof included in the contract. In the event of any claim made under or action brought against SBIIMS Pvt. Ltd. in respect of such matters as aforesaid the contractor shall be immediately notified thereof and the contractor shall be at liberty, at his own expenses to settle any dispute or to conduct any litigation that may arise there from, provided that the contractor shall not be liable to indemnify the SBIIMS Pvt. Ltd. if the infringement of the patent or design or any alleged patent or design right is the direct result of an order passed by the Architect / consultant in this behalf.

25.5 Third Party Insurance

25.5.1 Before commencing the execution of the work the contractor but without limiting his obligations and responsibilities under clause 24.0 of GCC shall insure against his liability for any material or physical damage, loss, or injury which may occur to any property including that of SBIIMS Pvt. Ltd., or to any person, including any employee of the SBIIMS Pvt. Ltd., by or arising out of the execution of the works or in the carrying out of the contract, otherwise than due to the matters referred to in the provision to clause 24.0 thereof.

25.5.2 Minimum amount of Third Party Insurance

Such insurance shall be affected with an insurer and in terms approved by the SBIIMS Pvt. Ltd. which approval shall not be reasonably withheld and for at least the amount stated below. The contractor shall, whenever required, produce to the. Architect / consultant the policy or policies of insurance cover and receipts for payment of the current premiums.

25.6 The minimum insurance cover for physical property, injury, and death is Rs.5 Lakhs per occurrence with the number of occurrences limited to four. After each occurrence contractor will pay additional premium necessary to make insurance valid for four occurrences always.

25.7 Accident or Injury to workman:

25.7.1 The SBIIMS Pvt. Ltd. shall not be liable for or in respect of any damages or compensation payable at law in respect or in consequence of any accident or injury to any workmen or other person in the employment of the contractor or any sub-contractor, save and except an accident or injury resulting from any act or default of the SBIIMS Pvt. Ltd. or their agents, or employees. The contractor shall indemnify and keep indemnified SBIIMS Pvt. Ltd. against all such damages and compensation, save and except as aforesaid, and

Signature of Contractor with Seal

against all claims, proceedings, costs, charges and expenses whatsoever in respect thereof or in relation thereto.

25.7.2 Insurance against accidents etc. to workmen

The contractor shall insure against such liability with an insurer approved by the SBIIMS Pvt. Ltd. during the whole of the time that any persons are employed by him on the works and shall, when required, produce to the architect / consultant such policy of insurance and receipt for payment of the current premium. Provided always that, in respect of any persons employed by any sub-contractor the contractor's obligation to insured as aforesaid under this sub-clause shall be satisfied if the sub-contractor shall have insured against the liability in respect of such persons in such manner that SBIIMS Pvt. Ltd. is indemnified under the policy but the contractor shall require such sub-contractor to produce to the Architect /consultant when such policy of insurance and the receipt for the payment of the current premium.

25.7.3 Remedy on contractor's failure to insure

If the contractor fails to effect and keep in force the insurance referred to above or any other insurance which he may be required to effect under the terms of contract, then and in any such case the SBIIMS Pvt. Ltd. may effect and keep in force any such insurance and pay such premium or premiums as may be necessary for that purpose and from time to time deduct the amount so paid by the SBIIMS Pvt. Ltd. as aforesaid from any amount due or which may become due to the contractor, or recover the same as debt from the contractor.

25.7.4 Without prejudice to the others rights of the SBIIMS Pvt. Ltd. against contractors. In respect of such default, the employer shall be entitled to deduct from any sums payable to the contractor the amount of any damages costs, charges, and other expenses paid by the SBIIMS Pvt. Ltd. and which are payable by the contractors under this clause. The contractor shall upon settlement by the Insurer of any claim made against the insurer pursuant to a policy taken under this clause, proceed with due diligence to rebuild or repair the works destroyed or damaged. In this event all the monies received from the Insurer in respect of such damage shall be paid to the contractor and the Contractor shall not be entitled to any further payment in respect of the expenditure incurred for rebuilding or repairing of the materials or goods destroyed or damaged.

26.0 Commencement of Works:

The date of commencement of the work will be reckoned as the date, fifteen days from the date of award of letter by the SBIIMS Pvt. Ltd.

27.0 Time for completion

Time is essence of the contract and shall be strictly observed by the contractor. The entire work shall be completed within a period of **3 calendar months** from the date of commencement. If required in the contract or as directed by the Architect / consultant. The contractor shall complete certain portions of work before completion of the entire work. However, the completion date shall be reckoned as the date by which the whole work is completed as per the terms of the contract.

Signature of Contractor with Seal

28.0 Extension of time

If, in the opinion of the Architect/consultant, the work be delayed for reasons beyond the control of the contractor, the Architect/consultant may submit a recommendation to the SBIIMS Pvt. Ltd. to grant a fair and reasonable extension of time for completion of work as per the terms of contract. If the contractor needs an extension of time for the completion of work or if the completion of work is likely to be delayed for any reasons beyond the due date of completion as stipulated in the contract, the contractor shall apply to the SBIIMS Pvt. Ltd. through the Architect' Consultant in writing at least 30 Days before the expiry of the scheduled time and while applying for extension of time he shall furnish the reason in detail and his justification if an', for the delays. The architect/consultant shall submit their recommendations to the SBIIMS Pvt. Ltd. in the prescribed format for granting extension of time. While granting extension of time the contractor shall be informed the period extended time which will qualify for levy of liquidated damages. For the balance period in excess of original stipulated period and duly sanctioned extension of time by the provision of liquidated damages as stated under clause 10.0 shall become applicable. Further the contract shall remain in force even for the period beyond the due date of completion irrespective whether the extension is granted or not.

29.0 Rate of progress

Whole of the materials, plant and labour to be provided by the contractor and the mode, manner and speed of execution and maintenance of the works are to be of a kind and conducted in a manner to the satisfaction of the Architect / consultant should the rate of progress of the work or any part thereof be at any time be in the opinion the. Architect / consultant too Slow to ensure the completion of the whole of the work the prescribed time or extended time for completion the Architect / consultant shall thereupon take such steps as considered necessary by the Architect / consultant to expedite progress so as to complete the works by the prescribed time or extended time. Such communications from the Architect / consultant neither shall relieve. The contractor from fulfilling obligations under the contract nor he will be entitled to raise any claims arising out of such directions.

30.0 Work during nights and holidays

Subject to any provision to the contrary contained in the contract no permanent work shall save as herein provided be carried on during the night or on holidays without the permission in writing of the Architect / consultant, save when the work is unavoidable or absolutely necessary for the saving of life or property or for the safety of the work in which case the contractor shall immediately advise the Architect / consultant. However the provisions of the clause shall not be applicable in the case of any work which becomes essential to carry by rotary or double shifts in order to achieve the progress and quality of the part of the works being technically required / continued with the prior approval of the Architect / consultant at no extra cost to the SBIIMS Pvt. Ltd..

All work at night after obtaining approval from competent authorities shall be carried out without unreasonable noise and disturbance.

31.0 No compensation or restrictions of work

If at any time after acceptance of the tender SBIIMS Pvt. Ltd. shall decide to abandon or reduce the scope of work for any reason whatsoever and hence not required the

Signature of Contractor with Seal

whole or any part of the work to be carried out. The Architect / consultant shall give notice in writing to that effect to the contractor and the contractor shall act accordingly in the matter. The contractor shall have no claim to any payment of compensation or otherwise what so ever on account of any profit or advantage which he might have derived from the execution of the Work fully but which he did not derive in consequence of the foreclosure of the whole or part of the work.

Provided that the contractor shall be paid the charges on the cartage only of materials actually and bonafide brought to the site of the work by the contractor and rendered surplus as a result of the abandonment, curtailment of the work or any portion thereof and then taken back by the contractor, provided however that the Architect / Consultant shall have in such cases the option of taking over all or any such materials at their purchase price or a local current rate whichever is less.

“In case of such stores having been issued from SBIIMS Pvt. Ltd. stores and returned by the contractor to stores, credit shall be given to him at the rates not exceeding those at which were originally issued to the contractor after taking into consideration and deduction for claims on account of any deterioration or damage while in the custody of the contractor and in this respect the decision of Architect / consultant shall be final.

32.0 Suspension of work

- i) The contractor shall, on receipt of the order in writing of the Architect / consultant (whose decision shall be final and binding on the contractor) suspend the progress of works or any part thereof for such time and in such manner as Architect /consultant may consider necessary so as not to cause any damage or injury to the work already done or endanger the safety thereof for any of following reasons:
 - a) On account any default on the part of the contractor, or
 - b) For proper execution of the works or part thereof for reasons other than the default the contractor, or
 - c) For safety of the works or part thereof.
- The contractor shall, during such suspension, properly protect and secure the works the extent necessary and carry out the instructions given in that behalf by the Architect / consultant.
- i) If the suspension is ordered for reasons (b) and (c) in sub-para (i) above:
The contractor shall be entitled to an extension of time equal to the period of every such suspension. No compensation whatsoever shall be paid on this account.

33 Action when the whole security deposit is forfeited

In any case in which under any clause or clauses of this contract, the Contractor shall have rendered himself liable to pay compensation amounting to the whole of his security deposit the Architect / consultant shall have the power to adopt any of the following course as they may deem best suited to the interest of the SBIIMS Pvt. Ltd.:

- a) To rescind the contract (of which rescission notice in writing to the contractor by - Architect / consultant shall be conclusive evidence) and in which case the security, deposit of the contractor shall be forfeited and be absolutely at the disposal of SBIIMS Pvt. Ltd..

Signature of Contractor with Seal

- b) To employ labour paid by the SBIIMS Pvt. Ltd. and to supply materials to carry out the work, or part of the work, debiting the contractor with the cost of the labour and materials cost of such labour and materials as worked out by the Architect/consultant shall final and conclusive against the contractor) and crediting him with the value of the work done, in all respects in the same manner and at the same manner and at the same rates as if it had been carried out by the contractor under the terms of this contract certificate of architect /consultant as to the value of work done shall be final conclusive against the contractor.
- c) To measure up the work of the contractor, and to take such part thereof as shall unexecuted, out of his hands, and to give it to another contractor to complete in which case any expenses which may be incurred in excess of the sum which would have been paid to the original contractor, if the whole work had been executed by him (The amount of which excess the certificates in writing of the Architects / consultant shall final and conclusive) shall be borne by original contractor and may be deducted f any money due to him by SBIIMS Pvt. Ltd. under the contract or otherwise, or from his security deposit or the proceeds of sale thereof, or sufficient part thereof.

In the event of any of above courses being adopted by the SBIIMS Pvt. Ltd. the contractor shall have no claim to compensation for any loss sustained by him by reasons of his having purchased or procured any material or entered into any engagements or make any advances on account of, or with a view to the execution of the work or the performance of the contract and in case the contract shall be rescind under the provision aforesaid, the contractor shall not be entitled to recover or to be paid any sum or any work thereto for actually performed under this contract, unless, and until the Architect / consultant will have certified in writing the performance of such work and the value payable in respect thereof, and he shall only be entitled to be paid the value so certified.

34.0 **Owner's right to terminate the contract**

If the contractor being an individual or a firm commit any 'Act of insolvency' or shall be adjusted an insolvent or being an incorporated company shall have an order for compulsory winding up voluntarily or subject to the supervision of Govt. and of the Official Assignee of the liquidator in such acts of insolvency or winding up shall be unable within seven days after notice to him to do so, to show to the reasonable satisfaction of the Architect / Consultant that he is able to carry out and fulfill the contract, and to dye security therefore if so required by the Architect / Consultant.

Or if the contractor (whether an individual firm or incorporated Company) shall suffer execution to be issued or shall suffer any payment under this contract to be attached by or on behalf of any of the creditors of the contractor.

Or shall assign or sublet this contract without the consent in writing of the SBIIMS Pvt. Ltd. through the Architect/Consultant or shall charge or encumber this contract or any payment due to which may become due to the contractor there under:

- a) has abandoned the contract; or
- b) has failed to commence the works, or has without any lawful excuse under these conditions suspended the progress of the works for 14 days after receiving from the SBIIMS Pvt. Ltd. through the Architect / consultant written notice to proceed, or
- c) has failed to proceed with the works with such diligence and failed to make such due progress as would enable the works to be completed within the time agreed upon, or

Signature of Contractor with Seal

has failed to remove the materials from the site or to pull down and replace work within seven days after written notice from the SBIIMS Pvt. Ltd. through the Architect / Consultant that the said materials were condemned and rejected by the Architect/consultant under these conditions; or has neglected or failed persistently to observe and perform all or any of the acts matters or things by this contract to be observed and performed by the contractor for seven days after written notice shall have been given to the contractor to observe or perform the same or has to the detriment of good workmanship or in defiance of the SBIIMS Pvt. Ltd. or Architect's / consultant's instructions to the contrary subject any part of the contract. Then and in any of said cases the SBIIMS Pvt. Ltd. and or the Architect / consultant, may not withstanding any previous waiver, after giving seven days' notice in writing to the contractor, determine the contract, but without thereby affecting the powers of the SBIIMS Pvt. Ltd. or the Architect / consultant or the obligation and liabilities of the contractor the whole of which shall continue in force as fully as if the contract had not been determined and as if the works subsequently had been executed by or on behalf of the contractor. And, further the SBIIMS Pvt. Ltd. through the Architect / consultant their agents or employees may enter upon and take possession of the work and all plants, tools scaffoldings, materials, sheds, machineries lying upon the premises or on the adjoining lands or roads use the same by means of their own employees or workmen in carrying on and completing the work or by engaging any other contractors or persons to the work and the contractor shall not in any way interrupt or do any act, matter or thing to prevent or hinder such other contractor or other persons employed for complement and finishing or using the materials and plant for the works.

When the works shall be completed or as soon thereafter as convenient the SBIIMS Pvt. Ltd. or architect / consultant shall give a notice in writing to the contractor to remove his surplus materials and plants and should the contractor fail to do so within 14 days after receive thereof by him the SBIIMS Pvt. Ltd. sell the same by publication, and after due publication, and shall, adjust the amount realized by such auction. The contractor shall have no right to question any of the act of the SBIIMS Pvt. Ltd. incidental to the sale of the materials etc.

35.0 Certificate of payment

The contractor shall be entitled under the certificates to be issued by the Architect / consultant to the contractor within 10 working days from the date of certificate to payment from SBIIMS Pvt. Ltd. from time to time. The SBIIMS Pvt. Ltd. shall recover the statutory recovering other dues including the retention amount from the certificate of payment.

Provided always that the issue of any certificate by the Architect / consultant during progress of works or completion shall not have effect as certificate of satisfaction relieve the contractor from his liability under clause.

The Architect / consultant shall have power to withhold the certificate if the work or in part thereof is not carried out to their satisfaction.

The Architect / consultant may by any certificate make any corrections required previous certificate.

The SBIIMS Pvt. Ltd. shall modify the certificate of payment as issued by the architect / consultant from time to time while making the payment

Signature of Contractor with Seal

The contractor shall submit interim bills only after taking actual measurements and properly recorded in the M books

The Contractor shall not submit interim bills when the approximate value of work done by him is less than Rs. 10.0 Lakhs.

The final bill may be submitted by contractor within a period of one month from the date of virtual completion and Architect / consultant shall issue the certificate of payment within a period of two months. The SBIIMS Pvt. Ltd. shall pay the amount within a period of three months from the date of issue of certificate provided there is no dispute in respect of rates and quantities.

The contractor shall submit the interim bills in the prescribed format with all details.

36.0 A. Settlement of Disputes and Arbitration

Except where otherwise provided in the contract all questions and disputes to the meaning of the specifications, design, drawings and instructions herein before mentioned and as to the quality of workmanship or materials used on the work or as to any other question, claim, right, matter or thing whatsoever in any way arising out of or relating to the contract, designs, drawings specifications, estimates, instructions orders or these conditions or otherwise concerning the work or the execution or failure to execute the same whether arising during the progress of the work or after the cancellation, termination, completion or abandonment thereof shall be dealt with as mentioned hereinafter:

- i) If the contractor considers that he is entitled to any extra payment or compensation in respect of the works over and above the amounts admitted as payable by the Architect or in case the contractor wants to dispute the validity of any deductions or recoveries made or proposed to be made from the contract or raise any dispute, the contractor shall forthwith give notice in writing of his claim, or dispute to The M.D.& C.E.O. SBIIMS Pvt. Ltd., Head Office, Raheja Chambers, Free Press Journal Marg, Mumbai and endorse a copy of the same to the Architect, within 30 days from the date of disallowance thereof or the date of deduction or recovery. The said notice shall give full particulars of the claim, grounds on which it is based and detailed calculations of the amount claimed and the contractor shall not be entitled to raise any claim nor shall the SBIIMS Pvt. Ltd be in any way liable in respect of any claim by the contractor unless notice of such claim shall have been given by the contractor to the M.D.& C.E.O. SBIIMS Pvt. Ltd., Head Office in the manner and within the time as aforesaid. The Contractor shall be deemed to have waived and extinguished all his rights in respect of any claim not notified to the M.D.&C.E.O. SBIIMS Pvt. Ltd., Head Office in writing in the manner and within the time aforesaid.

B. Settlement of Disputes and Arbitration

The M.D.& C.E.O. SBIIMS Pvt. Ltd., Head Office shall give his decision in writing on the claims notified by the receipt of the contractor may within 30 days of the receipt of the decision of the M.D.& C.E.O. SBIIMS Pvt. Ltd., Head Office/ Submit his claims to the conciliating authority namely the M.D.& C.E.O. SBIIMS Pvt. Ltd., Head Office, Raheja Chambers, Free Press Journal Marg, Mumbai. For conciliation along with all details and copies of correspondence exchanged between him and the SBIIMS Pvt. Ltd.

Signature of Contractor with Seal

- iii) If the conciliation proceedings are terminated without settlement of the disputes, the contractor shall, within a period of 30 days of termination thereof shall give a notice to the concerned M.D. & C.E.O. of the SBIIMS Pvt. Ltd. for appointment of an arbitrator to adjudicate the notified claims falling which the claims of the contractor shall be deemed to have been considered absolutely barred and waived.
- iv) Except where the decision has become final, binding and conclusive in terms of the contract, all disputes or differences arising out of the notified claims of the contractor as aforesaid and all claims of the SBIIMS Pvt. Ltd shall be referred for adjudication through arbitration by the Sole Arbitrator appointed by the M.D. & C.E.O. and who will be of Deputy General Manager rank. It will also be no objection to any such appointment that the Arbitrator so appointed is a SBIIMS Pvt. Ltd., Officer and that he had to deal with the matters to which the Contract relates in the course of his duties as SBIIMS Pvt. Ltd., Officer. If the arbitrator so appointed is unable or unwilling to act or resigns his appointment or vacates his office due to any reason whatsoever another sole arbitrator shall be appointed in the manner aforesaid by the said M.D. & C.E.O. of the SBIIMS Pvt. Ltd. Such person shall be entitled to proceed with the reference from the stage at which it was let by his predecessor.

It is a term of this contract that the party invoking arbitration shall give a list of disputes with amounts claimed in respect of each dispute along with the notice for appointment of arbitrator.

It is also a term of this contract that no person other than a person appointed by such Chief General Manager as aforesaid should act as arbitrator.

The conciliation and arbitration shall be conducted in accordance with the provisions of the Arbitration & Conciliation Act 1996 or any or any accordance modification or reenactment thereof and the rules made there under.

It is also a term of the contract that if any fees are payable to the Arbitrator these shall be paid equally by both the parties. However, no fees will be payable to the arbitrator if he is a SBIIMS Pvt. Ltd. Officer.

It is also a term of the contract that the Arbitrator shall be deemed to have entered on the reference on the date he issues notice to both the parties calling them to submit their statement of claims and counter statement of claims. The venue of the arbitration shall be such place as may be fixed by the arbitrator in his sole discretion. The fees, if any of the arbitrators shall, if required to be paid before the award is made and published, be paid half and half by each of the parties. The Cost of the reference and of the award (including the fees, if any of the arbitrator) shall be in the discretion of the arbitrator who may direct to any by whom and in what manner, such costs or any part thereof, shall be paid and fix or settle the amount of costs to be so paid.

37.0 Water supply

The contractor shall make his own arrangements for water required for the work and nothing extra will be paid for the same. This will be subject to the following condition.

- i) That the water used by the contractor shall be fit for construction purposes to the satisfaction of the Architect / consultant's.

Signature of Contractor with Seal

- ii) The contractor shall make alternative arrangements for the supply of water if the arrangement made by the contractor for procurement of water in the opinion of the Architect / consultant is unsatisfactory.
- iii) In case contractor is permitted to use SBIIMS's source of water i.e. Municipal connection, Bore well (existing or new) etc., the SBIIMS Pvt. Ltd may consider recovering @1% of contract amount from the final bill of contractor.

37.1 The contractor shall construct temporary well / tube well in SBIIMS Pvt. Ltd land for taking water for construction purposes only after obtaining permission in writing from the SBIIMS Pvt. Ltd. The contractor has to make his own arrangements for drawing and distributing the water at his own cost. He has to make necessary arrangements. To avoid any accidents or damages caused due to construction and subsequent maintenance of the wells. He has to obtain necessary approvals from local authorities, if required, at his own cost. He shall restore the ground to its original condition after wells are dismantled on completion of work or hand over the well to the SBIIMS Pvt. Ltd. without any compensation as directed by the architect / consultant.

38.0 **Power supply**

The contractor shall make his own arrangements for power and supply / distribution system for driving plant or machinery for the work and for lighting purpose at his own cost, The cost of running and maintenance of the plants are to be included in his tender prices, He shall pay all fees and charges required, by the power supply and include the same in his tendered rates and hold the owner free from all such costs. He has to obtain necessary approval from the appropriate authorities, if required.

39.0 **Treasure trove etc.**

Any treasure trove, coin or object antique which may be found on the site shall be the property of SBIIMS Pvt. Ltd. and shall be handed over to the bank immediately.

40.0 **Method of measurement**

Unless otherwise mentioned in the schedule of quantities or in mode of measurement, the measurement will be on the net quantities or work produced in accordance with up to date rules laid down by the Bureau of Indian Standards. In the event any dispute / disagreement the decision of the Architect / consultant shall be final and binding on the corrector.

41.0 **Maintenance of registers**

The contractor shall maintain the following registers as per the enclosed perform at site of work and should produce the same for inspection of SBIIMS Pvt. Ltd/Architect / consultant whenever desired by them. The contractor shall also maintain the records / registers as required by the local authorities / Govt. from time to time.

- i) Register for secured advance
- ii) Register for hindrance to work
- iii) Register for running account bill
- iv) Register for labour

Signature of Contractor with Seal

42.0 Force Majeure

- 42.1 Neither contractor nor SBIIMS Pvt. Ltd. shall be considered in default in performance of the obligations if such performance is prevented or delayed by events such as but not war, hostilities revolution, riots, civil commotion, strikes, lockout, conflagrations, epidemics, accidents, fire, storms, floods, droughts, earthquakes or ordinances or any act of or for any other cause beyond the reasonable control of the party affected or prevents or delayed. However a notice is required to be given within 30 days from the happening of the event with complete details, to the other party to the contract, if it is not possible to serve a notice, within the shortest possible period without delay.
- 42.2 As soon as the cause of force majeure has been removed the party whose ability perform its obligations has been affected, shall notify the other of such cessation and the actual delay incurred in such affected activity adducing necessary evidence in support thereof.
- 42.3 From the date of occurrence of a case of force majeure obligations of the party affected shall be suspended during the continuance of any inability so caused. With the caused itself and inability resulting there from having been removed, the agreed time completion of the respective obligations under this agreement shall stand extended a period equal to the period of delay occasioned by such events.
- 42.4 Should one or both parties be prevented from fulfilling the contractual obligations by state of force majeure lasting to a period of 6 months or wore the two parties, shall each other to decide regarding the future execution of this agreement.

43.0 Local laws, Acts Regulations:

The contractor shall strictly adhere to all prevailing labour laws inclusive at contract labour (regulation and abolition act of 1970) and other safety regulations. The contractors should comply with the provision of all labour legislation including the latest requirements of the Acts, laws, any other regulations that are applicable to the execution of the project.

- i) Minimum wages Act 1948 (Amended)
- ii) Payment of wages Act 1936 (Amended)
- iii) Workmen's compensation Act 1923 (Amended)
- iv) Contract labour regulation and abolition act 1970 and central rules 1971 (Amended)
- v) Apprentice act 1961 (amended)
- vi) Industrial employment (standing order) Act 1946 (Amended)
- vii) Personal injuries (Compensation insurance) act 1 963 and any other modifications
- viii) Employees' provident fund and miscellaneous provisions Act 1952 and amendment thereof
- ix) Shop and establishment act
- x) Any other act or enactment relating thereto and rules framed there under from time to time.
- xi) Prevailing Indian Electricity rules & act.

44.0 Accidents

The contractor shall immediately on occurrence of any accident at or about the site or in connection with the execution of the work report such accident to the architect / consultant. The contractor shall also such report immediately to the competent authority whenever such report is required to be lodged by the law and take appropriate actions thereof.

Signature of Contractor with Seal

SPECIAL CONDITION OF CONTRACT

Scope of work

1.0 The scope of work is to carry out for the Replacing and Shifting of Cooling Towers from Terrace to Ground Floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051.

2.0 Address of site

The site is located at Metro Local Head Office, C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051

3.0 Dimensions and levels

All dimensions and levels shown on the drawings shall be verified by the contractor and the site and he will be held responsible for the accuracy and maintenance of. All the dimensions and the levels. Figured dimensions are in all cases to be accepted and dimension shall be scaled. Large scale details shall take precedence over small scale drawings. In case of discrepancy the contractor shall ask for clarification from the Architect / consultant before proceeding with the work.

04 Notice of operation

The contractor shall not carry out any important operation without the Consent in with from the Architect / consultant:

5.0 Construction records

The contractor shall keep and provide to the Architect / consultant full and accurate records of the dimensions and positions of all new work and any other information necessary to prepare complete drawings recording details of the work as construction.

6.0 Safety of adjacent structures and trees

The contractor shall provide and erect to the approval of the Architect / consultant supports as may be required to protect effectively all structures and protective give to trees, which may be endangered by the execution of the works or otherwise such permanent measures as may be required by the Architect to protect the tree structures.

7.0 Temporary works.

Before any temporary works are commenced the contractor shall submit at least in advance to the architect / consultant for approval complete drawings of all temporary works he may require for the execution of the works. The contractor shall carry out the modifications relating to strength, if required by the architect / consultant may require in accordance with the conditions of contract at his own cost The contractor shall be solely responsible for the stability and safety of all temporary works and unfinished works and for the quality of the permanent works resulting from the arrangement eventually adopted for their execution.

Signature of Contractor with Seal

8.0 Water power and other facilities

- a) The rate quoted by the contractor shall include all expenses that are required for providing all the water required for the work and the contractor shall make his own arrangements for the supply of good quality water suitable for the construction and good quality drinking water for their workers. If necessary the contractor has to sink a tube well / open well and bring water by means of tankers at his own cost for the purpose. The SBIIMS Pvt. Ltd. will not be liable to pay any charges in connection with the above.
- b) The rate quoted in the tender shall include the expenses for obtaining and maintaining power connections and shall pay for the consumption charges.
- c) The contractors for other trades directly appointed by the SBIIMS Pvt. Ltd. shall be entitled to take power and water connections from the temporary water and power supply obtained by the contractor. However, the concerned contractor shall make their own arrangements to draw the supply and pay directly the actual consumption charges at mutually agreed rates between them. All municipal charges for drainage and water connection for construction purposes shall be borne by the contractor and charges payable for permanent connections, if any, shall be initially paid by the contractor and the SBIIMS Pvt. Ltd. will reimburse the amount on production of receipts.
- d) The SBIIMS Pvt. Ltd. as well as the Architect / consultant shall give all possible assistance to the Contractor's to obtain the requisite Permission from the various authorities, but the responsibility for obtaining the same in time shall be of the contractor.

9.0 Facilities for contractor's employees

The contractor shall make his own arrangement for the housing and welfare of his staff and workmen including adequate drinking water facilities. The contractor shall also make the arrangements at his own cost for transport where necessary for his staff and workmen to and from site of work at his own cost.

10.0 Lighting of works

The contractor shall at all times provide adequate and approved lighting as required for the proper execution and supervision and inspection of work.

11.0 Firefighting arrangements

- i) The contractor shall provide suitable arrangement for firefighting at his own cost. This purpose he shall provide requisite number of fire extinguishers and adequate number of buckets, some of which are to be always kept filled with sand and some with water. These equipment shall be provided at suitable prominent and easily accessible place and shall be properly maintained.
- ii) Any deficiency in the fire safety or unsafe conditions shall be corrected by the contractor at his own cost and, to the approval of the relevant authorities. The contractor make the following arrangements at his own cost but not limited to the following:
 - a) Proper handling, storage and disposal of combustible materials and waste.
 - b) Work operations which can create fire hazards.
 - c) Access for fire-fighting equipments.

Signature of Contractor with Seal

- d) Type, number and location of containers for the removal of surplus materials and rubbish.
- e) Type, size, number and location of fire extinguishers or other fire fighting equipment.
- f) General house keeping

12.0 Site order book

A site order book shall be maintained at site for the purpose of quick communication between the Architect / Consultant. Any communication relating to the work may be conveyed through records in the site order book. Such a communication from one party to the other shall be deemed to have been adequately served in terms of contract. Each site order book shall have machine numbered pages in triplicate and shall be carefully maintained and preserved by the contractor and shall be made available to the architect / consultant as and when demanded. Any instruction which the architect / consultant may like to issue to the contractor or the contractor may like to bring to the architect / consultant two copies of such instructions shall be taken from the site order book and one copy will be handed over to the party against proper acknowledgment and the second copy will be retained for their record.

13.0 Temporary fencing/ barricading

The contractor shall provide and maintain a suitable temporary fencing / barricading and gates at his cost to adequately enclose all boundaries of the site for the protection of the public and for the proper execution and security of the work and in accordance with the requirement of the architect / consultant and regulations of local authorities. These shall be altered, relocated and adopted from time to time as necessary and removed on completion of the work.

14.0 Site meetings

Site meetings will be held to review the progress and quality evaluation. The contractor shall depute a senior representative along with the site representative and other staff of approved sub-contractors and suppliers as required to the site meetings and ensure all follow up actions. Any additional review meetings shall be held if required by the architect/ consultant. -

15.0 Disposal of refuse

The contractor shall cart away all debris, refuse etc. arising from the work from the site and deposit the same as directed by the architect / consultant at his own cost. It is the responsibility of the contractor to obtain from the local authorities concerned to the effect that all rubbish arising out of contractor's activities at the construction site or any other off-site activities borrow pits has been properly disposed off.

16.0 Contractor to verify site measurement

The contractor shall check and verify all site measurements whenever requested other specialists contractors or other sub-contractors to enable them to prepare the own shop drawing and pass on the information with sufficient promptness as will in any way delay the works.

Signature of Contractor with Seal

17.0 Displaying the name of the work

The contractor shall put up a name board of suitable size as directed by the architect/consultant indicating therein the name of the project and other details as given by the architect/consultant at his own cost and remove the same on completion of work.

18.0 As built drawings

- i) For the drawings issued to the contractor by the Architect / Consultant. The architect Consultant will issue two sets of drawings to the Contractor for the items for some changes have been made. From the approved drawings as instructed by the SBIIMS Pvt. Ltd. / Architect / Consultant. The contractor will make the changes made on these copies and return these copies to the architect / Consultant for their approval. In cases revision is required or the corrections are not properly marked the architect / Consultant will point out the discrepancies to the contractor. The contractor will have to incorporated these corrections and / or attend to discrepancies either on copies as directed by the architect / consultant and resubmit to him for approval. The architect / consultant will return one copy duly approved by him.

- ii) For the drawings prepared by the contractor

The contractor will modify the drawing prepared by him wherever the changes made by the SBIIMS Pvt. Ltd. / architect / consultant. And submit two copies of such modified drawings to the architect/ consultant for approval. The architect / consultant will return one copy of the approved drawing to the contractor.

19.0 Approved make

The contractor shall provide all materials from the list of approved makes at his own cost and also appoint the specialized agency for the waterproofing anti-termite, aluminum doors and windows and any other item as specified in the tender. The architect/consultant may approve any make / agency within the approved list as given in the tender after inspection of the sample/mock up.

20.0 Procurement of materials

The contractor shall make his own arrangements to procure all the required materials for the work .All wastages and losses in weight shall be to the contractors account

21.0 Excise duty, taxes, levies etc.;

The contractor shall pay and be responsible for payment of all taxes, duties, levies, royalties, fees, cess or charges in respect of the works including but not limited to sales tax, tax on works contract excise duty, and octroi, payable in respect of materials, equipment plant and other things required for the contact. All of the aforesaid taxes, duties, levies, fees and charges shall be to the contractor's account and the SBIIMS Pvt. Ltd. shall not be required to pay any additional or extra amount on this account. Variation of taxes, duties, fees, levies etc. if any, till completion of work shall be deemed to be included in the quoted rates and no extra amount on this account. Variation of taxes, duties, fees, levies etc. if any, till completion of work shall be deemed to be included in the quoted rates and no extra claim on this account will in any case be entertained. If a new tax or duty or levy or cess or royalty or octroi is imposed under as statutory law during the currency of contract the same shall be borne by the contractor.

Signature of Contractor with Seal

22.0 Acceptance of tender

The SBIIMS Pvt. Ltd. shall have the right to reject any or all tenders without assigning any reason. They are not to bind to accept the lowest or any tender and the tenderer or tenderers shall have no right to question the acts of the SBIIMS Pvt. Ltd. However adequate transparency would be maintained by the SBIIMS Pvt. Ltd.

23.0 Photographs:

- The Contractor shall at his own expense supply to the Architects with duplicate hard copies of large photographs not less than 25 cm. x 20 cm. (10" x 8") of the works, taken from two approved portions of each building, at intervals of not more than one months during the progress of the work or at every important stage of construction.
- In addition to above, the contractor shall be bound to submit adequate no. of site photographs along with their each Running Bill for the project clearing showing major progress of work measured and claimed therein failing which the Architect/ SBIIMS Pvt. Ltd. may consider returning the Bill to the contractor and no claim for delay on this account will be entertained.

SAFETY CODE

1. First aid appliances including adequate supply of sterilized dressing and cotton wool shall be kept in a readily accessible place.
2. An injured person shall be taken to a public hospital without loss of time, in cases when the injury necessitates hospitalization.
3. Suitable and strong scaffolds should be provided for workmen for all works that cannot safely be done from the ground.
4. No portable single ladder shall be over 8 meters in length. The width between the side rails shall not be less than 30 cm. (clear) and the distance between two adjacent runnings shall not be more than 30 cm. When a ladder is used an extra mazdoor shall be engaged for holding ladder.
5. The excavated material shall not be placed within 1.5 meters of the edge of the trench half of the depth of trench whichever is more. All trenches and excavations shall be provided with necessary fencing and lighting.
6. Every opening in the floor of a building or in a working platform be provided with suitable means to prevent the fall of persons or materials by providing suitable fencing or railing whose minimum height shall be one meter.
7. No floor, roof or other part of the structure shall be so overloaded with debris or material as to render it unsafe.
8. Workers employed on mixing and handling material such as asphalt, cement, mortar, concrete and lime shall be provided with protective footwear and rubber hand gloves.

Signature of Contractor with Seal

- 9 Those engaged in welding works shall be provided with welders' protective eye shield and gloves.
10. (i) No paint containing lead or lead products shall be used except in the form of paste readymade paint.
(ii) Suitable facemasks should be supplied for use by the workers when the paint applied in the form of spray or surface having lead paint dry rubbed and scrapped.
11. Overalls shall be supplied by the contractor to the painters and adequate facilities shall be provided to enable the working painters to wash during cessation of work.
- 12 Hoisting machines and tackle used in the works including their attachments anchor and supports shall be in perfect condition.
13. The ropes used in hoisting or lowering material or as a means of suspension shall be durable quality and adequate strength and free from defects.

APPENDIX HEREINBEFORE REFERRED TO

- | | |
|---|---|
| 1) Name of the organization Offering Contract | :The V.P. & Circle Head, SBI Infra Management Solutions Pvt. Ltd., State Bank of India, Premises Department, Local Head Office, 'Synergy', C-6, G-Block, Bandra Kurla Complex, Bandra (E), Mumbai 400 051 |
| 2) Consultants | : M/s. ARCHITECTS APPROACH
Architects & Interior Designers,
20, Shridhar, Hanuman Road,
Vile-parle (East), Mumbai 400057.
TEL. NO. 26146829 / 26163137
FAX NO. 26163137
E-mail:architectsapproach@gmail.com |
| 3) Site Address | : Local Head Office Floor C-6, Block G,
Bandra Kurla Complex, Bandra (E),
Mumbai 400 051 |
| 4) Scope of Work | : Replacing and Shifting of Cooling Towers
from Terrace to Ground Floor C-6, Block
G, Bandra Kurla Complex, Bandra (E),
Mumbai 400 051. |
| 5) Name of the Contractor | : -----

----- |
| 6) Address of the Contractor | : ----- |

Signature of Contractor with Seal

- -----
- 7) Period of Completion : 3 (Three) months from the dated of Commencement
 - 8) Earnest Money Deposit : **Rs. 1,21,000/- (One Lac Twenty One Thousand Only) by means of Demand Draft / Pay Order**
from any scheduled Nationalized Bank drawn **in favour of SBI Infra Management Solutions Pvt. Ltd. and payable in Mumbai.**
 - 9) Retention Money : As per clause no. 11(a) of general Conditions
 - 10) Defects Liability Period : Twelve Months from the date of Virtual Completion.
 - 11) Insurance to be undertaken by the Contractor at his cost : 125% of Contract Value (Contractor's all risk policy)
 - 12) Liquidated damages : 0.5% of the Contract amount shown in the tender per week subject to max. 5% of the contract value or actual final bill value.
 - 13) Value of Interim Bill (Min.) : Rs. 20.00 Lakhs.
 - 14) Date of Commencement : 15 days from the date of acceptance letter is issued to the Contractor/ or the day on which the Contractor is instructed to take possession of the site whichever is earlier.
 - 15) Period of Final Measurement : 3 Months from the date of Virtual Completion.
 - 16) Initial Security Deposit Tender. (Clause No. 22) : 2% of the Accepted Value of the
 - 17) Total Security Deposit : As per clause No. 11 a
 - 18) Refund of initial Security Deposit Comprising of EMD and ISD. : 50% of the Security Deposit shall be refunded to the Contractor on completion of the work and balance refunded only after the Defect Liability Period is over.
 - 19) Period for Honoring Certificate : 1. One Month for R.A. Bills
2. The final bill will be submitted by the

Signature of Contractor with Seal

Contractor within one month of the date fixed for completion work and the Bill shall be Certified within 3 months from the date of receipt of final bill provided the bills are submitted with all pre-requisite documents/test reports etc. prescribed in the tender.

Signature of Tenderer.

Date:

LETTER OF DECLARATION

To,
The V.P. Circle Head,
SBI Infra Management Solutions Pvt. Ltd.
State Bank of India, Local Head Office,
'Synergy', C-6, G-Block,
Bandra Kurla Complex,
Bandra, Mumbai- 400 021.

Dear Sir,

REPLACING AND SHIFTING OF COOLING TOWERS FROM TERRACE TO GROUND FLOOR AT C-6, BLOCK G, BANDRA KURLA COMPLEX, BANDRA (E), MUMBAI 400 051

Having examined the terms & conditions, drawings, specifications, design relating to the works specified in the memorandum hereinafter set out and having visited and examined the site of the works specified in the said memorandum and having acquired the requisite information relating thereto and affecting the quotation, I/We hereby offer to execute the works specified in the said memorandum within the time specified in the said memorandum on the item rate basis mentioned in the attached schedule and in accordance in all respect with the specifications, design, drawings and instructions in writing referred to in conditions of Tender, the articles of agreement, conditions of contract and with such conditions so far as they may be applicable.

MEMORANDUM

(a)	Description of work	Replacement and relocating of existing old cooling towers of centralized A.C. plant, relocating existing cooling towers of D.G. Set from terrace to ground floor at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051
-----	---------------------	--

Signature of Contractor with Seal

(b)	Earnest Money	Rs. Rs.1,21,000/- (One Lac Twenty-One Thousand Only) by means of Demand Draft / Pay Order from any scheduled Nationalized Bank drawn in favour of SBI Infra Management Solutions Pvt. Ltd. and payable in Mumbai.
(c)	Time allowed for completion of work from the date of issue of work order.	3(Three) months from the date of commencement as per tender.

Should this tender be accepted, I/we hereby agree to abide by and fulfill the terms and provisions of the said conditions of Contract annexed hereto so far as they may be applicable or in default thereof to forfeit and pay to SBIIMS PVT.LTD., the amount mentioned in the said conditions.

I/we have deposited Demand Draft / Banker's Cheque / FDR for a sum of **Rs. Rs.1,21,000/- (One Lac Twenty-One Thousand Only)** as Earnest money deposit with the SBI Infra Management Solutions Pvt. Ltd. Should I/we do fail to execute the contract when called upon to do so, I/we hereby agree that this sum shall be forfeited by me/us to SBI Infra Management Solutions Pvt. Ltd.

We understand that as per terms of this tender, the SBIIMS Pvt. Ltd. may consider accepting our tender in part or whole or in phases. We, therefore, undertake that we shall not raise any claim / compensation in the eventuality of Bank deciding to drop any of the building / buildings from the scope of work of this tender at any stage during the contract period. Further, we also undertake to execute the work entrusted to us in phases on our approved rates and within the stipulated time limit without any extra claim for price escalation as provided for in Clause 11.1.7 and 11.1.8 "Instructions to Tenderers" of this tender.

We, hereby, also undertake that, we will not raise any claim for any escalation in the prices of any of the material during the currency of contract/execution/completion period.

Yours faithfully,

Signature of contractor
With Seal

Signature of Contractor with Seal

INDEX**PROFORMAS OF VARIOUS TESTS**

TABLE NO.	DESCRIPTION	PAGE NO.
1.	Record of Cement/Received/Used/Balance.	
2.	Proforma of Paint/Lead/CICO Register.	
3.	Bank for Reinforcement Bars Received.	
4.	Proforma for Register of Material of Site Account.	
5.	Proforma for Account of Secured Advance Register.	
6.	Proforma for Bulkage Test of Sand Register.	
7.	Proforma for Silt Test Register.	
8.	Proforma for Sieve Analysis of Fine Aggregate Register.	
9.	Proforma for Sieve Analysis of Coarse Aggregate Register.	
10.	Proforma for Slump Test Register.	
11.	Proforma of Cube Test Register.	
12.	Proforma for Hindrance to Work.	
13.	Proforma for Running A/c. Bill.	

Signature of Contractor with Seal

14. Account of Secured Advance if Admissible on Materials Held at Site by the Contractors

15. Memorandum for Payment.

TABLE-I

RECORD OF CEMENT RECEIVED / USED / BALANCE

S. No.	Cement in stock Bags	Cement received (Bags)	Total Cement received (Bags)	Source from which received	Description of work where cement is used	Number of cement bags consumed	Balance in stock	Signature of Contractor's Bank / Engineer
1	2	3	4	5	6	7	8	9

Signature of Contractor with Seal

--	--	--	--	--	--	--	--	--

Signature of Contractor with Seal

TABLE-II

RECORD OF PAINT / LEAD / CICO REGISTER

Name of work :

Name of the Contractor :

Agreement No. :

Date of Receipt	Source Receipt with Ref. To S.O./Ident	Qty. Received	Progressive Total	Item of work for which issued with approx qty. work done in case of paint only	Date of issued	Quantity issued	Qty. returned at the end of the day	Total issued	Delay Balance at hand	Contractors initials	Site Engineer's initials	Signature of Banks/Architect
1	2	3	4	5	6	7	8	9	10	11	12	13

Register for bitumen should be maintained. The format will be similar to that for cement.

Signature of Contractor with Seal

TABLE-IV

PROFORMA FOR REGISTER OF MATERIAL AT SITE ACCOUNT

Name of Work : Name of Article :
 Name of Contractor : Estimated Requirement :
 Agreement No. : Issue Rate :

Date of Recei pt	Received from/Issued to (with Ret. to So/Indent)	Recei pt	Issue	Balanc e	Initials of Contract or	Initial of Bank's/Architect 's representative	Remar k
1	2	3	4	5	6	7	8

Signature of Contractor with Seal

TABLE-V

PROFORMA FOR REGISTER OF MATERIAL AT SITE ACCOUNT

Name of Work :

Name of Contractor :

Agreement No. :

Description of Material	Qty.outstanding from previous Bill	Deduct Qty.utilised in works measured since previous bill	Qty.outstanding & Qty.brought to site since previous bill	Signature of Site Engineer	Signature of Contractor	Initial of Bank's/ Architect's representative	Remark
1	2	3	4	5	6	7	8

Signature of Contractor with Seal

TABLE-VI

PROFORMA FOR BULKAGE TEST OF SAND REGISTER

S.No.	Date of Test	Volume of dust sand in Cylinder inundated & stirred	Volume inundated Sand in Cylinder	Percentage of Bulkage	Signature of Site Engineer	Signature of Contractor	Initial of Bank's Architect's representative (Periodical)
1	2	3	4	5	6	7	8

Signature of Contractor with Seal

TABLE-VII

PROFORMA OF SILT TEST REGISTER

S. N o.	Date of Test	Height of Sand in Cylinder innundated & stirred	Height of Silt	Max percenta ge of silt as specified	Percentag e of silt obtained	Signat ure of Site Engin eer	Signatur e of Contract or	Initial of Bank's / Representa tive (Periodical)
1	2	3	4	5	6	7	8	9

Signature of Contractor with Seal

TABLE-VIII

PROFORMA SIEVE ANALYSIS OF FINE AGGREGATE REGISTER

S. No.	Date of Test	Wt. of Material to be tested	Sieve as per I.S. designation	Wt. of Sand retained in sieve	% retained in each sieve successively	Cumulative % retained in each sieve	F. M.	Signature of Site Engineer	Signature of Contractor	Signature of Banks/Architect's representative & Remarks (Periodical)
1	2	3	4	5				7	8	9

Signature of Contractor with Seal

TABLE-IX

PROFORMA OF SIEVE ANALYSIS OF COARSE AGGREGATE REGISTER

S. No.	Date of Testing	Wt. of Material to be tested	Nominal size of Aggregate	I.S. Sieve designation	Standard passing for graded aggregate of nominal size	Test Result	Obtained passing	Signature of Site Engineer	Signature of Contractor	Signature of Banks/Architect's representative & Remarks (Periodical)
1	2	3	4	5	6	7	8	9	10	11

Signature of Contractor with Seal

TABLE-X

PROFORMA FOR SLUMP TEST REGISTER

S. No.	Date of Testing	Type of work for which slump taken	Specified slump		Slump Obtained		Signature of Site Engineer	Signature of Contractor	Signature of Banks/ Architect's representative & Remarks (Periodical)
			When Vibrators are used	When Vibrators are not used	When Vibrators are used	When Vibrators are not used			
1	2	3	4	5	6	7	8	9	10

Signature of Contractor with Seal

TABLE-XI

PROFORMA OF CUBE TEST REGISTER

Date of taking Cube + Lime	Sample No.	No. of Cubes taken	Specific marking of Cubes	Proportion of mixture	Description of work carried out	Signature of Engineer taking sample	Signature of Contractor	7/28 Days Testing				Permissible Compressive strength of Concrete / 28 Days / 7 days		Remarks on Test Report and No.	Remarks of Banks/ Architects representative Periodicals
								Date of Test	Test Result Kg/Sq.cm	Average Strength Kg./Sq.cm.	Standard strength Kg./Sq.cm.	7 Days	28 Days		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	

Signature of Contractor with Seal

PROFORMA FOR HINDRANCE TO WORK

Name of Work : Date of Start of work :
 Name of Contractor : Period of Completion :
 Agreement No. : Dt. of Completion of work :

S.No.	Nature of Hindrance	Date of Occurrence of Hindrance	Date of which Hindrance was removed	Period of which Hindrance existed	Signature of Site Engineer	Signature of Bank / Architects Representative
1	2	3	4	5	6	7

Signature of Contractor with Seal

PROFORMA FOR RUNNING A/C BILL

- i. Name of Contractor / Agency :
- ii. Name of Work :
- iii. Sl.No. of this Bill :
- iv. No. & Date of previous Bill :
- v. Reference to Agreement No. :
- vi. Date of Written order to commence :
- vii. Date of Completion as per Agreement :

S.No.	Item Description	Unit	Rate (Rs.)	As per Tender	
				Quantity	Amount (Rs.)
1	2	3	4	5	

Upto Previous R.A. Bill		Up Date (Gross		Present Bill		Remarks
Quantity	Amount (Rs.)	Quantity	Amount (Rs.)	Quantity	Amount (Rs.)	
6		7		8		9

- Note: 1. If part rate is allowed for any items, it should be indicated with reasons for allowing such a rate.
2. If ad-hoc payment is made, it should be mentioned specifically.

 Net Value since previous bill

Signature of Contractor with Seal

CERTIFICATE

The measurements on the basis of which the above entries for the Running Bill No. ----
----- were made have been taken jointly on ----- and are recorded
at pages ----- to ----- of measurement book No. -----
-----.

Signature and
date of Contractor

Signature and
date of Architects
Representative (Seal)

Signature and
date of Site Engineer

The work recorded in the above mentioned measurements has been done at the site
satisfactorily as per tender drawings, conditions and specifications.

Architect

Signature and
date of Site Engineer

Signature of Contractor with Seal

TABLE - XIV

**ACCOUNT OF SECURED ADVANCE, IF ADMISSIBLE ON
MATERIALS HELD AT SITE BY THE CONTRACTOR**

S.No.	Item	Quantity	Unit	Amount	Remarks
1	2	3	4	5	6

Total value of materials at Site.

Secured Advance @ ----- of above value -

B

CERTIFIED:

- (i) That the materials mentioned above have actually been brought by the Contractor to the site of the work and on advance on any quantity of any of this item is outstanding on their security.
- (ii) That the materials (are of imperishable nature) and are all required by the Contractor for use in the work in connection with the items for which rates of finished work have been agreed upon.

Dated Signature of
Site Engineer
Preparing the bill
Rank -----

Date signature of
Banks Architects-----
(Name of the Architects)

Dated Signature of
the Contractor

Signature of Contractor with Seal

MEMORANDUM FOR PAYMENT

R/A BILL NO.

- | | | |
|----|---|-----------|
| 1. | Total value of work done since previous bill (A) | Rs. ----- |
| 2. | Total amount of secured advance due since Previous Bill (B) | Rs. ----- |
| 3. | Total amount due since Previous Bill (C) (A+B) | Rs. ----- |
| 4. | PVA on account of declaration in price of Steel, Cement and other materials and labour as detailed in separate statements enclosed. | Rs. ----- |
| 5. | Total amount due to the Contractor | Rs. ----- |

OBJECTIONS:

- | | | |
|------|---|-----------|
| i) | Secured Advance paid in the previous R/A | Rs. ----- |
| ii) | Retention money on value of works as per accepted tenders upto date amount Rs. | Rs. ----- |
| | Less already recovered | Rs. ----- |
| | Balance to be recovered | Rs. ----- |
| iii) | Mobilization Advance, if any | |
| (a) | Outstanding amount (principal + interest) as on date | Rs. ----- |
| (b) | To be recovered in this bill | Rs. ----- |
| iii. | Any other Departmental materials cost to be recovered as per contract, if any | Rs. ----- |
| iv. | Any other Departmental service charges to be recovered if any, as per contract (water, power etc.) enclose statement. | Rs. ----- |

Signature of Contractor with Seal

Total Deduction as per contract (F) Rs. -----

Adjustments, if any ----- Rs. -----
Amount less received by Contractor in
----- R/A Bill (as per statement of
Contractor)

P.V.A. Rs. -----

Total amount payable as per contract Rs. -----
(E+F+G)

(Rupees ----- in
words)

The bill amount to Rs. ----- (both figures and words) has been scrutinized by us after due checking of the measurements of work as required and is recommended for payment.

Date: -----

Signature of Architect
with Seal

The bill amount to Rs. ----- certified by Consultants has been scrutinized by me after due test checking of measurements of works as required and is recommended for payment for an amount of Rs.

Date : -----

Signature of Owners
Engineer

STATUTORY DEDUCTION:

i)	Total Amount due (E)	Rs. -----
ii)	Less I.T. Payable	Rs. -----
iii)	Less S.T. Payable	Rs. -----
	Net Payable	Rs. -----

This figures given in the Memorandum for payable has been verified and bill passed for payment ----- (in words and figures)

Date: -----

Signature of the M.D. & C.E.O.

Signature of Contractor with Seal

LIST OF APPROVED MATERIAL AND MAKES OF ITEMS

(THE MAKE LISTED BELOW SHOULD BE FIRST APPROVED BY THE BANK BEFORE USE IN CONSTRUCTION)

- | | | | |
|-----|--|---|--|
| 1. | CEMENT (53 Grade) | : | ULTRATECH, LAFARGE, JAYPEE,
DIAMOND, ACC, MODI OR
EQUIVALENT |
| | WHITE CEMENT | : | BIRLA WHITE, JK WHITE |
| 2. | STEEL FOR REINFORCEMENT | : | TESTED STEEL OF RATHI, TATA
OR MAGNUM (TMT STEEL) |
| 3. | BRICKS | : | GHOLE BRICKS OF METRIC
SYSTEM |
| 4. | WOOD | : | FIRST CLASS C.P. TEAK
UNLESS OTHER WISE SPECIFIED. |
| | SOFT WOOD | : | KAIL WOOD, HOLLOCK |
| 5. | BITUMIN | : | STP OR ANY OTHER I.S.I. MARKED
BRAND |
| 6. | ALUMINUM SECTION | : | HINDALCO, INDAL OR JINDAL |
| 7. | EXTERNAL PUTTY | : | BIRLA WALL CARE |
| 8. | EXTERNAL PAINTS | : | ASIAN, BERGER, NEROLAC,
SHALIMARICI OR EQUIVALENT |
| 9. | STEEL PRIMER | : | ASIAN, BERGER, SHALIMAR, ICI |
| 10. | SYNTHETIC ENAMEL PAINT | : | APCOLITE, NAROLAC, DULUX,
ICI |
| 11. | CEMENT PAINTS FOR EXTERIOR :
FINISH | : | SNOWCEM PLUS, SUPER
INDOCHEM, ICI, CEMENT PLUS |
| 12. | WATER PROOFING COMPOUND | : | BASF, CICO, CHOK SEY'S,
PIDILITE, ROFF, SUNANDA,
CHEMISTIK |
| 13. | GALVANISED STEEL SHEETS | : | TATA, JINDAL, HINDALCO OR
EQUIVALENT |
| 14. | GALVALUMN SHEETS | : | TRAC, KIRBY, CRIL |
| 15. | C.I. PIPES AND FITTINGS | : | B.I.C., HEPCO, NECO OR
EQUIVALENT. |
| 16. | G.I. PIPES | : | G.S.I. AMBICA, ZENITH, TATA OR
EQUIVALENT |
| 17. | BRASS C.P. FITTINGS | : | PLUMBER, L&K, K.B., TECHNO OR |

Signature of Contractor with Seal

			EQUIVALENT
21.	GUN METAL VALVES	:	LEADER, SANT OR EQUIVALENT
27.	PIGMENTS	:	TATA, SHALIMAR
28.	PVC PIPES	:	ASTRAL, SUPREME, PREMIER
29.	CPVC PIPES	:	ASTRAL, SUPREME, PREMIER
30.	FIRE FITTING SLUICE & NRV	:	KIRLOSKAR / KALPANA
36.	MILD STEEL FOR FABRICATION	:	TATA, SAIL OR EQUIVALENT

- NB. 1) The contractor should obtain prior approval from Employer / Consultants before placing order for any specific materials. Employer may / delete any of the makes or brands out of the above list.
- 2). All materials should conform to relevant standards and codes of BIS.
- 3) Materials with I.S.I. mark shall be used duly approved by the SBIIMS Engineer / Architect.

Note: - If any material is found to be not up to the mark, the contractor will have to produce original bills/certificate from the manufacturer or his authorised Distributor for authenticity and genuineness of the material for consideration and as per make approved by the SBIIMS. The same will not be considered for payment.

Signature of Contractor with Seal

MODE OF MEASUREMENT

1. Unless otherwise stated, all pipes shall be measured net, length as laid and measured overall fittings, such as bends, junctions, etc., and given in running meters. The length shall be taken along the center line of the pipes and fittings.
2. Length of fittings viz, taps, valves, traps etc., which are paid under appropriate items shall not be re-measured under linear measurements as enumerated above.

SECTION – A: MATERIALS

- 1) Material shall be of best approved quality obtaining and they shall comply with the respective Indian Standard Specification.
- 2) Samples of all materials shall be got approved before placing order and the approved sample shall be deposited with the Architect.
- 3) In case of non-availability of materials in metric sizes the nearest size in FPS units shall be provided with prior approval of the Architects for which neither extra will be paid nor shall any rebates be recovered.
- 4) If directed, materials shall be tested in any approved Testing Laboratory and the test certificates in original shall be testing including charges for repeated tests, if ordered, shall be borne by the Contractor.
- 5) It shall be obligatory for the Contractor to furnish certificate, if deemed by the Architects, from manufacturer or the material supplier that the work has been carried out by using their material and as per their recommendations.
- 6) All materials supplied by the Employer / any other Specialist Firms shall be properly stored and the Contractor shall be responsible for its safe custody until they are required on the works and till the completion of the work.
- 7) Unless otherwise shown on the Drawings or mentioned in the “Schedule of Quantities” or special specification, the quality of materials, workmanship, dimensions, etc., shall be as specified as hereunder.
- 8) All equipment and facilities for carrying out field tests on materials shall be provided by the Contractor without any extra cost.

a) **Cement** :

Cement shall comply in every respect with the requirements of the latest publications of IS: 269 and unless otherwise specified ordinary Portland Cement shall be used.

The weight of ordinary Portland Cement shall be taken as 1440 kg. per cu.m. (90 lbs. per C.Ft.). Cement shall be measured by weight and in whole bags, and each undisturbed and sealed 50 kg. bag being considered equivalent to 35 liters (1.2 c.ft.) in volume care should be taken to see that each bag contains full quantity of cement. When part bag is required cement shall be taken by weight or measured in measuring boxes.

No other make of cement but that approved by the Architects will be allowed on works and the source of supply will not be changed without approval of Architect in writing. Test certificates to show that cement is fully complying the specifications shall be submitted to the Architects and

notwithstanding this, the Architect may at his discretion, order that the cement brought on site and which he may consider damaged or of doubtful quality for any reason whatsoever, shall be re-tested in an approved testing laboratory and fresh certificates of its soundness shall be produced.

Signature of Contractor with Seal

Cement ordered for re-testing shall not be used for any work pending results of re-test.

Cement shall be stored in weather-proof shed with raised wooden plank flooring to prevent deterioration by dampness or intrusion of foreign matter. It shall be stored in such a way as to allow the removal and use of cement in chronological order of receipt i.e., first received being used first used. Cement deteriorated and or clotted shall not be used on the work but shall be removed at once from the site. However, allowing use of warehouse set cement shall be determined by the Architects.

b) **River Sand :**

River sand shall confirm to IS: 383 and relevant portion of IS: 515. It shall pass through pass through a I.S. sieve 4.75 mm. (3/16 B.S.) test sieve, leaving a residue not more than 5%. It shall be from natural source i.e. only river or crushed stone screenings, if allowed, chemically inert clean, sharp, hard durable, well graded and free from dust, pebbles, clay, shale, salt, organic matter, loam , mica or other deleterious matter. The sum percentages of all deleterious substances to acceptable limits. River sand shall not contain any trace of salt and it shall be tested and river sand containing any trace of salt shall be rejected.

The fine aggregate i.e. river sand for concrete shall be graded within limits as specified in IS: 383 and the fineness Modules may range between 2.60 to 3.20.

The fine aggregate shall be stacked carefully on a clean hard dry surface so that it will not get mixed up with deleterious foreign materials. If such a surface is not available a platform of planks or corrugated iron sheets or brick floor or a thin layer of lean concrete shall be prepared.

c) **Fine & Coarse Aggregate :**

Shall consist of crushed or broken stone 95% of which shall be retained on 4.75 mm. IS tests sieve. It shall be obtained on crushing Granite, Quartzite, Trap, Basalt, or similar approved stones from approved quarry and shall confirm to IS:383 and IS 515. Fine & Coarse aggregate shall be chemically inert when mixed with cement and shall be cubical in shape and be free soft, friable, thin, porous, laminated or flaky pieces. It shall be free from dust and any other foreign matter.

Gravel / Shingle of desired grading may be permitted as a substitute in part or full in plain cement concrete if the Architect is otherwise satisfied about the quality of aggregate. For all the R.C.C. works the size of coarse aggregate shall be 20 to 25 mm. and fine aggregate shall be 10 to 15 mm.

d) **Reinforcement :**

Reinforcement shall be of mild steel tested quality confirming to I.S. : 432-1966 and any other I.S. applicable or deformed bar confirming to IS:1786 and Is:1139 or hard drawn Fe 415 (Tor Steel) steel wire fabric confirming to IS:1566;1967.

All finished bars shall be free from cracks, surface flaws, laminations, jagged and imperfect edges.

Signature of Contractor with Seal

e) **Bricks** :

Bricks shall generally comply with IS:1077 except in size which shall be classified as 1st and 2nd class. 1st class bricks shall be the best quality locally available table moduled, well burnt but not over burnt, have plain rectangular faces with parallel sides and sharp right angled edges, have a fine compact and uniform texture. The bricks shall be free from cracks, chips, flaws, stones or subsequent to soaking in water. It shall emit a clear ringing sound on being struck and shall not absorb water more than 20% by weight. Common building bricks shall have a compressive strength of 35 kg. / sqm unless otherwise specified for first class bricks.

f) **Neeru** :

Shall be made of Class "C" Lime (i.e. pre fat lime) as mentioned in IS: 712. It shall be slaked with fresh water then sifted and reduced to a thick paste by grinding in a mill. Neeru thus prepared shall be kept moist until used and no more than that can be consumed in 15 days shall be prepared at time.

g) **Surkhi** :

Shall be made by grinding well burnt bricks, brick bats, burnt clay balls, etc., the brick etc., to be used shall be prepared from selected clay. The quality shall conform to IS:1344.

Bricks bats, etc., shall be ground in mechanical disintegrator to a fine powder passing through IS Sieve No. 9 (2.36 mm.) with a residue not exceeding 10% by weight.

Surkhi for lime surkhi plaster shall be ground to fine powder in a mortar mill to pass through IS Sieve 150 micron (No. 100)

Surkhi shall be stored in a weather-proof shed on a brick paved platform.

h) **Water** :

Water for mixing cement / lime / surkhi mortar or concrete shall not be salty or brackish and shall be clean, reasonably clear and free from objectionable quantities of silt and traces of oil, acid and injurious alkali, salts, organic matter and other deleterious materials which will either weaken the mortar or concrete or cause efflorescence or attack the steel in reinforced cement concrete. Water shall be obtained from sources approved by the Architect. Potable water is generally considered satisfactory for mixing and curing concrete, mortar masonry, etc., where water other than main source is used this shall be tested in an approved testing laboratory to establish its suitability. All charges connected therewith shall be borne by the Contractor.

i) **Paints** :

Lime for lime wash, dry distemper, oil bound distemper cement primer, oil paint, enamel paint, flat oil paint, plastic emulsion paint, anti-corrosive primer, red lead, water-proof cement paint and exterior grade Acrylic Emulsion paint, cement paint, sand-text matt shall be from an approved manufacturer and shall conform to the latest Indian Standard for various paints. Ready mixed paints as received from the manufacturer without any admixture shall be used, except for addition of thinner, if recommended by the manufacturer.

Signature of Contractor with Seal

j) **Mortar :**

Lime Surkhi Mortar :

Lime and surkhi shall conform to the specifications. It shall be composed of approved lime and surkhi in proportion of 1 lime to 2 surkhi mixed thoroughly. The ingredients shall be accurately gauged by measure and shall be well and evenly mixed together on a platform and water added to make it homogenous. When large quantities are required the mortar shall be mixed in a mechanical grinder.

Cement Mortar :

Cement mortar shall be of proportions specified for each type of work in the schedule. It shall be composed of Portland Cement and sand. The ingredients shall be accurately gauged by measure and shall well and evenly mixed together in a mechanical pan mixer, care being taken not to add more water than is required. No mortar that has begun to set shall be used. River sand shall be used unless otherwise specified.

If hand mixing is allowed, then it shall be done on pucca water-proof platform. The gauged materials shall be put on the platform and mixed dry. Water will then be added and the whole mixed again until it is homogenous and of uniform colour. Not more than one bag of cement shall be mixed at one time and which can be consumed within half an hour of its mixing.

Composite lime, cement, sand mortar :

The mortar shall be of proportions specified for each type of work in the schedule of quantities. It shall comprise of Portland cement, lime and sand. Lime shall be measured in gauge boxes similar to one used for measuring cement and sand to the proportion specified and sufficient water then added to it to form a thick slurry thus obtained shall then be added to dry cement and sand mixture and thoroughly mixed to make a workable homogenous mortar of uniform colour by adding more water if necessary. Mechanical mixers shall generally be used for mixing such mortars. If hand mixing is allowed it shall be done on pucca platform.

Note :

In connections with the I.S. Code numbers indicated under Section, Specification, Section A – General

Refer to the following I.S. Code numbers and the year and or otherwise latest modified I.S.Code Number.

1) Cement	:	I.S. 269 – 1976
2) Lime	:	I.S. 712 – 1964
		I.S. 1624 – 1960
3) Fine – Aggregate	:	I.S. 383 – 1970
4) Coarse – Aggregate	:	I.S. 515 – 1970
5) Reinforcement	:	I.S. 432 – 1966 Fe 415
		I.S. 1786 – 1966 (Tor Steel)
		I.S. 1139 – 1966
6) Bricks	:	I.S. 1077 – 1970
7) Neeru	:	I.S. 712 – 1964
8) Surkhi	:	I.S. 1344 – 1968

Signature of Contractor with Seal

9) Timber	:	I.S. 287 – 1960
10) Flush Doors	:	I.S. 2202 – 1966
11) Floor Tiles	:	I.S. 1237 – 1980
12) Ceramic / Vitrified Tiles	:	I.S. 777 – 1970
13) Asbestos Roofing and Rainwater pipes	:	I.S. 459 – 1962
14) R.C.C. design mix M-25	:	I.S. 456 – 2000

SECTION – B: MODE OF MEASUREMENTS

The method of measurement for various items in the tender shall be generally in accordance with the IS: 1200 subject to the items for which the mode of measurements are not given under or elsewhere in the tender.

1) Cement Concrete (Plain & Reinforcement):

Cement concrete in R.C.C. and P.C.C. items shall be measured exclusive of reinforcement and plaster thickness but shall include necessary costs of shuttering, centering, hire charges of all equipment, curing, hacking and fair finish. Reinforcement and plaster shall be measured and paid separately.

Items like R.C.C. precast jalli, R.C.C. pipes and other such items which are normally manufactured in factories as well as those items which have been specifically mentioned in the Schedule of Quantities shall be measured inclusive of reinforcement.

No deductions will be made for openings upto 0.1 sq.m. and no extra labour for forming such openings or voids shall be paid.

Columns shall be measured from face to face of columns / beams and shall include haunches, if any. The depth of the beams (other than raft foundations beam) shall be measured from the top of the slab to the bottom of the beam.

In case of combined footings and raft foundations, the exposed, portion of the beam rib shall be measured as beam and remaining portion measured in footing / raft slab.

Slabs (other than in raft foundations) shall be measured in bays (clear of beams) with deductions for columns portions.

2) Reinforcement:

Shall be measured in lengths of bars as actually placed in position on standard weight basis; no allowance being made in the weight for rolling margin, Wastage and binding wire shall not be measured, authorised overlaps and spacers shall only be measured.

Signature of Contractor with Seal

Standard weight for steel reinforcement bars

Diameter of the steel bars in mm.	6	8	10	12	16	20	25	32
Weight of steel bars in kg per Rmt.	0.22	0.39	0.62	0.89	1.58	2.47	3.85	6.31

3) Plastering and Pointing:

All plastering and pointing shall be measured in square meters unless otherwise described.

Net are of surface plastered shall be measured. No deductions will be made for ends of joints, beams, posts, etc., and opening not exceeding 0.5 sq.m. each and no additions shall be made neither for reveals, jambs, soffits, sills, etc. of these openings nor for finishing the plaster around openings, ends, of joists, beam and posts, etc.

Full deductions will be made for door, window and ventilator from each side with adding jambs for door, window and ventilator.

4) Painting, White washing, colour washing and distempering:

All painting work shall be measured in square meters.

Net are of surface painted shall be measured. No deductions will be made for unpainted surfaces of ends of joists, beams, posts etc., and opening not exceeding 0.5 sq.m. each and no additions shall be made for reveals, jambs, soffits, sills, etc., of these openings.

Full deductions will be made for door, window and ventilator from each side with adding jambs for door, window and ventilator.

No coefficient will be considered for painting over sponge finished or sandfaced plaster.

The following multiplying factors for obtaining equivalent areas shall be adopted.

No.	Description of works	How measured	Multiplying Factor
a)	Wood paneled framed ledged, braces and battened.	Measured flat (not girthed) including frame, edges, chawkats, cleats, etc., shall be deemed to be included in the item.	1 1/8 (for each side).
b)	Wood flush part paneled and part.	-- do -- glazed or gauzed.	1 (for each side).
c)	Fully glazed or gauzed or glazed louvered ventilators / window / door.	-- do --	¼ (for each side).
d)	Fully venetioned of louvered (not with glazing).	-- do --	1 ½ (for each side).
e)	Weather boarding.	Measured flat (not grithed supporting frame work shall not be measured separately).	1 1/8 (for each side).

Signature of Contractor with Seal

f)	Trellis (or Jaffri) work one way or two way.	Measured flat overall, no deduction shall be made for opening (supporting members shall not be measured separately)	1 (for each side).
g)	Guard bars, balustrades, gratings, grille railings, grille partitions, etc.	--- do ---	1 (for painting all over).
h)	M.S. gates & open palisades fencing, door including standards, braces, rails, stays, etc.	See not below	1 (for painting over all).
i)	Steel rolling / alligator type shutters.	Measured flat over jambs, guides, bottoms, rails and locking arrangement etc. shall be deemed to be included in the item.	1 ¼ (for each side).
j)	Carved or enriched work.	Measured flat.	2 (for each side).
k)	Fully glazed or gauzed steel windows or partitions.	Measured flat.	1 ¼ (for all over).

Note :

The height shall be taken from the bottom of the lowest rail, if the palisades do not go below it (or from the lower end of the palisades, if they project below the lowest rail) upto the top of the palisades, but not upto the top of the standards, if they are higher than the palisades. Similarly for the gates, depth of roller shall not be considered while measuring the height.

Area painted over sand cement plaster, sponge finished / sand faced plaster / rough cast plaster area painted without considering any coefficient for painting over sand faced plaster

Signature of Contractor with Seal

SECTION – C : WORKMANSHIP

CLEARING OF SITE, EXCAVATION AND EARTH FILLING

Note: Workmanship for all items related to the construction work should be as per relevant I.S. Code.

General:

Trenches for wall foundations, column footings, raft foundations, pile caps, plinth beams, water tanks, cess pits, etc., shall be excavated to the exact length, width and depth shown in the figure on the drawing or as may be directed by the Architect. If taken out to greater length, width or depth than shown or required, the extra work occasioned thereby shall be done at the Contractors own expenses. Extra depth shall be brought up by plain cement concrete filling 1:4:8 proportion and extra length and width filled in by rammed earth or murum or if the Architect thinks it necessary for the stability of the work by 1:4:8 concrete, as may be directed by the Contractors costs.

Excavated material shall be used for filling in plinth, or each side of the foundation blocks or trenches or it shall be spread elsewhere on or near the site of work including watering, ramming and consolidating or carted away from site free of charge, as may be ordered.

The Contractor shall at his own expenses and without any extra charge, make provision for supporting all utility services, lighting the trenches, separating and stacking, serviceable materials neatly, shoring, timbering, stuttering, bailing out of water either sub-soil or rain water including pumping at any stage of the work. Trenches shall be kept free of water while masonry or any concrete works are in progress and until the Architects consider that concrete is sufficiently set.

PLAIN & REINFORCED CEMENT CONCRETE

A) VOLUMETRIC BASIS:-

General : Except where they are varied by the requirements of this specification due provision of Indian Standard Specification IS-456-1964 for plain and reinforced concrete and IS-432 part I and II for Mild and Medium Tensile steel Bars and hard drawn steel wire for concrete reinforcement and any other relevant ISS applicable together with the latest amendments shall be held to be incorporated this specifications. It shall be intent of these specifications to ensure that all concrete placed at various location of the job should be durable, strong enough to carry design, loads, it should wear well and practically be impervious to water. It should be free from such defects as shrinkage, cracking and honey-combing.

Proportioning the Mix :

In ordinary concrete, excluding controlled concrete, proportions of cement to fine and coarse aggregate shall be as specified in the respective items and shall be accurately measured as in table "A" below. These proportions are based on assumption that the aggregates are dry. If aggregates are moist allowance shall be made for bulking in accordance with IS:2386/-. Allowance shall also be made for surface water present in aggregate when computing water contents. Surface water present shall be determined by one of the field methods described in IS:2386/- (Part III). In the absence of exact data, the amount of surface water may estimated by the value given in table "B" below (Table "A" and "B" please see on page nos.124 & 125).

Signature of Contractor with Seal

Mixing :

Concrete of 1:2:4 or richer mix shall be mixed in an approved mechanical mixer. The mixer and mixing platform shall be suitably protected from wind and rain. Aggregates shall be accurately measured out in boxes and mixed dry along with cement, water shall be then added in measured quantity and mixing shall be continued until there is a uniform distribution of the materials and the mass is uniform in colour and in consistency but in no case shall the mixing be done for less than 2 minutes.

When hand mixing is permitted with the approval of the Architect it shall be carried out on water-tight mixing platform and care shall be taken to ensure that mixing is continued until mass is uniform in colour and consistency.

Consistency :

Quantity of water for making reinforced concrete shall be sufficient so as to ensure that concrete shall surround and properly grip all the reinforcement. The best consistency shall be that, which will flow sluggishly without flattening out and without separation of coarse aggregates from the mortar. The degree of plasticity shall depend on the nature of work and atmospheric temperature and whether the concrete is vibrated or hand compacted. The slumps shown in table "C" obtained by standard slump test carried out in accordance with the procedure laid down in IS:119-1959 shall be adopted for different types of work.

Admixtures :

The usages of admixtures are allowed only if approved by the structural consultant and his decision in this regard shall be final.

Transportation:

Concrete shall be conveyed from the place of mixing to the place of final deposit as rapidly as practicable by methods which will prevent segregation or loss of any of the ingredients. If segregation does occur during transport, the concrete shall remix before being placed. In no case, more than 30 minutes shall elapse between mixing the consolidation in its position.

Placing and Compacting :

Concrete shall be placed in layers of suitable thickness or in strips and compacted before initial setting commences and should not be subsequently disturbed. Method of placing shall be such as to preclude segregation and as far as practicable the placing shall be continuous. Special care shall be taken in accordance with IS:456 while laying concrete under extreme weather.

Concrete shall be thoroughly compacted during the operation of placing and thoroughly working around the reinforcement, embedded fixtures and spaded against corners of the form work and by punning, rodding, mechanically vibrating or by any other approved means. In addition form work shall be tapped lightly by using wooden mallet at the pouring head. The number and type of vibrator to be used shall be subject to the approval of the Architects and in general immersion type vibrators shall be used. External vibrators shall also be used whenever directed.

The intensity and duration (of vibration shall be sufficient to cause complete settlement and compaction without any stratification of successive layers or separation of ingredients or formation of laitance. Vibrator shall be inserted vertically in the concrete at points not more than 45 cm. apart and withdrawn very slowly when air bubbles no longer come on the surface.

Signature of Contractor with Seal

Over vibration or vibration of very wet mixes is harmful and should be avoided. Care shall be taken to utilize the vibrator only to compact the concrete and not to spread it, sufficient number of reserve vibrator in good working condition shall be kept on hand at all times, so as to ensure that there is no slackening or interruption in compacting.

Construction Joints :

Concreting shall be carried out end to end continuously as far as possible and when construction joints are totally unavoidable; it shall be located in a predetermined position approved by the Architect. The joints shall be kept at places where the shear force is the minimum and these shall be straight and at right angles to the direction of main reinforcement. When the work has to be resumed, on a surface which has hardened, such surface shall be roughened. It shall be swept clean, thoroughly wetted and covered with a 13 mm. layer of mortar composed of cement and sand in the same ratio as the cement concrete mix. This 13 mm. layer of mortar shall be freshly mixed and placed immediately before the placing of the concrete.

Where the concrete has not fully hardened, all laitance shall be removed by scrubbing the wet surface with wire or bristle brushes, care being taken to avoid dislodgment of particles of aggregate. The surface shall then be coated with neat cement grout. In horizontal joints the first layer of concrete to be placed on this surface shall not exceed 15 cm. thickness and shall be well rammed against old work, particular attention being paid to corners.

Expansion Joint:

Expansion joint shall be provided where required as shown on the drawings or as directed by the Architect / Consultant. The joints shall be filled by the approved quality filler.

Curing :

Concrete shall be carefully protected during first stage of hardening from harmful effects of excessive heat, drying winds, rain or running water. It shall be covered with a layer of sacking, sand canvas, hessian, or similar absorbent materials and kept constantly, wet for ten days from the date of placing of concrete. Alternatively, the concrete being thoroughly wetted and covered by layer of approved water-proof material which should be kept in contact with it for seven days.

Form Work :

The form work shall conform to the shape, lines and dimensions as shown on the plans and be so constructed as to remain sufficiently rigid during the placing and compacting of the concrete and shall be sufficiently watertight to prevent loss of cement slurry from the concrete. Form work or centering shall be constructed of steel or timber and adequately designed to support the full weight of wet concrete without deflection and retain its form during laying, ramming and setting of concrete. Timber used shall be properly seasoned so as to prevent deformation when wetted.

All props shall be straight and of full height and no joints shall be allowed. Props shall be braced with thin bamboos or wooden battens and where additional staging is necessary, extra care shall be taken to use bigger diameter props with bracing at 4 or 5 levels. All props shall be supported on sole plates and double wedges. At the time of removing props these wedges shall be gently eased and not knocked out.

All rubbish, chippings, shavings and saw dust shall be removed from the interior of the forms before the concrete is placed and the form work in contact with the concrete shall be cleaned

Signature of Contractor with Seal

and thoroughly wetter or treated with non-staining mineral oil or any other approved materials is kept out of contact with the reinforcement.

All form work shall be removed without shock or vibration and shall be eased off carefully in order to allow the structure to take up its load gradually. Forms shall not be disturbed until concrete has adequately hardened to take up superimposed load coming on it and in no circumstances shall forms be struck until the concrete may be subjected at the time of striking.

In the normal circumstances (generally where temperatures are above 21 degrees centigrade) and where ordinary cement is used, forms may be struck after expiry of following periods :

- | | |
|---|--|
| a) Walls, Columns and Vertical sides of beam} | 48 hours as may be directly by the Architect |
| b) Bottom of slab upto 4.5 m. span. | 7 days. |
| c) Bottom of slab upto 4.5 m. span. bottom of beam and arch rib upto 6 m. span. | 14 days. |
| d) Bottom of beams and arch rib over 6 m. span. | 21 days. |

However, this period may be increased or decreased at the discretion of Architects. Special care shall be taken while striking the centering of cantilevered slab canopies, portal frames, folded plate construction and period of striking centering shall be as determined by the Architect.

If directed, form shall be given an upward camber to ensure that the beams do not have any sag. Surface that becomes exposed on removal of forms shall be carefully examined and any fins, burrs, projections etc., that are detected shall be removed. Any honeycombing of minor nature shall be finished neatly with cement mortar 1:2.

Any work showing signs of damage through premature or careless removal of centering or shuttering, shall be reconstructed by the contractor at his own cost.

Strength :

Concrete mixed in the proportion desired shall have compressive strength after placing, not less than the following :

No	Concrete Mix.	Minimum compressive strength @ 7 days	Minimum compressive strength @ 28 days
1	1:1:2	160 Kg. / Sq.m. (2250 Lbs. / Sq. inch).	250 Kg. / Sq.m. (3500 Lbs. / Sq. inch).
2	1:1 1/2:3	132 Kg. / Sq.m. (1875 Lbs. / Sq. inch).	200 Kg. / Sq.m. (2850 Lbs. / Sq. inch).
3	1:2:4	106 Kg. / Sq.m. (1500 Lbs. / Sq. inch).	150 Kg. / Sq.m. (2250 Lbs. / Sq. inch).

Tests : Tests on concrete shall be carried out in accordance with IS-456/- and any other is applicable. The frequency of work test shall be at such intervals as ordered by the Architect and subject to that every 150 cu.m. of concrete placed or part thereof and for a day's concrete exceeding 30 cu.m. a batch of 6 cubes shall be made for every sample and 3 of them tested after 7 days and the remaining 3 cubes shall be tested after 28 days. The criteria for acceptance

Signature of Contractor with Seal

of a concrete as confirming to a specified proportion / grade of concrete shall be in accordance with IS:456 and the Contractor shall entirely re-do the rejected work at his own cost. Strength of 28 days shall alone be considered for acceptance.

The Contractor shall arrange to carry out the tests in accordance with the relevant Indian Standards Specifications in an approved laboratory and the test reports in original be submitted to Architect. The entire cost of testing shall be borne by the Contractor.

Steel Reinforcement :

Reinforcement shall be accurately fabricated, placed and adequately maintained in position as shown on the drawings or as directed by the Architect. All finished bars shall be free from cracks, surface flaws, laminations, jagged and imperfect edges. Cement mortar blocks shall be used to give requisite cover as shown be firmly tied with binding wire of 16 to 18 gauge. Reinforcement shall be bent in accordance with the procedure stipulated in IS:2502-1963 and will not be straightened in a manner which will injure the material.

All reinforcement shall immediately before placing in concrete be thoroughly cleaned of loose mill scale, loose rust, oil and grease or other deleterious matter that would destroy or reduce bond.

Reinforcement in reinforced concrete members shall not be connected by welding or coupling except in accordance with relevant ISS and with the previous approval of the

Architect. Overlaps and joints shall be staggered and located at points, along the spans where neither shear nor bending moment is maximum.

Cover :

Reinforcement shall have cover as shown on the R.C.C. drawings and where not specified the thickness of cover shall be as follows. Cement mortar blocks in C.M. 1:1 shall be used for making cover blocks.

- a) At each end of reinforcing bar not less than 25 mm. not less than twice the diameter of such rod or bar.
- b) For a longitudinal reinforcing bar in a column not less than the diameter of such rod or bar. In the case of columns of minimum of 20 mm. or under whose reinforcing bars do not exceed 13 mm. the cover of 25 mm. may be used.
- c) For longitudinal reinforcing bar in a column not less than 25 mm. not less than diameter of such rod or bar.
- d) For tensile, compressive, shear or other reinforcement in a slab not less than 13 mm. nor less than diameter of such reinforcement, and
- e) For any other reinforcement not less than 13 mm. not less than the diameter of such reinforcement.

A) WEIGH-BATCHING BASIS i.e. (DESIGN MIX CONCRETE) :

Workmanship of Design Mix Concrete shall be carried out in accordance with I.S. : 456 – 2000 and any other I.S. Code is applicable.

Signature of Contractor with Seal

TABLE – A

No	Nominal Mix.	Quantity of aggregates required per 50 kgs of cement.		Quantity of water required per 50 kgs of cement.	
		Fine Cu.m.	Coarse Cu.m.	Vibrated (For dry aggregate)	Unvibrated
1	1:1:2	0.035 (1.2 C.ft.)	0.070 (2.4 C.ft.)	22 lit. (4.8 Gal.)	27 lit. (6 Gal.)
2	1:1 1/2:3	0.052 (1.8 C.ft.)	0.106 (3.6 C.ft.)	23 lit. (5 Gal.)	30 lit. (6 Gal.)
3	1:2:4	0.070 (2.4 C.ft.)	0.138 (4.8 C.ft.)	27 lit. (6 Gal.)	32 lit. (7 Gal.)
4	1:3:6	0.105 (3.6 C.ft.)	0.210 (7.2 C.ft.)	28 lit. (6.25 Gal.)	34 lit. (7.5 Gal.)
5	1:4:8	0.150 (4.8 C.ft.)	0.280 (9.6 C.ft.)	-- --	45 lit. (10 Gal.)

TABLE – B

No	Aggregate	Approx. quantity of surface water in Lit / Cu.m.
1	Very wet sand.	120
2	Moderately wet sand.	80
3	Moist sand.	40
4	Moist gravel or crushed sock. Coarser the aggregate, lesser the water it will carry.	20 to 40

TABLE – C

No.	Type of Work	<u>SLUMPS</u>	
		When vibrated	When not vibrated
1.	Mass concrete in R.C.C. foundation footings.	2.5 cms. (1")	5 cms. (2")
2.	Beams, slabs, columns with simple reinforcement.	2.5 cms. to 5 cms. (1" to 2")	5 cms. to 10 cms. (2" to 4")
3.	Thin sections with congested reinforcement.	5 cms. to 10 cms. (2" to 4")	10 cms. to 15 cms. (4" to 6")

Note :Should conditions governing slump and workability changed pointing to advisability of an increased slump, this shall only be done by decreasing the amount of aggregate and not by increasing the amount of water.

B) WEIGH-BATCHING BASIS i.e (DESIGN MIX CONCRETE) :-

Workmanship for design mix concrete shall be carried out in accordance with I.S. 456-2000 and any other I.S. code is applicable.

Signature of Contractor with Seal

PLASTERING

Scaffolding :

Scaffolding for carrying out plastering work shall be double steel scaffolding having two sets of vertical supports so that the scaffolding is independent of the walls.

Preparation of surface :

All putlog holes in brick work and junction between concrete and brick work shall be properly filled in advance. Joints in brick work shall be raked about 10 mm. if not raked out while constructing brick masonry work and concrete surface hacked to provide the grip to the plaster, if not hacked earlier projecting burns of mortar formed due to gaps at joints in shuttering shall be removed.

The surface shall be scrubbed clean with wire brush / coir brush to removed dirt, dust etc., and the surface thoroughly washed with clean water to remove efflorescence, grease and oil etc., and shall be kept wet for a minimum of six hours before application of plaster.

NeeruPlaster :

Cement mortar of specified proportion and thickness shall be prepared in small batches and applied to the wall surface / ceiling. The ensure proper thickness, gauged patches shall be made at 1.5 to 2 m. apart and the surface plastered true to line, level and plumb taking special care to finish jambs of windows, doors, wall returns, corners, junctions etc. A thin layer of neeru shall then be applied and rubbed into surface and finished by means of trowel until the surface is even and smooth. The surface shall be kept moist for seven days and then given a coat of white wash.

Sand-faced Plaster :

The surface shall be prepared as above.

The coat of cement mortar in proportion of 1:4 or as specified, shall be applied uniformly all over the surface to a thickness of 12 mm. and finished true to level and line and keys shall formed on the surface. The surface shall be kept moist till the finishing coat is applied.

The finishing coat shall be applied a day or two after. The proportion of mortar for finishing coat shall be one part of cement and three parts of selected, well graded and washed sand, or as specified under item and it shall be applied in a uniform thickness of 6 mm. (1/4").

The surface shall be tapped to uniform grained texture by using sponge pads as directed. Curing shall start after 24 hours and the surface kept wet for seven days.

Rough Cast Plaster:

Except for the finishing coat the surface shall be prepared and base coat of plaster applied as under sand-faced plaster.

Finishing coat mortar shall be in proportion of one part of cement and one part of specially selected and graded sand and one part of gravel of 3 to 6 mm. size. It shall be flung upon the first coat with large trowel to form an even and decorative coat. The work shall generally conform to clause 16.5 of IS:1661-1960. The thickness of the coat shall be about 12 mm. (1/2"). It shall be cured for seven days.

Signature of Contractor with Seal

Rough coat plaster with colourfinish :

This finish shall be similar to Rough cast plaster above except a high grade mineral pigment of approved shade shall be mixed with white cement instead of ordinary grey cement while preparing the mortar.

Water-proofing Treatment :

Unless otherwise specified, the Contractor shall carry out waterproofing treatment of basements, terrace and water retaining structures through reputed firms having specialization in the line and approved by the Architects. The Contractor shall also furnish full details of such treatment to the Architects and provide all information / proof etc., regarding the effectiveness of the treatment when called upon to do so. All such treatment shall have to be guaranteed in the form approved by the Employer for a minimum period of ten years. Any defects / leakages noticed during the guarantee period shall have to be rectified free of cost by the Contractor including reinstating the surface to its original condition and finish.

Water-proofing of sunk portions of floor slabs for baths, W.C. and kitchen mores etc., in residential buildings, unless otherwise specified, shall be done as specified in the schedule and shall generally comprise of :

- a) A coat of hot bitumen, min. 6 mm. thick screeded with stone grit.
- b) Min. 20 mm. thick cement plaster in cement mortar 1:3 with approved water-proofing cement compound as per manufactures specifications. The plaster shall be cured by pounding for seven days.

The rate for the above treatment shall include drying and cleaning surfaces free of dust etc., and wiping with kerosene before application of bitumen. The vertical faces and returns shall also be treated similarly. The actual area treated including vertical faces and returns shall be measured and paid for. The work should be done in such a way that the finished flooring in bath has a minimum slope of 20 to 25 mm.

PAINTING

General:

Wherever scaffolding is necessary, it shall be double scaffolding.

The surface shall be thoroughly brushed free from mortar droppings and foreign matter. All steel work shall be cleaned of loose rust, mill scales etc. so as to expose the original surface. All broken edges, cracks, loose plaster and wavy surface shall be brought up either by patch plaster work or by plaster of paris.

All materials viz., dry distemper, oil bound distemper, oil paint, flat oil paint, synthetic enamel paint, plastic emulsion paint, cement primer, red lead and other primers and metallic paints shall conform to respective I.S. specifications and shall be obtained from approved manufactures. All paints shall be brought on site in sealed thins in ready mixed form and shall be applied direct with the addition of thinner, if recommended by the manufacturers.

Water-proof Cement Paint / Sand-tex matt Paint:

The surface shall be prepared as specified above and thoroughly wetted with clean water before water-proof cement paint is applied.

Signature of Contractor with Seal

The paint shall be prepared strictly as per manufacturers specifications and in such quantities as can be used up in an hour of its mixing, as otherwise the mixture will set and thicken, affecting flow and finish.

The paint thus prepared shall be applied on clean and wetted surface with brush or spraying machine. The solution shall be kept stirred during the period of application. It shall be applied on the surface which is on the shady side of the building so that the direct heat of the sun on the surface is avoided. The completed surface shall be watered after the days work. Number of coats shall be as specified in the item.

Painting – Oil / Enamel / Plastic Emulsion etc. :

Ready mixed oil paint, flat oil paint, plastic emulsion paint, ready mixed synthetic enamel paint, etc., shall be brought in original containers and in sealed tins. If for any reason thinner is necessary, the brand and quantity of thinner recommended by the manufacturer or as instructed by the Architect shall be used. The surface shall be prepared as specified above and a coat of approved primer shall be applied. After 24 hours drying approved or specified quality paint shall be applied evenly and smoothly. A filler putty coating may be given to give a smooth finish. Each coat shall be allowed to dry out thoroughly and then lightly rubbed down with sand paper and cleaned of dust before the next coat is applied. Number of coats shall be as specified in the item and if the finish of the surface is not uniform, additional coats as required shall be applied to get good and uniform finish at no extra cost. After completion no hair marks from the brush or clogging of paint puddles in the corners of panels, angles or mouldings etc., shall be left on the work. The glass panes, floor etc. shall be cleaned of stains.

When the final coat is applied, if directed, the surface shall be rolled with a roller or if directed, it shall be stippled with a stippling brush.

FULL – GROUT

Spreading of Metal :

2.5 cm. to 4 cm. size stone metal shall be spread to a loose thickness of 10 cm. and compacted to a thickness of about 7.5 cm. by 8 ton power roller.

Applied Bitumen:

Bitumen 30/40 penetration of approved manufacturer, heated to a temperature of 200 C. (400 F) shall be applied hot by means of a pressure distributor or handspray at the rate of 65 kg. / 10 sqm.

Blinding the Surface :

Immediately following the application of bitumen and while it is still hot, key aggregate 12 mm. size shall be evenly spread at the rate of 0.2 cum. / 10 sqm. After spreading the aggregate the whole area shall be thoroughly rolled with a six to eight ton power roller. It is important that this rolling shall be done when the bitumen is still movement under the roller.

Protection of the Surface:

The surface shall be protected from all traffic.

Signature of Contractor with Seal

SEMI – GROUT

Spreading of Metal :

2.5 cm. to 4 cm. size stone metal shall be spread to a loose thickness of 7.5 cm. thick and compacted to a thickness of about 5 cm. by 8 ton power roller.

Applied Bitumen:

Bitumen 30/40 penetration of approved manufacturer, heated to a temperature of 200 C. (400 F) shall be applied hot by means of a pressure distributor or handspray at the rate of 25 kg. / 10 sqm.

Blinding the Surface :

As in Full–Grout.

Seal Coat (For Full Grout and Semi Grout Surface) :

The surface shall be brushed free of any loose blindage, taking care that the brushing is not so severe as to remove the blindage but of the voids into which it is set. The surface shall then be tested for depression, which shall be made up by painting with bitumen 30/40 penetration and blinding with aggregate of a size, equivalent to the depth of depression.

Application of Bitumen:

Bitumen 80/100 penetration of approved manufacturer, heated to a temperature of 177 to 190 C. (350 to 375 F) shall than be applied evenly to the road surface by means of a pressure distributor or handspray at the rate of 12.5 kg. / 10 sqm.

Blinding and Final Consolidation:

While the bitumen is still hot the surface shall be blinded evenly with stone aggregate of 6 mm. and down gauge size. The blindage shall be clean and not contain any dust and the rate of application shall be 0.1 cum. per 10 sqm.

After spreading of the blindage the road shall be given a final rolling with a eight ton power. Any soft or depressions detected at a later date shall be made up as directed by the Architect without any extra cost.

Premix Asphalt Carpet :

The rate shall include preparation of surface.

Preparation of Surface :

Clean the surface with wire brush and dust it with gunny bags. All pot holes, depressions and corrugations shall be made good and applying a tack coat of 80/100 penetration bitumen heated to 177 to 191 C. and the depressions made up with suitable size premix aggregate and consolidated by approved means. The surface shall then be painted with 80/100 penetration bitumen heated to 177 to 191 C. at the rate of 7.5 kgs. Per 10 sqm.

Signature of Contractor with Seal

Preparation of Premix :

Premix shall be prepared as under :

2.5 cm. thick consolidated.

No		Per 100 Sft.	Per 1000 Sft.
1	Stone metal 2 cm. (3/4")	5 Cft.	15.25 Cum.
2	Stone chips 10 mm. (3/8")	3 Cft.	9 Cum.
3	Grit / sand (of desired grade and quality)	4 Cft.	12 Cum.
4	Asphalt 80/100 penetration from approved manufacturer heated to 177 C.	50 lbs.	2450 Kgs.
5	Solvent*	3 lbs.	150 Kgs.
6	Filler	Either clean lime stone powder or Hydrated lime in desired quantity.	

4 cm. thick consolidated (to be done in 2 courses)

Base Course (2.5 cm. thick)

No		Per 100 Sft.	Per 1000 Sft.
1	Stone metal 2.5 cm. (1/4")	8 Cft.	24.5 Cum.
2	Stone chips 12 mm. (1/2")	4 Cft.	12 Cum.
3	Asphalt 60/70 penetration from approved manufacturer heated to 177 C.	36 lbs.	1760 Kgs.
4	Filler	As above.	

Wearing Course (1.5 cm. thick)

No		Per 100 Sft.	Per 1000 Sft.
5	Stone metal 12 cm. (1/2")	5 Cft.	15.25 Cum.
6	Grit / Chips 6 mm. (1/4")	2 Cft.	6 Cum.
7	Asphalt 60/70 or 80/100 penetration from approved manufacturer heated to 177 C.	22 lbs.	1075 Kgs.
8	Solvent*	1.5 lbs.	65 Kgs.
9	Filler	As above.	

The quantity of solvent may vary depending upon the local weather conditions. Use of solvent and its quantity shall be determined by the Architects before commencement of the work. Batches should be proportioned in accordance with the capacity of the mixer being used. Place clean stone metal and chips in the mixer. Add 2/3 of the batch of quantity of the hot asphalt at the designed temperature along with solvent and mix well. Add grit / sand and filler and continue mixing until the sand / grit is uniformly disturbed throughout the mix. The add remaining quantity of hot asphalt and continue mixing till the whole mix is uniform and homogenous. If desired, the sand / grit shall be heated before use. The mix shall then be carried to the place of deposition by means of wheel barrows.

The proportion suggested above should in the normal course give a dense mix. If necessary the proportions may be varied to obtain a dense mix, at the discretion of the Architects, at no extra cost.

Signature of Contractor with Seal

Laying of Premix:

The mix shall be laid to a uniform thickness and to proper level, grade and camber and rolled with six to eight ton power roller. The surface shall be checked for grade and camber during rolling and premix added and removed as required. The thickness shall be as specified after consolidation. When the base course is rolled the wearing course is laid similarly and rolled to give a consolidated thickness as specified in the time.

Premixed Seal Coat :

After the premix carpet is laid the surface shall be sealed with premix grit prepared as described under wearing course above with a suitable cutback added. The premixed seal must be brushed in to fill the interstices, additional material being applied during rolling of found necessary. The quantity of premixed seal shall be approximately 0.15 cum. per 10 cum. The surface shall be finally dusted with stone powder and rolled to give a smooth finish.

Road Concrete :

Specification for aggregate cement and concreting shall be as specified in the section under "Materials".

Before concreting, the surface shall be checked for the given profile. Wooden forms equal to the depth road slab thickness shall be erected to correct line and level and held by stakes driven into the ground along the outside edge at suitable intervals and two stakes being placed at each joint. Forms should be supported, strengthened or braced, whenever necessary so that they are able to prevent deformation and resist deformation under pressure of concrete or impact of tamping or vibrating. Working faces of all forms shall be thoroughly cleaned and oiled before use and forms which are used more than once, shall be carefully examined and trued if necessary before re-use.

Sub-grade shall be properly moistened before any concrete is deposited on it, care being taken to see that there are no standing pools of water. It may be advisable to have the sub-

grade watered 12 to 24 hours in advance of placing concrete. Concrete shall be laid in alternate bays not exceeding 30 sqm.

Concrete shall be deposited on sub-grade for the entire width of the slab and shall be kept sufficiently above the level of forms so that when tamped, it becomes a dense mass.

I.R.C. fabric reinforcement, if specified, shall be placed in correct position before commencing concreting.

The concrete shall be brought to the specified contour by means of heavy screed or tamper handles weighing not less than 10 kgs. / meter and not less than 7.5 cm. wide or surface vibrator if directed by the Architects. This screed or tamper may be steel. It shall be drawn with a saw in motion in combination with a series of lifts and drops. At transverse joint tamper shall be drawn not closer than one meter towards the joint and shall then be lifted and set down at the joint and drawn backwards away therefrom. Surplus concrete shall then be taken up with shovels and thrown ahead of the joint. Immediately after the screeding or tamping has been completed the surface shall be inspected for high and low spots and any needed correction made by adding or removing concrete. The entire surface shall then be floated with hand floats one meter long and 7.5 cm. wide and this operation must be performed from bridge provided across the slab. The surface shall be roughened by brooming.

Signature of Contractor with Seal

The longitudinal and transverse edges of the slab shall be properly formed with suitable tools and the same should be rounded to 10 mm. radius.

The finished surface of the slab must conform to the grade, alignment and contours as directed and cured for fourteen days.

After curing period is over the joints shall be filled up with approved bitumastic filler. Unless otherwise specified, the rate shall include filling of joints as specified.

MATERIAL TEST LIST

The Contractors will have to take necessary material test as per I.S. code which is applicable, at their own cost for the following materials or any other material using in construction work periodically or as and when required by the Architects / Consulting Engineer.

The materials should be got tested in an approved Laboratory as per IS standard and test reports in duplicate should be submitted to the Architect's Office.

- | | | | | |
|----|--------------------------------|---|----|-------------------------------------|
| 1) | Sand | : | a) | Silt Content. |
| | | | b) | Bulking. |
| | | | c) | Particle size distribution. |
| | | | d) | Or as directed. |
| 2) | Stone aggregate | : | a) | Soft and deleterious material. |
| | | | b) | Particle size distribution. |
| 3) | Cement Concrete RCC mix design | : | a) | Slump. |
| | | | b) | Cube strength. |
| | | | c) | Or as per I.S. 456-2000 |
| 4) | Bricks | : | a) | Dimensions |
| | | | b) | Water absorption and efflorescence. |
| | | | c) | Compressive strength. |
| 5) | Timber | : | | Moisture. |
| 6) | Ceramic/Vitrified Floor Tiles | : | a) | Transverse strength. |
| | | | b) | Water absorption. |
| | | | c) | Abrasion test. |
| 7) | Steel | : | a) | Tensile |
| | | : | b) | Bend. |

Note: The Contractor will have to take necessary material test other than above test as per relevant I.S. code, if required and as directed by Architect / Owner.

Signature of Contractor with Seal

MATERIAL TESTING

A chart showing the recommended time and quantity scheduled for conducting test on various building materials is given. Please ensure that tests are carried out according to the above guidelines. Contractor's rate should include for necessary expenditure for testing including transport of samples of following tests.

No	Material	Test	Test Procedure	Minimum Quantity	Frequency
1	Sand	a) Silt Content b) Bulking c) Particle size distribution	Field Field Field	20 Cum 20 Cum 40 Cum	20 Cum or part thereof --- Do --- Every 40 Cum required for RCC work.
2	Cement Concrete or RCC	Slump Cube Strength	Field Field Laboratory /	20 Cum slab, beams and connected columns 5 Cum in columns	Once a day or as desired. Every 20 Cum of a day's concrete. Every 5 Cum column concrete.
3	Steel	a) Tensile Strength	IS - 1529	20 tonnes	Every 20 tonnes or part.
		b) Bend Strength	---- Do ----	---- Do ----	---- Do ----
4	R.C.C. design mix M-25	All test as per I.S.:456-2000		As per directed	As per directed

Note : The Contractor will have to take necessary material test other than above test as per I.S. code for above material or other than above material, if required and as directed by the Architect / Owner.

Signature of Contractor with Seal

THEORETICAL CEMENT CONSUMPTION STATEMENT (BASE CPWD)

No	Description of item of work.	Quantity of cement to be used per Unit Quantity of work.	Unit.
1	Cement Concrete (Cast in Situ) Plain or Reinforced.		
a.	1:1:2 (1 Cement : 1 Sand :2 Graded Aggregate).	12.20 Bags.	Cubic Meter
b.	1:1.5:3 (1 Cement:1.5 sand:3 Graded Aggregate).	8.00 Bags.	Cubic Meter
c.	1:2:4 (1 Cement : 2 Sand :4 Graded Aggregate).	6.40 Bags.	Cubic Meter
d.	1:3:6 (1 Cement : 3 Sand :6 Graded Aggregate).	4.40 Bags.	Cubic Meter
e.	1:4:8 (1 Cement : 4 Sand :8 Graded Aggregate).	3.40 Bags.	Cubic Meter
f.	1:5:10(1 Cement : 5 Sand :10 Graded Aggregate).	2.60 Bags.	Cubic Meter
g.	Providing and laying cement concrete 1:2:4 (1 Cement: 2 Coarse Sand: 4 Graded Aggregate of 20 mm. nominal size) including finishing exposed surface with 6 mm. thick cement mortar 1:3 (1 Cement: 3 Fine Sand). Kerbs, Steps, and the like.	7.02 Bags.	Cubic Meter
h.	String or lacing courses, parapets, coping, bed blocks, anchor blocks, plain window cills and the like mouldings in cornices, window cills etc.	7.62 Bags.	Cubic Meter
2.	Cement Mortar		
a.	1:1 (1Cement: 1 Sand)	20.40 Bags.	Cubic Meter
b.	1:2 (1Cement: 2 Sand)	13.60 Bags.	Cubic Meter
c.	1:3 (1Cement: 3 Sand)	10.20 Bags.	Cubic Meter
d.	1:4 (1Cement: 4 Sand)	7.60 Bags.	Cubic Meter
e.	1:5 (1Cement: 5 Sand)	6.20 Bags.	Cubic Meter
f.	1:6 (1Cement: 6 Sand)	5.00 Bags.	Cubic Meter
g.	1:2 (1Cement: 2 Stone Dust)	13.60 Bags.	Cubic Meter
h.	1:2 (1Cement: 2 Marble Dust)	13.60 Bags.	Cubic Meter
i.	1:5 (1Cement: 5 Marble Dust)	6.20 Bags.	Cubic Meter
j.	1:1:3 (1Cement: 1 Marble Dust: 3 Stone Dust)	7.60 Bags.	Cubic Meter
k.	White Cement Mortar 1:2 (1 White Cement : 2 Marble Dust)	13.60 Bags.	Cubic Meter
l.	White Cement Mortar 1:3 (1 White Cement : 3 Marble Dust)	10.20 Bags.	Cubic Meter
m.	White Cement Mortar 1:5 (1 White Cement : 5 Marble Dust)	6.20 Bags.	Cubic Meter
3.	Cement Lime Mortar		
a.	1:1:3 (1 Cement:1 Lime putty:3	8.20 Bags.	Cubic Meter

Signature of Contractor with Seal

	Sand)		
b.	1:1:6 (1 Cement:1 Lime putty:6 Sand)	5.00 Bags.	Cubic Meter
4.	Brick Work in All Classes		
a.	In Cement Mortar 1:3 (1 Cement:3 Sand)	2.56 Bags.	Cubic Meter
b.	In Cement Mortar 1:4 (1 Cement:4 Sand)	1.90 Bags.	Cubic Meter
c.	In Cement Mortar 1:5 (1 Cement:5 Sand)	1.56 Bags.	Cubic Meter
d.	In Cement Mortar 1:6 (1 Cement:6 Sand)	1.24 Bags.	Cubic Meter
5.	Half Brick Work in All Classes		
a.	In Cement Mortar 1:3 (1 Cement:3 Sand) With or without hoop iron.	28.56 Bags per 100 Square Meter	
b.	In Cement Mortar 1:4 (1 Cement:4 Sand)	21.28 Bags per 100 Square Meter	
c.	In Cement Mortar 1:5 (1 Cement:5 Sand)	14.50 Bags per 100 Square Meter	
d.	Moulding and cornices in brick masonry in cement mortar 1:4 Cement:4 Sand) Joining old brick work with new brick work.	0.18 Bags per 100 Square Meter per cm. girth	
	a) Old Brick in metric or FPS. System with new brick work in metric system in cement mortar 1:4 (1 Cement : 4 Sand).	4.20 Bags per 100 Square Meter	
	b) Old Brick work in FPS. System with new brick work in cement mortar 1:4 (1 Cement: 4 Sand).	5.44 Bags per 100 Square Meter	
6.	Random Rubble Masonry		
a.	Cement Mortar 1:6 (1 Cement : 6 Sand)	1.70 Bags.	Cubic Meter
b.	Cement Lime Mortar 1:1:8 (1 Cement : 1 Lime Putty : 8 Sand)	1.32 Bags.	Cubic Meter
7.	Coursed Rubble Masonry		
a.	Cement Mortar 1:6 (1 Cement : 6 Sand)	1.50 Bags.	Cubic Meter
8.	Ashlar Masonry In plain ashlar punched (ordinary) in superstructure in cement mortar 1:6 (1 Cement : 6 Sand) including pointing with cement mortar 1:2 (1Cement:6 Stone dust) with an admixture of pigment matching the stone shade.	1.08 Bags.	Cubic Meter

Signature of Contractor with Seal

9.	Stone Veneering Work For wall lining etc., average thickness 40 mm. to 170 mm. in cement lime mortar 1:1:6 (1Cement:1 Lime Putty:6 Sand) including pointing in White cement mortar 1:2 (1 White Cement : 2 Stone Dust) with an admixture of pigment matching the stone shade.	17.50 Bags per 100 Square Meter	
10.	Marble work in steps jambs, walls, pillars and other plain work in cement mortar 1:4 (1 Cement : 4 Sand) including pointing in White cement mortar 1:2 (1 Cement : 2 Marble dsust).	0.136 Bags per 1.52 Bags per	Cubic Meter (Grey Cement) Cubic Meter (White Cement)
11.	Marble work in steps jambs, walls, pillars and other plain work in cement mortar 1:4 (1 Cement : 4 Sand) including pointing in cement mortar (1 Cement : 2 Marble dsust).	1.66 Bags per	Cubic Meter
12.	Marble work for wall lining (Veneer work) 2.5 cm. thick in cement mortar 1:3 (1 Cement : 3 Sand) including pointing in White cement mortar 1:2 (1 Cement : 2 Marble dust).	14.28 Bags per 100 Square Metre 3.40 Bags per 100 Square Metre	(Grey Cement) (White Cement)
13.	Marble work for wall lining (Veneer work) 2.5 cm. thick in cement mortar 1:3 (1 Cement : 3 Sand) including pointing in cement mortar 1:2 (1 Cement : 2 Marble dust).	17.68 Bags per	Square Meter
14.	Marble work for wall lining (Veneer work) 4 cm. thick in cement mortar 1:3 (1 Cement : 3 Sand) including pointing in White cement mortar 1:2 (1 Cement : 2 Marble dust).	20.40 Bags per 100 Square Metre. 3.40 Bags per 100 Square Metre	(Grey Cement) (White Cement)
15.	Marble work for wall lining (Veneer work) 4 cm. thick in cement mortar 1:3 (1 Cement : 3 Sand) including pointing in cement mortar 1:2 (1 Cement : 2 Marble dust).	23.80 Bags per 100 Square Metre.	
16.	Cement Concrete Flooring Flooring 1:2:4 (1 Cement : 2 Sand : 4 Graded Stone Aggregate) finished with a floating coat of neat cement including cement slurry rounding of edges and strips etc., but excluding cost of nosing of steps etc., complete.		
a.	25 mm. thick with 20 mm. nominal size stone aggregate.	0.244 Bags	Square Meter
b.	40 mm. thick with 20 mm. nominal size stone aggregate.	0.34 Bags	Square Meter
c.	50 mm. thick with 20 mm. nominal size stone aggregate.	0.404 Bags	Square Meter

Signature of Contractor with Seal

d.	75 mm. thick with 20 mm. nominal size stone aggregate.	0.564 Bags	Square Meter
17.	Cement Plaster Skirting (upto 30 cm. height) with cement mortar 1:3 (1 Cement : 3 Coarse Sand) finished with a floating coat of neat cement including rounding of junctions with floor, including slurry complete.		
a.	18 mm. thick.	0.32 Bags	Square Meter
b.	21 mm. thick.	0.35 Bags	Square Meter
18.	Pavement (25 to 50 mm. thick) with 1:2:4 (1 Cement : 2 Coarse Sand : 4 Graded Stone Aggregate 20 mm. nominal size) including finishing complete.	6.80 Bags	Cubic Meter
19.	Terrazo Flooring 40 mm. thick marble chips flooring rubbed and polished to granolithic finish, under layer 34 mm. thick cement concrete 1:2:4 (1 Cement: 2 Coarse Sand : 4 Graded Stone Aggregate 12.5 mm. nominal size) and top layer 6 mm. thick with white, black or white and black marble chips of size 1 mm. to 4 mm. nominal size laid in cement marble powder 3:1 mix. (3 Cement : 1 Marble Powder) by weight in proportion of 4:7 (4 Cement marble powder) by weight in marble powder mix:7 Marble chips) by volume including cement slurry etc., complete.		
a.	Dark shade / Light shade pigment with ordinary cement.	0.339 Bags per	Square Meter
b.	Light shade pigment with white cement.	0.258 Bags per 0.081 Bags per	Square Meter (Grey Cement) (White Cement)
c.	Medium shade pigment with approximately 50% white cement and 50% ordinary cement.	0.298 Bags 0.0440 Bags per	Square Meter (Grey Cement) (White Cement)
20	40 mm. thick marble chips flooring rubbed and polished to granolithic finish, under layer 31 mm. thick cement concrete 1:2:4 (1 Cement: 2 Coarse Sand : 4 Graded Stone Aggregate 12.5 mm. nominal size) and top layer 9 mm. thick marble chips, chips, size 4 to 7 mm. size, laid in cement marble powder mix. 3:1) (3 Cement : 1 Marble Powder) by volume in proportion of 4:7 (4 Cement		

Signature of Contractor with Seal

	marble powder mix. 7 Marble chips) by volume including cement slurry etc., complete.		
a.	Dark shade / Light shade pigment with ordinary cement.	0.357 Bags	Square Meter
b.	Light shade pigment with white cement.	0.241 Bags 0.116 Bags	Square Meter (Grey Cement) Square Meter (White Cement)
c.	Medium shade pigment with approximately 50% white cement and 50% ordinary cement.	0.299 Bags 0.058 Bags	Square Meter (Grey Cement) Square Meter (White Cement)
21	40 mm. thick marble chips flooring rubbed and polished to granolithic finish, under layer 28 mm. thick cement concrete 1:2:4 (1 Cement: 2 Coarse Sand : 4 Graded Stone Aggregate 12.5 mm. nominal size) and top layer 9 mm. thick marble chips, chips, sizes 7 mm to 10 mm. nominal size, laid in cement marble powder mix. 3:1) by weight in proportion of 2:3 (2 Cement Marble Powder mix. 3 Marble Chips) by volume including cement slurry etc., complete.		
a.	Dark or Light shade pigments with grey cement.	0.381 Bags	Square Meter
b.	Light shade pigment or without any pigment with white cement.	0.219 Bags 0.162 Bags	Square Meter (Grey Cement) Square Meter (White Cement)
c.	Medium shade pigment with approximately 50% grey cement and 50% white cement.	0.300 Bags 0.081 Bags	S.M. (Grey Cement) S.M.(White Cement)
22	Marble chips skirting (up to 300 mm high) rubbed and polished to granolithic finish top layer 6 mm. thick marble chips of sizes from smallest to 4 mm. nominal size laid to cement marble powder mix. 3:1 (3 Cement: 1 Marble Powder mix. By weight in proportion of 4:7 (4 Cement Marble Powder mix: 7 marble chips) by volume including cement slurry complete.		
a.	18 mm. thick with under layer 12 mm. thick cement plaster 1:3 (1 Cement: 3	0.298 Bags	Square Meter

Signature of Contractor with Seal

	Course Sand) dark or light shade pigment with grey cement.		
b.	Light shade pigment or no pigment with cement.	0.217 Bags Square Meter (Grey Cement) 0.081 Bags Square Meter (White Cement)	
c.	Medium shade colour pigment with 50% grey cement and 50% white cement.	0.258 Bags Square Meter (Grey Cement) 0.0406 Bags Square Meter (White Cement)	
d.	21 mm. thick with under layer 15 mm. thick cement plaster 1:3 (1 Cement: 3 Course Sand) dark or light shade pigment with grey cement.	0.327 Bags	Square Meter
e.	Light shade pigment or no pigment with white cement.	0.246 Bags Square Meter (Grey Cement) 0.081 Bags Square Meter (White Cement)	
f.	Medium shade pigment with 50% grey cement and 50% white cement.	0.286 Bags Square Meter (Grey Cement) 0.04 Bags Square Meter (White Cement)	
23.	Tile Flooring :		
a.	Precast terrazzo tiles 20 mm. thick white black or white and black marble chips of size up to 6 mm. laid in floors treads of steps and landings jointed with neat cement slurry mixd with pigment to match the shade of the tile including rubbing polishing with precast tiles of 30 mm. thick bed of lime mortar 1:1.2 or 1:3 light shade using white cement.	0.088 Bags Square Meter (Grey Cement) 0.088 Bags Square Meter (White Cement)	
b.	Medium shade colour pigment with 50% white cement and 50% grey cement.	0.132 Bags Square Meter (Grey Cement) 0.044 Bags Square Meter (White Cement)	
c.	Dark shades using ordinary cement precast terrazo tiles 20 mm. thick with marble chips of size 6 mm. in skirting and risers of steps not exceeding 30 cm. in height on wall, laid on 12 mm. thick cement plaster 1:3 mix. (1 Cement: 3 Sand) joint with neat cement slurry, light shades using white cement.	0.235 Bags Square Meter (Grey Cement) 0.044 Bags Square Meter (White Cement)	
d.	Medium shade colour pigment with 50% white cement and 50% ordinary cement.	0.257 Bags Square Meter (Grey Cement) 0.022 Bags Square Meter (White Cement)	
e.	Dark shades using ordinary cement.	0.279 Bags	Square Metre
24.	Chequered Terrazo Tile Flooring		

Signature of Contractor with Seal

a.	Chequered Terrazo Tile 22 mm. thick with marble chips of sizes upto 6 mm. in floors, jointed with neat cement slurry mixed with pigment to match the shade of the tiles including robbing, polishing complete on 28 mm. thick bed of lime mortar 1:1.2 or 1:3.		
a.	Light shade using white cement.	0.088 Bags Square Meter (Grey Cement) 0.096 Bags Square Meter (White Cement)	
b.	Medium shades using 50% grey cement and 50% white cement.	0.136 Bags Square Meter (Grey Cement) 0.048 Bags Square Meter (White Cement)	
c.	Dark shade using grey cement.	0.184 Bags Square Meter (Grey Cement)	
d.	Chequered Terrazo Tile 30 mm. thick with marble chips of sizes upto 6 mm. in stairs, treads, jointed with neat cement slurry mixed with pigment to match the shade of the tiles including rubbing polishing rounding of nosing etc., complete on 20 mm. bed of : Lime mortar 1:1:1 (1 Lime putty:1 Surkhi:1 Coarse Sand) :		
i.	Light shade using white cement.	0.088 Bags Square Meter (Grey Cement) 0.136 Bags Square Meter (White Cement)	
ii.	Medium shades using 50% grey cement and 50% white cement.	0.154 Bags Square Meter (Grey Cement) 0.066 Bags Square Meter (White Cement)	
iii.	Dark shade using grey cement.	0.220 Bags Square Meter (Grey Cement)	
e.	Cement mortar 1:4 (1 Cement:4 Coarse Sand)		
i.	Light shade using white cement.	0.258 Bags Square Meter (Grey Cement) 0.132 Bags Square Meter (White Cement)	
ii.	Medium shades using 50% grey cement and 50% white cement.	0.324 Bags Square Meter (Grey Cement) 0.066 Bags Square Meter (White Cement)	
iii.	Dark shade using grey cement.	0.39 Bags Square Meter (Grey Cement)	
25.	White Glazed Tiles.		
	White Glazed Tiles 5,6 or 7 mm. thick in flooring treads risers of steps skirting and dado on 12 mm. thick cement plaster 1:3 (1 Cement : 3 sand) in base and cement jointed with white cement slurry etc. complete.	0.188 Bags Square Meter (Grey Cement) 0.050 Bags Square Meter (White Cement)	
26.	Marble Stone Flooring		
	Marble Stone slab flooring over 20 mm. thick base of lime mortar 1:1:1 (1 Lime putty:1 Surkhi:1 Sand) and jointed with grey cement slurry etc. (all marble slabs).		
a.	20 mm. thick	0.098 Bags Square Meter	
b.	30 mm. thick	0.102 Bags Square Meter	
c.	40 mm. thick	0.107 Bags Square Meter	

Signature of Contractor with Seal

	Marble stone slab flooring over 20 mm. thick base of cement mortar 1:4 (1 Cement:4 Sand) and jointed with grey cement slurry etc., (all marble slabs).		
d.	20 mm. thick	0.268 Bags Square Meter	
e.	30 mm. thick	0.273 Bags Square Meter	
f.	40 mm. thick	0.277 Bags Square Meter	
g.	Extra if white cement slurry is used instead of grey cement slurry in joints of marble stone flooring.	0.015 Bags Square Meter (White Cement)	
h.	Marble slabs 30 mm. thick in risers of steps, skirting dado, wall and pillars, laid on 12 mm. thick cement mortar 1:3 (1 Cement : 3 Sand) and jointed with grey cement slurry.	0.246 Bags Square Meter (White Cement)	
27.	Kotah Stone Flooring		
	Kotah stone slab flooring over 20 mm. thick base of lime mortar 1:1:1 (1 Lime putty:1 Surkhi:1 Sand) and jointed with neat cement slurry etc.		
a.	25 mm. thick	0.128 Bags Square Meter	
b.	30 mm. thick	0.136 Bags Square Meter	
c.	40 mm. thick	0.152 Bags Square Meter	
	Kotah Stone slab flooring over 20 mm. thick base of cement mortar 1:4 (1 Cement:4 Sand) and jointed with neat cement slurry etc.		
d.	25 mm. thick	0.298 Bags Square Meter	
e.	30 mm. thick	0.306 Bags Square Meter	
f.	40 mm. thick	0.322 Bags Square Meter	
g.	Kotah stone slab 25 mm. thick risers of steps, skirting, dado and pillar laid on 12 mm. thick cement mortar 1:3 (1 Cement:3 Sand) and jointed with neat cement slurry etc.	0.275 Bags Square Meter	
28	Sand Stone Flooring		
a.	40 mm. thick sand stone flooring over 20 mm. thick base of cement mortar 1:5 (1 Cement :5 Sand) with joints finish flush.	0.155 Bags Square Meter	
b.	40 mm. thick sand stone flooring over 20 mm. thick base of cement mortar 1:5 (1 Cement :5 Sand) including pointing with cement mortar 1:2 (1 Cement : 2 Stone Dust).	0.186 Bags Square Meter	
c.	40 mm. thick sand stone flooring over 20 mm. thick base of lime mortar 1:1:1 (1 Lime :1 Surkhi:1 Sand) including pointing with cement plaster 1:2 (1 Cement :2 Stone Dust).	0.031 Bags Square Meter	

Signature of Contractor with Seal

d.	40 mm. thick fine dressed and rubbed stone flooring over 20 mm. thick base of cement mortar 1:5 (1 Cement :5 Sand) with joints 5 mm. thick finished flush.	0.166 Bags Square Meter
e.	40 mm. thick fine dressed and rubbed stone flooring over 20 mm. thick base of lime mortar 1:5 (1 Cement : 5 Sand) with joints 5 mm. thick including pointing with cement mortar 1:2 (1 Cement : 2 Stone Dust).	0.196 Bags Square Meter
f.	25 mm. thick cast iron grid flooring using grid tiles of required size weighing 47 kg. per square metre on bed of 12 mm. thick cement concrete 1:2 (1 Cement : 2 Stone Aggregate 6 mm. nominal size) including filling the hollows with cement concrete same mix and tamping with 10 mm. dia. iron bars and grouting the joints with neat cement slurry complete.	0.025 Bags Square Meter
g.	Filling cement concrete 1:2:4 (1 Cement :2 Coarse Sand : 4 Graded Stone Aggregate 12.5 mm. nominal size) in gaps of A.C.Sheet corrugations and wings of ridges.	3.82 Bags Square Meter
29.	Cement Plaster	
a.	12 mm. 1:3 (1 Cement : 3 Sand).	14.68 100 Square Metre
b.	12 mm. 1:4 (1 Cement : 4 Sand).	10.94 100 Square Metre
c.	12 mm. 1:5 (1 Cement : 5 Sand).	8.92 100 Square Metre
d.	12 mm. 1:6 (1 Cement : 5 Sand).	7.20 100 Square Metre
e.	15 mm. 1:3 (1 Cement : 3 Sand).	17.54 100 Square Metre
f.	15 mm. 1:4 (1 Cement : 4 Sand).	12.08 100 Square Metre
g.	15 mm. 1:5 (1 Cement : 5 Sand).	10.66 100 Square Metre
h.	12 mm. 1:6 (1 Cement : 6 Sand).	8.60 100 Square Metre
i.	20 mm. 1:3 (1 Cement : 3 Sand).	22.84 100 Square Metre
j.	20mm. 1:4 (1 Cement : 4 Sand).	17.02 100 Square Metre
k.	20 mm. 1:5 (1 Cement : 5 Sand).	13.88 100 Square Metre
l.	20 mm. 1:6 (1 Cement : 6 Sand).	11.20 100 Square Metre
30.	Cement Plaster with a Floating Coat of neat cement	
a.	12 mm. 1:3 (1 Cement: 3 Sand).	19.08 100 Square Metre
b.	12 mm. 1:4 (1 Cement: 4 Sand).	15.34 100 Square Metre
c.	12 mm. 1:3 (1 Cement: 3 Sand).	21.94 100 Square Metre
d.	12 mm. 1:4 (1 Cement : 4 Sand).	17.48 100 Square Metre
e.	15 mm. 1:3 (1 Cement : 3 Sand).	27.24 100 Square Metre
f.	15 mm. 1:4 (1 Cement : 4 Sand).	21.42 100 Square Metre
31.	Cement Plaster in two coats	

a.	20 mm. Cement Plaster in two coats under layer 12 mm. cement plaster 1:4 (1 Cement :4 Sand) finished with a top layer 8 mm. thick cement plaster 1:3 (1 Cement : 3 Sand)	20.00 Bags per 100 Square Metre
b.	18 mm. thick Cement Plaster in two coats under layer 12 mm. thick cement plaster 1:5 (1 Cement :5 Sand) finished with a top layer 6 mm. thick cement plaster 1:3 (1 Cement : 3 Sand)	16.26 Bags per 100 Square Metre
32.	6 mm. Cement Plaster	
a.	6 mm. Cement Plaster to ceiling 1:3 (1 Cement :3 Sand)	7.34 Bags per 100 Square Metre
b.	6 mm. Cement Plaster to ceiling 1:4 (1 Cement :4 Sand)	5.48 Bags per 100 Square Metre
c.	6 mm. Cement Plaster to ceiling 1:3 (1 Cement :3 Sand) finished with a floating coat of neat cement.	11.74 Bags per 100 Square Metre
d.	Neat Cement Punning.	4.40 Bags per 100 Square Metre
33.	Sand Cement Neeru Finished Plaster	
a.	Sand cement smooth neeru finished plaster for ceiling in cement mortar mix 1:4 (1 Cement :4 Sand), 10 to 15 mm. thick average, finished top smooth with neeru.	13.00 Bags per 100 Square Metre
b.	Sand cement smooth neeru finished plaster for walls in cement mortar mix 1:4 (1 Cement :4 Sand), 18 to 20 mm. thick average, finished top smooth with neeru.	19.00 Bags per 100 Square Metre
34.	Rough Cast Plaster	
	Rough Cast Plaster with a mixture of sand and gravel or crushed stone from 2.36 mm. to 12.5 mm. nominal size dashed over and including the fresh plaster in two layers, top layer 10 mm. cement plaster 1:3 (1 Cement: 3 Sand) mixed with 10% finely grounded hydrated lime by volume of cement and under layer 12 mm. cement plaster : 1:4 (1 Cement: 4 Sand)	
a.	With ordinary cement finish or cement pigment finish.	23.18 Bags per 100 Square Metre
b.	With white cement and pigment finish.	10.94 Bags 100 Sqm.(Grey Cement) 12.24 Bags 100 Sqm. (White Cement)
	1:5 Cement Sand (1 Cement:5 Sand)	
c.	With ordinary cement finish or cement and pigment finish.	21.16 Bags 100 Sqm.(Grey Cement)
d.	With white cement and pigment finish.	8.92 Bags 100 Sqm.(Grey Cement) 12.24 Bags 100 Sqm. (White Cement)

Signature of Contractor with Seal

35.	Pointing on Stone Work	
a.	Flush or ruled pointing on stone work with cement mortar 1:3 (1 Cement : 3 Sand)	2.34 Bags per 100 Square Metre
b.	Raised and cut pointing in stone work with cement mortar 1:3 (1 Cement : 3 Sand)	3.88 Bags per 100 Square Metre
36.	Waterproofing	
a.	Proprietary waterproofing treatment to the terrace with brick-bat coba, cement base.	55.00 Bags per 100 Square Metre
b.	Proprietary waterproofing treatment to the canopy with brick-bat coba, cement base.	45.00 Bags per 100 Square Metre
c.	Waterproofing chajja with sand cement plaster average 25 mm. thick in cement mortar 1:3 (1 Cement :3 Sand)	25.00 Bags per 100 Square Metre
d.	Proprietary waterproofing treatment to the sunk portion of toilet, cement base.	30.00 Bags per 100 Square Metre

THEORETICAL CEMENT CONSUMPTION STATEMENT (BASE CPWD)

No	Description of item of work.	Quantity of cement to be used per Unit Quantity of work.	Unit.
1.	Cast Iron Pipes		
	Providing and fixing on wall face C.I. rain water pipes including filling the joints with spun yarn soaked in neat cement slurry and cement mortar 1:2 (1 Cement : 2 Sand)		
a.	75 mm. dia pipe	0.132 Bags per 100 Metre	
b.	105 mm. dia pipe	0.176 Bags per 100 Metre	
c.	150 mm. dia pipe	0.264 Bags per 100 Metre	
2.	Cast Iron Accessories		
	Providing and fixing on wall face C.I. Accessories for rain water pipes including filling the joints with spun yarn soaked in neat cement slurry and cement mortar 1:2 (1 Cement : 2 Fine Sand)		
a.	75 mm. dia pipe C.I. Plain bend.	0.0052	Each
b.	100 mm. dia pipe C.I. Plain bend.	0.0062	Each
c.	150 mm. dia pipe C.I. Plain bend.	0.010	Each
d.	75 mm. dia C.I. head flat or corner type.	0.003	Each
e.	100 mm. dia C.I. head flat or corner type.	0.003	Each
f.	150 mm. dia C.I. head flat or corner type.	0.0052	Each

Signature of Contractor with Seal

g.	75 mm. dia C.I. plain shoe.	0.003	Each		
h.	100 mm. dia C.I. plain shoe.	0.003	Each		
i.	150 mm. dia C.I. plain shoe.	0.0052	Each		
j.	75 mm. dia C.I. single branch (plain)	0.0052	Each		
k.	100 mm. dia C.I. single branch (plain)	0.0062	Each		
l.	150 mm. dia C.I. single branch (plain)	0.0010	Each		
m.	75 mm. dia C.I. double branch (plain)	0.008	Each		
n.	100 mm. dia C.I. double branch (plain)	0.009	Each		
o.	150 mm. dia C.I. double branch (plain)	0.0052	Each		
p.	C.I. off-sets (plain) 75 mm. dia. 55 mm. projection.	0.0052	Each		
q.	C.I. off-sets (plain) 75 mm. dia. 150 mm. projection.	0.0052	Each		
r.	C.I. off-sets (plain) 100 mm. dia. 55 mm. projection.	0.0052	Each		
s.	C.I. off-sets (plain) 100 mm. dia. 55 mm. projection.	0.0062	Each		
t.	C.I. off-sets (plain) 100 mm. dia. 75 mm. projection.	0.0062	Each		
3.	A.C. Fittings & Pipes				
	Providing and fixing on wall face asbestos cement rain water pipes including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement 2 Coarse Sand) complete.				
a.	50 mm. dia.	0.150	100 Metre		
b.	80 mm. dia.	0.250	100 Metre		
c.	100 mm. dia.	0.300	100 Metre		
d.	150 mm. dia.	0.320	100 Metre		
e.	Providing and fixing A.C. Pipe (or any diameter) wall plugs and standard holder bat clamps comprising of two semi-circular halves of flat and cast iron base screwed on wooden plugs.	0.0004	100 Metre		
f.	Providing and fixing on wall face asbestos cement rain water pipes including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement 2 Coarse Sand) complete.				
		50 mm. (2")	80 mm. (3")	100 mm. (4")	Unit
g.	Bend of required degree with door or without door.	0.0072	0.012	0.015	Each
h.	Off-set 52.2 mm. projection.	0.0058	0.0090	0.0116	Each
i.	Off-set 76.2 mm. projection.	0.0058	0.0090	0.011	Each
j.	Off-set 114.3 mm. projection.	0.0058	0.0090	0.0116	Each
k.	Off-set 152.4 mm. projection.	0.0058	0.0090	0.0116	Each
l.	Off-set 228.6 mm. projection.	0.0058	0.0090	0.0116	Each

Signature of Contractor with Seal

m.	Off-set 304.8 mm. projection.	--	0.0090	0.0116	Each
n.	Off-set 457.2 mm. projection.	--	0.0090	0.0116	Each
o.	Off-set 609.6 mm. projection.	--	--	0.0116	Each
p.	Junction equal single of required degree with or without door.	0.0072	0.0116	0.0146	Each
q.	Junction equal double with or without door or required degree.	0.0108	0.0174	0.0220	Each
r.	Standard shoe.	0.00400	0.0058	0.0058	Each
4.	Sanitary Fittings				
a.	Fixing long pan pattern or Orissa pattern squatting pan or pedestal type water closet 12.5 litres or 15 litres flushing cistern and brackets, telescopic flush pipe or bend with fittings and clamps, overflow pipe with specials and mosquito proof coupling complete including cutting and making good the walls and floors.	0.10			Each
	Fixing flat back or wall corner type, lipped front, urinal basin of 430 x 260 x 350 mm. and 340 x 430 x 265 mm. size respectively, white glazed earthenware with automatic C.I. flushing cistern with fittings, brackets, standard size flush pipe and spreaders with brass union and G.I. clamps complete including painting of cistern and fittings, cutting and making good the walls and floors.	0.050			Each
b.	One urinal basin with 5 litres C.I. automatic flushing cistern.	0.050			Each
c.	Range of two urinal basins with 10 litres C.I. automatic flushing cistern.	0.08			Each
d.	Range of three urinal basins with 10 litres C.I. automatic flushing cistern.	0.134			Each
e.	Range of four urinal basins with 15 litres C.I. automatic flushing cistern.	0.190			Each
	Fixing white glazed fire clay stall urinal with automatic C.I. flushing cistern with fittings R.S. or C.I. brackets standard size C.P. brass flush pipe and spreaders with unions and clamps, C.I. trap with outlet grating and other coupling in C.P. brass including painting of cistern and fittings, cutting and making good the walls and floors.				
f.	Single stall urinal with 5 litres C.I. automatic flushing cistern.	0.102			Each
g.	Range of two urinal basins with 10 litres C.I. automatic flushing cistern.	0.204			Each

Signature of Contractor with Seal

h.	Range of three urinal basins with 10 litres C.I. automatic flushing cistern.	0.306 Bags	Each
i.	Range of four urinal basins with 15 litres C.I. automatic flushing cistern.	0.406 Bags	Each
	Fixing one piece construction white squatting plate urinal with an integral longitudinal flushing pipe 100 mm. dia. half round channel automatic C.I. flushing cistern with fittings R.S. or C.I. brackets, standard size. G.I. flush pipe for back and front flush with standard spreader pipes with fittings G.I. clamps, white vitreous tiling 1200 mm. high to the front and side walls with white vitreous china corners and angles set in neat cement, standard urinals C.I. trap 65 mm. diameter with vent arm and outlet grating and coupling in C.P. brass complete, including painting the cistern and fittings and making good the walls and floors.		
j.	Single squatting plate with 5 litres C.I. automatic flushing cistern.	0.102 Bags	Each
k.	Range of two squatting plates with 10 litres C.I. automatic flushing cistern.	0.204 Bags	Each
l.	Range of three squatting plates with 10 litres C.I. automatic flushing cistern.	0.306 Bags	Each
m.	Range of four squatting plates with 15 litres C.I. automatic flushing cistern.	0.406 Bags	Each
n.	Fixing lavatory basin with brackets, pillar taps, rubber plug, waste of standard pattern, trap and unions complete including cutting and making good the walls.	0.050 Bags	Each
o.	Fixing white pedestal for wash basin completely recessed at the back for reception of pipes and fittings.	0.032 Bags	Each
p.	Fixing sink with brackets, 40 mm. rubber plus, brass chain, waste, trap with necessary unions complete including cutting and making good the walls.	0.050 Bags	Each
q.	Fixing teal-wood draining board with skirting and beading, wax polished with brackets painted white complete including making good the walls.	0.028 Bags	Each
5.	Sanitary Fittings (Items separately ordered)		

Signature of Contractor with Seal

a.	Fixing long pan pattern or Orissa pattern squatting, or pedestal type W.C. pan.	0.050 Bags	Each
b.	Fixing a pair of white glazed earthenware or vitreous china foot rests of standard pattern for Indian type W.C. pan.	0.010 Bags	Each
c.	Fixing flat back or wall corner type lipped front urinal basin of 430 x 260 x 350 mm. and 340 x 430 x 265 mm.	0.020 Bags	Each
d.	Fixing white glazed fire clay stall urinal of standard size.	0.04 Bags	Each
e.	Fixing white squatting plate urinal with integral longitudinal flush pipe. .	0.040 Bags	Each
f.	Fixing wash basin including making all connections excluding cost of fittings.	0.030 Bags	Each
g.	Fixing kitchen sink including making all connections complete.	0.030 Bags	Each
h.	Fixing in position 32 mm. diameter galvanised steel telescopic flush pipe complete including cutting and making good the walls and floor.	0.020 Bags	Each
6.	Sand Cast Iron Pipe and Fittings		
a.	Fixing M.S. holder bat clamp to 100 mm. dia. sand cast iron pipe embedded in cement concrete blocks 10 x 10 x 10 cm. of cement concrete 1:2:4 (1 Cement : 2 Sand : 4 Stone Aggregate) including cost of cutting holes and making good the walls etc.	0.010 Bags	Each
b.	Fixing M.S. stays and clamps for 100 mm. diameter sand cast iron pipe.	0.010 Bags	Each
c.	Fixing M.S. holder bat clamps for 50 mm. diameter sand cast iron pipe embedded in cement concrete block 10 x 10 x 10 cm. of 1:2:4 (1 Cement : 2 Sand : 4 Stone Aggregate) including cost of cutting holes and	0.010 Bags	Each
	making good the walls etc.		
d.	Fixing M.S. stays and clamps for 50 mm. diameter sand cast iron pipe.	0.010 Bags	Each
e.	Fixing sand cast iron trap 100 mm. inlet 100 mm. outlet of selfcleaning design with sand cast iron screwed down or hinged grating with or without vent arm complete including cost of cutting without and making good the walls and floor.	0.050 Bags	Each
f.	Fixing 100 mm. inlet and 50 mm. outlet sand cast iron floor trap of self cleaning design with sand cast iron screwed down or hinged grating with	0.050 Bags	Each

Signature of Contractor with Seal

	or without vent arm complete including cost of cutting and making good the walls and floors.		
7.	Asbestos Cement Soil, Waste and Vent Pipes and Fittings		
	Providing and fixing on wall face asbestos cement soil waste and vent pipe including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement: 2 Sand) complete.		
a.	For 100 mm. diameter.	0.300 Bags	100 Metre
b.	For 50 mm. diameter.	0.150 Bags	100 Metre
	Fixing wooden plugs and standards holder bat clamps comprising of two semicircular halves of flat iron and cast iron base screwed on wooden plugs.		
c.	For 100 mm. diameter.	0.0004 Bags	Each
d.	For 50 mm. diameter.	0.0004 Bags	Each
	Providing and fixing A.C. bends of required degree with access door insertion rubber washer 3 mm. thick, bolts and nuts or plain bend of heel rest unitary bend including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement : 2 Sand)		
e.	For 100 mm. diameter.	0.0020 Bags	Each
f.	For 50 mm. diameter.	0.0010 Bags	Each
	Providing and fixing double equal or unequal A.C. junctions of required degree plain or with access door, insertion, rubber washer 3 mm. thick bolts and nuts, including jointing with spun yarn cement mortar 1:2 (1 Cement : 2 Sand) complete.		
g.	100 x 100 x 100 x 100 mm. double equal junctions or 100 x 100 x 50 x 50 mm. double unequal junctions.	0.004 Bags	Each
h.	50 x 50 x 50 50 mm. double equal junctions.	0.002 Bags	Each
	Providing and fixing single equal or unequal A.C. junctions of required degree plain or with access door, insertion, rubber washer 3 mm. thick bolts and nuts, including jointing with spun yarn cement mortar 1:2 (1 Cement : 2 Sand) complete.		
i.	100 x 100 x 100 x 100 mm. single equal junctions or 100 x 100 x 50 x 50 mm. single unequal junctions.	0.0030 Bags	Each

Signature of Contractor with Seal

j.	50 x 50 x 50 50 mm. single equal junctions.	0.0016 Bags	Each
	Providing and fixing plain A.C. invert branch of required degree including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement : 2 sand).		
l.	50 x 50 x 50 x 50 mm.	0.002 Bags	Each
m.	50 x 50 x 50 x 50 mm.	0.0016 Bags	Each
	Providing and fixing A.C. offset including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement : 2 Sand)		
n.	100 mm. dia. A.C. offset with any projection.	0.002 Bags	Each
o.	50 mm. dia. A.C. offset with any projection.	0.0010 Bags	Each
	Providing and fixing A.C. loose socket including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement : 2 Sand) complete.		
p.	100 mm.	0.002 Bags	Each
q.	50 mm.	0.0010 Bags	Each
	Providing and fixing A.C. Terminal guard including jointing with spun yarn soaked in bitumen and cement mortar 1:2 (1 Cement : 2 Sand).		
r.	100 mm.	0.002 Bags	Each
s.	50 mm.	0.0010 Bags	Each
t.	Cutting chase in brick masonry walls for fixing 100 mm diameter sand cast iron pipes and making good the same with brick work in cement mortar 1:3 (1 Cement : 3 Sand)	10.00 Bags	100 Metre
u	Cutting chase in brick masonry walls for fixing 50 mm. diameter sand cast iron pipes and making good the same with the brick work in cement mortar 1:3 (1 Cement : 3 Sand).	6.66 Bags	100 Metre
8.	Drainage		
	Jointing glazed stone ware pipes grade "A" with stiff mixture of cement mortar in the proportion of 1:1 (1 Cement : 1 Sand)		
a.	100 mm. dia.	4.34 Bags	100 Metre
b.	150 mm. dia.	6.46 Bags	100 Metre
c.	200 mm. dia.	8.66 Bags	100 Metre
d.	230 mm. dia.	9.74 Bags	100 Metre
e.	250 mm. dia.	10.80 Bags	100 Metre
f.	300 mm. dia.	12.94 Bags	100 Metre
g.	450 mm. dia.	19.54 Bags	100 Metre

Signature of Contractor with Seal

	Laying cement concrete 1:5:10 (1 Cement : 5 Sand : 10 Graded Stone Aggregate 40 mm. nominal size) around S.W. pipe including bed concrete 15 cm. thick.:		
h.	100 mm. dia. S.W. Pipe.	47.32 Bags	100 Metre
i.	150 mm. dia. S.W. Pipe.	50.70 Bags	100 Metre
j.	200 mm. dia. S.W. Pipe.	58.24 Bags	100 Metre
k.	230 mm. dia. S.W. Pipe.	62.92 Bags	100 Metre
l.	250 mm. dia. S.W. Pipe.	66.04 Bags	100 Metre
m.	300 mm. dia. S.W. Pipe.	73.58 Bags	100 Metre
n.	350 mm. dia. S.W. Pipe.	81.12 Bags	100 Metre
o.	400 mm. dia. S.W. Pipe.	88.40 Bags	100 Metre
p.	450 mm. dia. S.W. Pipe.	96.20 Bags	100 Metre
	Laying cement concrete 1:5:10 (1 Cement : 5 Sand : 10 Graded Stone Aggregate 40 mm. nominal size) upto haunches of S.W. pipe including bed concrete 15 cm. thick.:		
q.	100 mm. dia. S.W. Pipe.	31.72 Bags	100 Metre
r.	150 mm. dia. S.W. Pipe.	34.84 Bags	100 Metre
s.	200 mm. dia. S.W. Pipe.	40.56 Bags	100 Metre
t.	230 mm. dia. S.W. Pipe.	44.20 Bags	100 Metre
u.	250 mm. dia. S.W. Pipe.	46.54 Bags	100 Metre
v.	300 mm. dia. S.W. Pipe.	52.26 Bags	100 Metre
w.	350 mm. dia. S.W. Pipe.	58.24 Bags	100 Metre
x.	400 mm. dia. S.W. Pipe.	62.96 Bags	100 Metre
y.	450 mm. dia. S.W. Pipe.	69.94 Bags	100 Metre
z.	Laying light duty non-pressure NP2 or P1 class R.C.C. pipes with collars jointed with stiff mixture of cement mixture of cement mortar in the proportion of 1:2 (1 Cement : 2 Sand) including joints etc.		
Z1.	100 mm. dia. R.C.C. pipe (NP2) or (P1)	1.00 Bags	100 Metre
Z2.	150 mm. dia. R.C.C. pipe (NP2) or (P1)	1.20 Bags	100 Metre
Z3.	250 mm. dia. R.C.C. pipe (NP2) or (P1)	1.80 Bags	100 Metre
Z4.	300 mm. dia. R.C.C. pipe (NP2) or (P1)	2.20 Bags	100 Metre
Z5.	450 mm. dia. R.C.C. pipe (NP2) or (P1)	4.80 Bags	100 Metre
Z6.	500 mm. dia. R.C.C. pipe (NP2) or (P1)	5.20 Bags	100 Metre
Z7.	600 mm. dia. R.C.C. pipe (NP2) or (P1)	6.40 Bags	100 Metre
Z8.	700 mm. dia. R.C.C. pipe (NP2) or (P1)	7.40 Bags	100 Metre

Signature of Contractor with Seal

Z9.	800 mm. dia. R.C.C. pipe (NP2) or (P1)	8.40 Bags	100 Metre
Z10	900 mm. dia. R.C.C. pipe (NP2) or (P1)	9.80 Bags	100 Metre
Z11	1000 mm. dia. R.C.C. pipe (NP2) or (P1)	11.00 Bags	100 Metre

Signature of Contractor with Seal

TECHNICAL SPECIFICATIONS

1. GENERAL

This specification is for work to be done, item to be supplied and materials to be used in the works as shown and defined on the drawings and described herein, all under the supervision and to the satisfaction of the Competent Authority.

Competent authority means Architects / Engineer in charge.

- 1.1 The workmanship is to be the best and of high standard, use must be made of special trades men in all respects of the work and allowances must be made in the rates for doing so.
- 1.2 The materials and items to be provided by the contractor shall be approved by the Competent Authority in accordance with any samples which will be submitted for approval by Contractor and generally in accordance with the Specifications Also if products are specified in the catalogue reference, the contractor will be required to obtain the approval of the Competent Authority before using a material. The Contractor shall produce all invoices, vouchers or receipts for any material if called upon to do so by the Competent Authority.
- 1.3 Samples of all materials are to be submitted to the Competent Authority for approval before the Contractor orders or delivers the materials at site. Samples together with their packing are to be provided free of charge by the Contractor and should any materials be rejected, they will be removed from the site at the Contractor's expense. All samples will be retained by the Competent Authority for comparison with materials, which will be delivered at the site. Also, the Contractor will be required to submit specimen finishes of colours, fabrics etc. for the approval of the Competent Authority before proceeding with the work.
- 1.4 The contractor shall be responsible for providing and maintaining and boxing or other temporary coverage required for the protection of dresses or finished work if left unprotected. He is also to clean out all shelving's, out ends and other waste from all parts of the works before coverings or in-fillings are constructed.
- 1.5 Templates, boxes and moulds shall be accurately set out and rigidly constructed so as to remain accurate during they are in use.
- 1.6 All unexposed surface of timber e. g. false ceiling, backing fillets, backs of door frames, cupboard framing, grounds, etc. are to be treated with two coats of approved timber preservative before fixing or converging.
- 1.7 Only first class workmanship will be accepted. Contractor shall maintain uniform quality and consistency in workmanship throughout.

Signature of Contractor with Seal

2. SCOPE OF WORK AND SPECIFICATIONS

- 2.1 To design & select the suitable cooling tower for existing 300 TR chillers-3nos. & 80TR chiller-1no. installed at SBI premises. The new cooling tower will be installed at Ground floor, available floor space 18 Meters x 6 meters. (Between ventilation shaft and ramp going to basement).
- 2.2 Dismantling, Removing, shifting DG set cooling tower-2nos. from Terrace level & Re-installation, Testing & commissioning of same cooling tower at location of ground floor near new cooling towers by making provision of foundation by means of MS structure.
- 2.3 Supply, Installation, Testing & Commissioning of new cooling tower along with new MS piping, valves, drain arrangement, Make-up water arrangement, cabling & control panels etc. (From ground floor to chiller plant room at basement) by making provision of foundation by means of MS Structure and necessary licensing for taking approval from MMRDA, Fire dept. or any other competent authorities.
- 2.4 Making provision of new cooling tower pipe connection with existing cooling tower (condenser water) headers by means of gas cutting & welding joints. By draining water from the line & then refilling of the same after completion of work by duly air purging.
- 2.5 After successful testing & commissioning of new cooling tower, Termination of existing cooling tower connections, dismantling, cutting & shifting all cooling tower parts, pipes & piping items from terrace level to ground floor at designated place and to be carted out after duly taking permission from MCGM.
- 2.6 Buyback amount includes dismantling, shifting, loading, unloading, cutting etc. without damaging existing structures in the terrace / passage.

Signature of Contractor with Seal

3 DESIGN SPECIFICATIONS FOR COOLING TOWERS:

Sr. No.	DESCRIPTION	DATA
1	Make	ADVANCE / HIMGIRI / HARRISON
2	Type of Cooling Tower	Induced Draft Counter Flow
3	Air Inlet Temperature (Dry Bulb)	31.6 Deg. C
4	Air Inlet Temperature (Wet Bulb)	28.3 Deg. C
5	Water Inlet Temperature	36.0 Deg. C
6	Water Outlet Temperature	31.0 Deg. C
7	No. of Cells	4 cells
8	Water Flow Rate - Per cell	183.75 CMH
9	Water Flow Rate - 4 cells	735.00 CMH
10	Type of Fill	VIRGIN C-10-12
11	Fan Diameter	2000 mm
12	No. of Blades	3 nos.
13	Fan Motor	9.3 Kw
14	No. of Fan	4 nos. (per cell each)
15	Fan RPM	560 rpm
16	Inlet / Outlet Size	250 NB
17	Overflow / Drain Size	80 NB
18	Float Valve Size	40 NB
19	Quick Fill Size	40 NB
20	Pumping Head	5 Mtr
21	Total Cooling Capacity Required - per cell	918750 Kcal / Hr. (303 TR)
22	Total Cooling Capacity Required - 4 cells	3675000 Kcal / Hr. (1215 TR)
23	Air Volume	119500 CuM / Hr.

4 CONSTRUCTION SPECIFICATION OF COOLING TOWER: - BASIN & CASING-

The Basin and casing shall be supported by heavy gauge C Rolled section hot-dip galvanized steel for long life and durability.

Standard accessories shall include overflow, drain and brass make-up valve with plastic float.

The Casing and Basin shall be made from FRP with both sides Gel coated for smoothness from inside and pigmented from outside.

AXIAL FANS

Fans shall be heavy duty Axial type statically balanced. The fans constructed of hollow FRP / extruded aluminum alloy blades, installed in a closely fitted cowl with venturi air inlet. Fan screens shall be galvanized steel mesh and frame, bolted to the fan cowl. Fans should be statistically & dynamically balanced.

Signature of Contractor with Seal

FAN MOTOR

Suitable capacity totally enclosed fan-cooled fan motor(s), with 1.1 service factor will be furnished suitable for outdoor service on 415 volts, 50 hertz, and 3 phase AC supply. The Fan Motor shall be high efficiency EFF1 4 pole, and shall be mounted out of moist Air stream.

DRIVE

The fan shall be mounted below the Fan bearing on a shaft, driven by a belt. The drive arrangement shall have FRP cover for protection.

PVC FILLS

The Cooling Tower Fill shall be of virgin PVC (polyvinyl chloride) of Munters make, of cross-fluted design for optimum heat transfer and efficiency. The cross fluted sheets shall be bonded together and the edges double folded for strength and durability. The PVC fill shall be resistant to rot, decay, or biological attack.

WATER DISTRIBUTION SYSTEM

The spray header and branches shall be constructed of Heavy duty, polyvinyl chloride pipe for corrosion resistance and shall have a steel connection to attach the external piping. The piping shall be removable for cleaning purposes. The water shall be distributed over the fill by precision molded ABS spray nozzles with large orifice openings to eliminate clogging.

DRIFT ELIMINATORS

The eliminators shall be constructed entirely of inert polyvinyl chloride (PVC) in easily handled sections. The eliminator design shall incorporate two changes in air direction to assure complete removal of all entrained moisture from the discharge air stream. Maximum drift rate shall be less than 0.005% of the circulating water rate.

LOUVERS

The louvers shall be constructed from FRP. The louvers shall be mounted in easily removable frames for access to the Basin for maintenance. The louvers shall be suitable angled and spaced to prevent splash out and block direct sunlight.

FINISH

All Basin and casing materials will be 2 side finished in standard colour with NPG, u. v. stabilizer gel coat.

ACCESS LADDER

For sizes greater than 2.4 M wide a GI Ladder of formed / Rolled channels shall be provided with platform for easy access to Motor.

5 CONSTRUCTION SPECIFICATION OF MS PIPING & ACCESSORIES:

MS Pipes

All pipes should be supply as per IS 1239 (upto 6") & IS 3589 (8" & above), Plain end, ERW type, Heavy, C class, as per approved make list.

Signature of Contractor with Seal

Butterfly valve

All Butterfly valves should be supply as per IS 13095, CI body, PN 10 rating, Leaver operated-upto 6” & Gearbox operated-8” & above, as per approved make list.

Strainers

Pot type Strainer should be used on main header of cooling tower. It should be flange connection, fabricated in MS body with SS mesh.

Balancing Valve

Manual controlling balancing valve with flange end valve should be used. CI body, PN 10 rating.

Structural Steel for pipe support

MS Angle, I beam, C channel should be used for pipe supports.

Primer & Painting

One coat of Red oxide should be applied on MS pipe/ st. steel surface & one coat of synthetic enamel paint should apply on primer coat.

Pipe Fittings

All pipe fittings like Elbow, T-Joints, Flanges should be heavy grade suitable to class 150.

Equalizer Line

Its should be with isolating gate valves.

5.1 MS Piping Make List:

Sr. No.	Item Description	Make
1	Cooling Tower	Advance / Paharpur / Equivalent
2	MS Pipes	Jindal / Tata
3	Butterfly valve	Honywell / Advance / L&T / C&R
4	Ball Valve	Zoloto / Honywell / Leader / Equivalent
5	Strainer	Trishul / Sant / Equivalent
6	Balancing Valve	Castle / Advance / Equivalent
7	Structural Steel	SAIL / ISI mark
8	Paint Primer	Asian / Burger / Shalimar
9	Cable	Polycab / ISI mark

6 MS Structure for cooling tower foundation**Scope:**

Preparation of detail fabrication drawing and review by approved Consultant, supply (AS APPLICABLE), Erection of structural steel works including the receiving the fabricated material at Project site, all field connections, bolting wherever applicable and welding and fixtures wherever necessary as shown on drawings and as directed by the engineer, labour and material, for all heights as per the drawings issued from time to time at the time of execution.

Signature of Contractor with Seal

Supply, Erection of chequered plate, handrail and grating including the receiving material at Project site all field connection, bolting, welding and fixtures wherever necessary as per specifications and as shown on drawings and as directed by the engineer, labour and material, for all heights as per the drawings.

Supply and application of 2 coats of synthetic enamel paint of Berger or equivalent make, approved colour over primer coat at all heights and levels for all steel structures including chequered plates and gratings.

6.1 MS Structure material specification

Fabrication shall be done out of Mild Steel conforming to IS:2062 GRADE 'A' for steel materials,

Items out of Channels/Angles

100x50mm ISMC Channel

50x50x6 mm Angle

75x40 mm ISMC Channels

7 DESIGN BASIS

LOCATION: State Bank Of India, LHO Building at C-6, Block G, Bandra Kurla Complex, Bandra (E), Mumbai 400 051

QUALITY & MAKE: As per Technical Specification given in list as above attached.

DRAWINGS & DOCUMENTS

Along with the Technical Bid /Quotation, the Bidder shall submit 2 sets of the following documents for approval & records:

- a. Technical data sheet duly filled in, as per format given in this tender.
- b. General & Commercial condition duly filled in as per the format given in this tender.
- c. Extra optional items.
- d. Catalogue of Materials / Items.

TRAINING

The supplier has to ensure that proper training should be provided to the staff and officials of the SBI for smooth use of the machineries and its maintenance.

The work order will be awarded to successful bidder, whose tender has been determined to be substantially responsive provided further that the bidder is determined to be qualified to perform the contract satisfactorily on comprehensive basis.

Delivery of Goods and performance of the services shall be made by the supplier in accordance with the time schedule specified by SBI.

Signature of Contractor with Seal