

ANNEXURE A

CORRIGENDUM TO TENDERS OF ROOF TOP SOLAR PANEL INSTALLATION AT STATE BANK BHAVAN BUILDING, THRISSUR, IRINJALAKKUDA BRANCH AND PBB ROUND SOUTH BRANCH, THRISSUR WITH TENDER IDS THI202006015, THI202006014, THI202006013

The pre-bid meeting related to the tenders of Roof Top Solar Panel Installation at State Bank Bhavan Building - Thrissur, Irinjalakkuda branch and PBB Round South Branch - Thrissur with Tender IDs THI202006015, THI202006014 and THI202006013 was fixed at 3.00 pm in Administrative Office, State Bank Bhavan Building, Thrissur on 15.06.2020. But the meeting could not be conducted on the specified time and date at Administrative Office, State Bank Bhavan as the office was in containment area as declared by State Government due to COVID 19 Pandemic and there was travel and entry restrictions in the area. Hence, the vendors who had contacted the office were instructed to convey their queries via email. The details of the queries and our clarifications are as given below:

Sl No	Queries	Clarifications
1	Amount of statutory bills paid to KSEB and Inspectorate for Grid connections to be included in tender amount or not? Will it be paid separately on the production of bills?	As indicated in the tender terms and conditions, Statutory payments for inspection fees, Security deposit will only be paid by the Bank upon production of fees receipt or challan from the department concerned. Applicant has to quote the rates including Liaisoning charges with all statutory bodies, documentation charges etc for obtaining approval for Grid integration"
2	If Reverse protection relay is not existing with the generator, That has to be installed, which is not part of solar.. The amount is to be included in tender amount or will it be paid separately on the production of bills?	The reverse Protection relay, if not present in the existing D G Set panel, the same has to be supplied and installed by the vendor after submission of separate quotation by the L1 vendor and after the approval of the cost by SBIIMS. Payment shall be released against production of original GST bill.
3	We assume that the KSEB will give technical feasibility for grid connection as per the transformer capacity. If KSEB does not give feasibility with regards to transformer capacity, SBI has to take up with KSEB to get feasibility.. It is understood that in normal case the vendor has to do the necessary liaisoning activities for connecting to Grid.	As indicated in the tender terms and conditions, the vendor has to do the necessary liaisoning activities with KSEB and Electrical Inspectorate for getting feasibility certificate and commissioning of the project.
4	L1 may be decided on totalling of (i) and (iii) mentioned in price bid format, i.e the basic value(excluding GST)of Design, supply, installation, testing and commissioning (i) and basic Charges (excluding GST) for 5 years warranty guarantee, operation and maintenance (iii) . Or If L1 has to be decided on the basis of Grand total of basic value and GST, then please mention the applicable percentage of GST for two elements (i) and (iii) Design, supply, installation, testing and commissioning (i) and Charges for 5 years warranty guarantee, operation and maintenance (iii) so that all participants are applying the same percentage GST in (ii) and (iv) of price bid. and there is no confusion in total amount for deciding L1.	It is already mentioned in the tender that "L1 is arrived based on the Grand total inclusive of GST. Applicant has to quote the rates based on their design, transportation charges (loading and unloading), all taxes, GST based on their supply and labour components, installation, commissioning charges, Liaisoning charges with all statutory bodies, documentation charges etc for obtaining approval for Grid integration". Vendors have to quote the GST component based on their supply and labour components, installation, commissioning charges, Liaisoning charges with all statutory bodies, documentation charges etc and hence the GST and respective percentage of the same is to be specified by the vendors in the tender.
5	Due to the present COVID-19 situation is there any provision to submit the technical bid at Thrissur AO	There is no provision to submit the technical bid at Thrissur AO office. The tenders are to be submitted by all the vendors

	office. It will be a great help.	to the address specified in the tender document
6	6. In normal cases DD s are issued by the banks for three months validity, So 180 days validity will not be there for the first DD of EMD. We hope later if required, it can be validated to 180 days.	EMD DD s can be submitted with their normal validity provided by the Banks.
7	Please consider the above points, give clarification and upload the required amendments as a corrigendum to the tender.	Queries considered, clarification given and corrigendum issued

ASSISTANT GENERAL MANAGER
SBIIMS, THIRUVANANTHAPURAM

NAME, SEAL AND SIGNATURE OF VENDOR