

SBI INFRA MANAGEMENT SOLUTIONS PVT LTD (SBIIMS)
(WHOLLY OWNED SUBSIDIARY OF SBI)
CIRCLE OFFICE, PATNA
SCHEDULE OF WORKS: ELECTRICAL WORKS
PROJECT: RACC (FIMM) BHAGALPUR

SI No.	Item Description	Unit	Qty.	Rate(Rs)	Amount(Rs)
1	Supplying, laying, testing & commissioning of PVC insulated aluminium armoured 1.1 KV grade 3.5 core 50 sqmm cable from Pole to Main panel to ACDB with making proper trench/support as per IS specification and complete with all respect as per the instruction of Engineer-In-Charge.	Mtr.	40		
2	(A) MAIN INCOMING SOURCE PANEL (MISP) : SITC of main incoming (MIP) Panel suitable for wall /floor mounted indoor type, air insulated, totally enclosed vermin-proof (IP 42), dead front, cubicle type, 2 mm thick sheet steel enclosure use on 415 V, 3 Ph., 4 wire, 50 Hz. A.C. system, instrumental panel, CTs, incoming and outgoing cable compartmen. The Panel shall be complete with switches as per site requirement, inter connection, G.I. earth busbar of adequate size covering the total length of switch board with drilled holes, G.I. bolts, nuts, washers etc. as directed by E-I-C. The cubicle should be painted with two coats of light grey synthetic enamel paint over two coats of zinc chromate primer. The complete fabrication, construction shall be done as per the site condition and conforming to the relevant IS. Name plate of Panels Danger Board, incoming and outgoing feeders with Ampere rating of switches are to be fixed up on front door above or below the respective switches. Approval of Manufacturer's drawings from EIC. The Panel consists of the following				
	INCOMING : 1 No. 415V, 125A 4P MCCB (35 KA); 1 No. : Digital Multi Function Meter (MFM) for Current, Voltage, Frequency, Power; 3 Nos.: LED Phase indicating lamps; 3 Nos.: Suitable CTS PVC sleeved TPN Tinned Copper Busbar 200 Amp. for phases and neutral; G.I. EARTH BUSBAR 25mm x 3mm covering the total length of panel.				
	OUTGOING : Termination I: (i) 3 Nos. 63 A (10KA) DP MCB (ii) 6 Nos. 32A (10 KA) DP MCB Termination II: (i) 2 Nos. 63 A (25KA) 4P MCCB (For ACDB)	No.	1		
3	(A) UPS INCOMING DB: Supply of all required materials and fixing of input UPS box (Company made Double Door) having provision of the following arrangement complete with all respects per the direction of engineer in charge. Incoming: 1 No. 40A (10KA) DP MCB Outgoing: 2 No. 32A (10KA) DP MCB	No.	1		

	<p>(B) UPS OUTGOING DB: Supply of all required materials and fixing of output UPS box (Company made Double Door) having provision of the following arrangement complete with all respects per the direction of engineer in charge.</p> <p>Incoming: 1 no. 40 A DP MCB</p> <p>Outgoing: 3 No. 32A (10KA) DP MCB</p>	No.	1		
4	<p>DISTRUBUTION BOD: Supply and installation of following metallic double door MCB Distribution Board with MCB having breaking capacity of 10 KA (minimum) complete with busbar, interconnection, painting, mounted on flat iron frame on wall/flushed with finished wall by chase cutting, mending good to original finish painting etc. as required. Name plate & number of DBs are to be fixed up on front door of DBs for their identification.</p>				
a	<p>ACDB : Consumer unit TPN MCB DB (Double Door) complete with busbar and the following MCBs.</p> <p>INCOMING : 1 No. 415V 63A 10KA TPN MCB</p> <p>OUTGOING : 12 Nos. 240V 32A 10 KA SP MCB</p>	No.	1		
b	<p>LDB : Consumer unit SPN MCB DB (Double Door) complete with busbar and the following MCBs.</p> <p>INCOMING : 1 No. 415V 32A 10KA MCB</p> <p>OUTGOING : 8 Nos. 240V 16A 10 KA SP MCB</p>	No.	2		
c	<p>CDB : Consumer unit SPN MCB DB (Double Door) complete with busbar and the following MCBs.</p> <p>INCOMING : 1 No. 415V 32A 10KA DP MCB</p> <p>OUTGOING : 8 Nos. 240V 10A 10 KA SP MCB</p>	No.	2		
d	<p>RPDB: Consumer unit SPN MCB DB (Double Door) complete with busbar and the following MCBs.</p> <p>INCOMING : 1 No. 415V 32A 10KA DP MCB</p> <p>OUTGOING : 8 Nos. 240V 16A 10 KA SP MCB</p>	No.	1		
5	<p>SUBMAIN WIRING Supply & laying of submain wiring with following sizes 1100 V grade, single core, PVC insulated multi stranded copper conductor wire (IS:694) in pre - laid (as per ISI) M.S. conduit including interconnection, painting etc. as required to be completed in all respect.</p>				
a	With 4 nos. 10 Sq.mm + 1 nos. 2.5 Sq.mm. PVC insulated copper wire from Main panel to ACDB.	Mtr.	40		
b	With 4 nos. 6 Sq.mm + 1 no. 2.5 Sq.mm. PVC insulated copper wire from Main Panel to LDB, UPS O/G DB/CDB/LDB to RPDB.	Mtr.	100		
c	With 2 Nos. 4 Sq.mm. + 1 No. 2.5 Sq.mm. PVC insulated copper wire from Main panel to ACDB to AC power point.	Mtr.	120		
e	With 2 Nos. 2.5 Sq.mm. + 1 x 1.5 Sq.mm. PVC insulated copper wire as required.	Mtr.	50		

6	(A) COMPUTER SOCKET OUTLET Computer socket outlet cluster point including supply and fixing of modular type socket outlet clusters components complete in all respect as detailed below. Each computer socket outlet cluster comprising the following 4 Nos. 6/10A 5 pin modular type approved sockets 1 No. 16A modular type common controlling switch with indicator on table top with 2 Nos. 2.5 Sq.mm. + 1 x 1.5 Sq.mm. PVC insulated copper wire in pre - laid (as per ISI) M.S. conduit including interconnection, painting etc. as required to be completed in all respect from CDB to Computer point.	No.	15		
	(B) RAW POWER SOCKET OUTLET Raw power socket outlet cluster point including supply and fixing of modular type socket outlet clusters components complete in all respect as detailed below. Each computer socket outlet cluster comprising the following 2 Nos. 16/20A 5 pin modular type International sockets. 1 No. 16/20A modular type controlling switch with 2 Nos. 2.5 Sq.mm. + 1 x 1.5 Sq.mm. PVC insulated copper wire in pre - laid (as per ISI) M.S. conduit including interconnection, painting etc. as required to be completed in all respect from RPDB to Raw Power Outlet.	No.	10		
7	Supply & fixing of Company made approved make modular type AC socket & Top OR Metal Clad Socket with 32/25A SP MCB.	No.	6		
8	Supply & installation of Company made 160 A 50 KA FP MCCB with enclosure to be fixed near Main Gate for Switching ON& OFF / controlling Lighting.	No.	1		
9	Chemical Earthing: Supply of material and installation of earth electrode made out of 50mm dia class B G.I. pipe in pipe of 3 metre long with arrangements for fitting / termination of G.I. flat with G.I. nut bolts and washers including cost of backfill compound and good quality soil, water puring arrangements, brick masonry enclosure on top with removable CI over complete with labour for excavation of pit conforming to IS: 3043/1987.	No.	1		
10	Supply of materials, laying under ground/walls/floor, making end termination and testing of 2x6 mm multistrand copper wire to be inside PVC . Conduit cables laid from earth pit to UPS Outgoing DB and complete.	Mtr.	100		
11	Supply of materials, laying under ground/walls/floor making end termination and testing of G.I. flat (25x3mm) laid from earth pit to Main panel as required.	Mtr.	100		

12	POINT WIRING: Point wiring with 1100 V grade 3 nos. single core 1.5 sq.mm. and 1 for earth PVC insulated stranded copper conductor wire (IS:694) through suitable size M.S. conduit (ISI marked) by thred cutting, complete with junction box, circular box, elbows, bends, couplers and other accessories on surface above false ceiling or concealed by chase cutting on wall from light & fan switch board to light, fan & 6A socket outlet on the same switch board or separately mounted switch board. The work includes supply and fixing of all materials such as modular type 6A switch for light and fan point, 6A 2/3 pin shuttered socket outlet with switch in each switch board, 3 plate ceiling rose / angle or batten holder etc. as required. The point wiring also includes circuit wiring with 1100 V grade 2 nos. single core 2.5 sq.mm. + 1 no. single core 1.5 sq.mm. PVC insulated stranded copper conductor cable (IS:694) through suitable size M.S. conduit as described above from DB to switch board, interconnection, mending good all damages to original finish, painting etc.				
A	1 Light control by 1 switch	Nos.	45		
B	Wall Fan point wiring with 2 Pin socket	No.	15		
C	Exhaust fan point	Nos.	2		
D	Ceiling fan point with supply and fixing of Electronic Regulator (2 module step, 120 watt rating)	Nos.	2		
E	1x16A 2/3 pin modular socket with switch on separate switch board outside the Cash Room and Locker Room complete with wiring. Suitable Top to be provided for supply to Record Room / Stationary Room.	Nos.	1		
F	3 pin 6/10A modular socket with switch in each board	Nos.	5		
13	Supply & Fixing of 36W-2'x2' LED Panel light recessed mounted of Phillips / Wipro / CG / HPL / Mescab / Century / Halonix /IB make of lumens >3000 complete with all accessories.	Nos.	24		
14	Supply & Fixing of 15W LED Downlighter recessed mounted of Phillips / Wipro / CG / HPL / Mescab / Century / Halonix / IB make complete with all accessories.	Nos.	15		
16	Supply & fixing of 18W LED T5 Batten fitting Phillips / Wipro / CG / HPL / Halonix complete with all respect.	Nos.	5		
17	Supply & fixing of wall fan complete with all respect. (Make: Polar, Orient, CG, Havells, Usha,)	Nos.	15		
18	Supply & fixing of Ceiling fan complete with all respect. (Make: Polar, Orient, CG, Havells, Usha,)	Nos.	2		
19	Supply & fixing of Exhaust fan complete with all respect. (Make: Polar, Orient, CG, Havells, Usha,)	Nos.	2		
20	Supply & Installation of 24 Port Switch. (Make: D-Link, DIGISOL	Nos.	1		
21	Suppy & Installation of 9U Rack. (Make: Valrack)	No.	1		
22	Supply and laying of E-CAT 6 UTP cable for the Data Circuit through the PVC conduit, Rate to include for termination on both end or as directed by E-I-C. (MAKE- D-LINK, AMP, HCL, DIGISOL)	Mtr.	600		

23	Supply and fixing of information outlet box suitable for 1 nos. RJ 45 terminals including mounting box (PVC) & top cover, to be fixed a concealed manner in partition by necessary bolts & nuts or as directed at site. (MAKE- D-LINK, AMP, HCL, Legrand, DIGISOL)	Nos.	15		
24	Supply of 2 mtr. Long E-CAT 6 PATCH CHORD (Make: D-LINK, AMP, HCL, Legrand, DIGISOL)	Nos.	15		
25	Supply and laying of 4 core telephone cable for Intercom through the PVC conduit, Rate to include for termination on both end or as directed by E-I-C.	Mtr.	200		
26	Supply and fixing of Telephone outlet box suitable for 1 nos. RJ- 11 terminals including mounting box (PVC) & top cover, to be fixed a concealed manner in partition by necessary bolts & nuts or as directed at site.	Mtr.	10		
27	Supply & Fixing of 20 pair Tagbox for Intercom termination	No.	1		
28	Removing of old unnecessary switchgears, cables, wires, conduit pipe etc. from the existing wiring, Redressing of existing cables & wires as required and advised by EIC / Bank.	Lumsum			
		Total			
	# GST EXTRA AS APPLICABLE				