

CORRIGENDUM-1

Notice Inviting Tenders No. P&E/001 DATED 19/05/2020

Tender For Supply of UPS & Batteries to State Bank of India - FI & MM – RBO/DSH/RACC

It is been decided modify the battery bank capacity and UPS warranty period in the technical specification of UPS

1. Technical Specification clause No. 27. (D) & (E) is changed as below.

Battery bank for UPS capacity	Minimum VAH capacity of Battery Bank	Battery OEM Warranty	D.C. Terminal voltage	No of batteries in battery bank.	Ampere-Hour capacity of each battery	Make of Battery and model
5kVA	18000	4 years				
10kVA	38400	4 years				
15kVA	57600	4 years				
20kVA	76800	4 years				

(Above details shall be filled by bidder and submitted along with Technical bid)

2. UPS warranty shall be 2 years from the date of installation.

**STATE BANK OF INDIA
LOCAL HEAD OFFICE, PREMISES & ESTATE DEPARTMENT**

St. MARK'S ROAD BENGALURU
