



**SBI INFRA MANAGEMENT SOLUTIONS PVT LTD
(WHOLLY OWNED SUBSIDIARY OF SBI)**

INVITES TENDERS IN TWO BID SYSTEM THROUGH E-TENDERING

FOR

**AIRCONDITIONING WORK AT GROUND FLOOR OF LHO BUILDING,
THIRUVANANTHAPURAM**

NIT: THI202004001

**Corrigendum-I clarifications for queries raised by prospective bidders through email is
clarified in the Annexure -I**

Last date for submission of Tender extended upto : 03.00 P.M. (IST) on 20/05/2020

Opening of Tenders: 03:30 P.M. (IST) on 20/05/2020

M/s. ENARC CONSULTANTS

Architects & Engineers

M.G. Road, Thrissur-1

KERALA

Ph: 2441901 & 2441905

Fax: 91-487-2442011

(Name & Address of Contractors)

**The Assistant General Manager
SBI Infra Management Solutions Pvt. Ltd
4th Floor, SBI LHO Building
Poojappura
Thiruvananthapuram – 695012
Contact No: 0471-2192410/2192435
Mob:9497714782**

Annexure-I
Corrigendum for the following points are to be read as under:

Tender condition	Clarification sought	Clarifications from SBIIMS
Date of submission - 27.04.20 at 3.00 PM & Date of tender opening - 27.04.20 at 3.30PM	The last date of tender submission mentioned is 27.04.20. Due to the current restrictions imposed by the Government, it is difficult to complete the formalities by that time. Hence request your good offices to extend the last date of submission further upto 27.05.20, until all the restrictions are relaxed and closed down operations of OEM offices and factories resume their operations	Due to prevailing situation of Covid-19, Date of submission and opening is extended as under: Date of submission - 20.05.20 at 3.00 PM & Date of tender opening - 20.05.20 at 3.30PM
Rs. 23,000/- (Rupees Twenty Three Thousand Only) in the form of DD in favor of 'Assistant General Manager, P&E payable at Thiruvananthapuram.	Is there any EMD exemptions for MSME units like in central govt tenders for organizations like ISRO, NIIST etc	SBIIMS being pvt ltd company no EMD exemptions are granted
Item no A.2.h Supply of indoor units equipped with pre-filter, fan section with low noise fan, multi speed motor, coil section with DX coil, outer cabinet, drain pan and drain pump, corded remote, cabling, vibration isolation, earthing, necessary supports etc. as required along with keytag operation relay - 3Tr Floor Standing unit	Most of OEM does not have this model line up	Tower AC is selected for the specific requirement as per site conditions. The same cannot be altered at this stage as it affects Bank's requirement.

Asst. General Manager (SBIIMS)

