



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2024/B/4819024
Dated/दिनांक : 27-03-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	08-04-2024 13:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	08-04-2024 13:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Finance
Department Name/विभाग का नाम	Department Of Financial Services
Organisation Name/संगठन का नाम	State Bank Of India (sbi)
Office Name/कार्यालय का नाम	Local Head Office Mumbai Metro
Total Quantity/कुल मात्रा	1
Item Category/मद केटेगरी	Solar Power Plant (Roof Top) for ONGRID System, Three Phase (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	35 Lakh (s)
OEM Average Turnover (Last 3 Years)/मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)	100 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,OEM Authorization Certificate,OEM Annual Turnover,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No

Bid Details/बिड विवरण	
Type of Bid/बिड का प्रकार	Two Packet Bid
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	35000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	62

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

AGM

LOCAL HEAD OFFICE MUMBAI METRO, Department of Financial Services, State Bank of India (SBI), Ministry of Finance, Mumbai
(State Bank Of India)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता
--

Yes

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता

Yes

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

6. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid

in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Solar Power Plant (Roof Top) For ONGRID System, Three Phase (1 set)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
INVERTER	Rated out put power of inverter (Kw)	70
	Switching device	IGBT
	No. of Phase (in Nos.)	3
	Inverter output wave form	Pure sine wave
	No.of MPPT per inverter (in Nos.)	4
	No. of string at input side of inverter (input port +ve and -ve) (hint: 1 sets contains 1 +ve and 1 -ve port)	4 Set
	Maximum power point tracker	Integrated in the PCU/inverter to maximize energy drawn from the array
	Operating Voltage Range of Inverter	200 V to 1000 V
	Over load support at Input side, DC	10% overload DC Capacity
	Maximum input current for each MPPT (in A)	28.5
	Service condition	Outdoor
	Ingress protection rating of inverter	IP 65 (for outdoor use)
	Cooling medium for inverter	Intelligent fan cooling
	Manual switch for disconnecting DC supply	Yes
Inverter mounting type	Wall Mounted	
GENERIC	A Grid Tied Photo Voltaic (SPV) power plant consists of	SPV array, Module Mounting Structure, Power Conditioning Unit (PCU) consisting of Maximum Power Point Tracker (MPPT), Inverter, and Controls and Protections, interconnect cables and switches
	PV Array Mounting	Mounted on a suitable structure

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Grid tied SPV system is	Without battery and designed with necessary features to supplement the grid power during day time.
	Installation and testing for complete system	Yes including Civil Work, Designing, Fabrication, Cabling Work with suitable Bolts, Nuts, Clamps, Connectors and testing etc
INVERTER OUT PUT	Maximum current for 3 phase inverter (in A)	100
	Output voltage (in V)	415 for 3 phase
	Invert auto trip at output side	Lower : at 304 V, Higher : at 460 V with adjustable
	Frequency range	50 Hz +/-3
	Overall Efficiency (in %)	>98
	Efficiency Measurements for Power conditioners / Inverters	as per IEC 61683 / IS:61683
	PCU/inverter shall be capable of complete automatic operation for	wake-up, synchronization and shutdown.
PROTECTION FOR INVERTER	Overload protection	110% for 1 Minute
	Over temperature protection	Yes at 65 Deg. C Cooling Fan will auto switch ON
	Surge protection	Metal Oxide Varistor (MOV)
	Insulation Resistance Monitoring	Yes
	Grid Monitoring protection	Yes
	THD (in %)	<1.5%, < 3%
	Power factor at rated output power	> 0.9, 0.9
	Inverter body material	Aluminium Casting, M.S. Plate
SERVICE CONDITION	Operating temperature	-25 to +60 deg. C
DISPLAY FEATURES ON INVERTER	Type of display	LCD
	Display parameters	DC Voltage, DC Current, AC Voltage, AC Current, Output frequency, Power Factor
	Generating power Data storage facility	Yes for 2 Years from the date of commissioning
	Interface facility for transmitting the generating power data for cloud storage	Inbuilt Wifi Enabled
	Net meter	Approved by Government of India/State Government authority concerned for connecting to Grid

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Add on items - DC DISTRIBUTION BOARD	DC Distribution panel to receive the DC output from the array field	Yes with surge arrestors
	Ingress protection (Enclosure protection) of DC Distribution Box	IP65
	Material of bus bar and size	Copper, size as per inverter rating
	Circuit Breaker for input side (DC side) for each inverter	MCB 15 A
Add on items - CABLE FOR INPUT	ISI Marked Connecting cables according to Inverter rating for each system	PV Module to Inverter DC
	Electric Cable for Input	1C x 6 Sq. mm, Copper Cable (as per IS:694:2010 latest)
	Cable Length for PV Module to Inverter, DC (in m)	20
Add on items - AC DISTRIBUTION BOARD	AC Distribution Panel Board (DPB) for controlling the AC power from PCU/inverter	3 Phase 415 Volt +/- 10%, 50 HZ +/-3 Hz
	Panel construction	Metal clad, totally enclosed, floor mounted, air insulated, cubical type with change over switch
	Ingress protection (Enclosure protection) of AC Distribution Box	IP65 for outdoor
	All switches and the circuit breakers, connectors should conform to	IS:60947 part I, II and III.
	Panels designed for minimum expected ambient temperature	45 deg. C
	Circuit Breaker for output side (AC side) for each inverter	MCB 100 A
Add on items - CABLE FOR OUTPUT	ISI marked Connecting cables according to Inverter rating for each system	From Inverter to Net Meter and to mains at LT Bus bar while in grid tied mode
	Conformity of the specification for cable	3.5C x 35 Sq. mm, Copper Cable (as per IS:694:2010 latest)
	Cable length for output side (from inverter to Net Meter for each system) (in m)	30, 20
Other Add on Items	Cabling work at input side for each system	With PVC Conduit pipe with necessary clamps and screws
	Cabling work at Output side for each system	With G.I. Cable Tray with fitment accessories

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Earthing for each inverter	G.I. Pipe, G.I. Wires and earthing as per IS:3043-1987
	Danger boards and signages	3 No.
ARRAY STRUCTURE	Material of mounting structure for mounting the modules/ panels/arrays	Structural Steel, Grade: E300 (as per IS:2062:2011 latest)
JUNCTION BOX	Material of Junction Box	Powder Coated Aluminium
	Ingress protection (Degree of Protection) for Junction Box	IP65
Wind Load	The Mounting structure shall be so designed to withstand the speed for the wind zone of the location where a PV system is proposed to be installed	Yes
	Compliance to wind velocity test for the Mounting structure of PV System	as per IS 875:1987 part 3 latest
	Regional wind withstand capacity which the Mounting structure of PV system support is suitable to withstand (in Km/Hour)	180
WARRANTY & GUARANTEE	Minimum guarantee for maintaing of out put peak watt capacity	> / = 90% at the end of 10 years and >/= 80% at the end of 25 years
CERTIFICATIONS	Availability of type test reports for PCU/Inverter, PV Module to prove the conformity of the specification from	MNRE approved Lab

Additional Specification Parameters - Solar Power Plant (Roof Top) For ONGRID System, Three Phase (1 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service local Centre at Mumbai / Thane / Kalyan / Navi Mumbai should be available in the name of Bidder.	Proof should be attached.

Specification Parameter Name	Bid Requirement (Allowed Values)
Any third-party service will not be accepted.	Only OEM and its authorized dealers service will be accepted.
All parts replacements, breakdown call should be attended on site.	Response time in Mumbai should be <24hours Resolution time should be < 48 hours
Security Deposit	5% amount of supply and installation will be held till the warranty period (5 years).
Minimum Generation Guarantee	The tenderer has to guarantee a minimum energy generation of 4 KWH per KWp per day (1300KWH/KWp/Year) valid with respect to total plant capacity (considering the weather conditions) during the first five years of operation. Failing which, a penalty @ Rs.12/- per kWh shortfall per annum will be deducted from the Security Deposit (SD) up to the defects liability period

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ramkishan Kumar Sinha	400051, STATE BANK OF INDIA, SYNERGY, C-6, G BLOCK, BANDRA KURLA COMPLEX BANDRA EAST, MUMBAI 400051	1	45

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

- i) No advance payment shall be paid.
- ii) 60% of total project cost against all materials delivery at site and production of test certificates and with necessary documents showing requisite quality as mentioned in tender document.
- iii) 35% after installation, commissioning, testing, successful trail run.

iv) 5% will be held with us as SD for 5 yrs and could be release against submission of Performance Bank Guarantee from any scheduled/ commercial Bank, other than SBI

v) Minimum Generation Guarantee:

The tenderer has to guarantee a minimum energy generation of 4 KWH per KW p per day (1300KWH/KWp/Year) valid with respect to total plant capacity (considering the weather conditions) during the first five years of operation at Bank's power grid synchronization point. Failing which, a penalty @ Rs.12/- per kWh shortfall per annum will be deducted from the Security Deposit (SD) up to the defects liability period.

vi) The 70KwP Solar Panel is Off grid system, No NET METERING is required.

vii) the solar panel has to be directly connected to the electrical panel.

3. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Plot No. C-6, Synergy Building
G- block, Bandra Kurla Complex
Bandra East, Mumbai
Pin: 400051
mob: 9158002461 / 8008496539

4. **Generic**

Bidders shall quote only those products (Part of Service delivery) in the bid which are not obsolete in the market and has at least 7 years residual market life i.e. the offered product shall not be declared end-of-life by the OEM before this period.

5. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

6. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

7. **Generic**

IT equipment shall be IPv6 ready from day one.

8. **Generic**

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

9. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

10. **Turnover**

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

11. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

12. **Service & Support**

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

13. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

14. **Service & Support**

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

15. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

16. **Certificates**

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

17. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

18. **Warranty**

Warranty period of the supplied products shall be 5 years from the date of final acceptance of goods or

after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

19. **Warranty**

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

20. **Past Project Experience**

The Bidder / OEM {themselves or through reseller(s)}, should have executed project for supply and installation / commissioning of same or similar Category Products during preceding 3 financial years (i.e. current year and three previous financial years) as on opening of bid, as per following criteria:

- (i) Single order of at least 35% of estimated bid value; or
- (ii) Two orders of at least 20% each of estimated bid value; or
- (iii) Three orders of at least 15% each of estimated bid value.

Satisfactory Performance certificate issued by respective Buyer Organization for the above Orders should be uploaded with bid. In case of bunch bids, the Category related to primary product having highest bid value should meet this criterion

21. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

state Bank of India
payable at
Mumbai

. Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

22. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

state Bank of India
payable at
mumbai

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.

3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---