

ALTERNATE PREMISES OF DIRANG BRANCH
BOQ for Electrical Installation Works

Sl.No	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
1	<p>a. Main Panel :- Supplying, Installing, testing and commissioning of factory fabricated 2MM thick CRCA, floor mounted cubicle type distribution Panel Board with 150 MM X 75 MM X 6MM ISMC base channel, suitable for 415 V TPN comprising of 300A suitable copper double bus bars with color coded heat shrink insulation with the followings: 200 A, 4P MCCB, 35 kA with overvoltage protection as incomer, R-Y-B LED indicating lamps, Digital multifunction meter of minimum size 150 MM X 150 MM to measure Voltage, Current, PF etc with all accessories. Outgoing:100 A 4P MCCB, 35kA for Power -1 Nos, 100 Amp TPN MCCB, 35kA for UPS - 2 Nos(one standby), 63 Amp TPN MCCB, 35kA for Capacitor Panel - 1No, 63 Amp 4P MCCB, 35 kA -1 Nos. for ATM. All MCCBs are strictly as specified above only. All outgoing must be in compartmentalized chamber fully isolated with 2 mm thick CRCA and 3 mm steel channel painted with 2 coats of red oxide primer paint followed by finishing paint with interconnection etc. as required.</p>	Set	1		
	<p>b. Capacitor Panel: Supply and installation of 30 KVAR APFC panel, floor/wall mounted front operated totally enclosed vermin proof, indoor non-drawout-cubicle type power panel fabricated out of 16 SWG thick CRCA sheet having gasketed hinged cover on each cubicle fully powder coated with suitable bus bar for connecting the contactors, MCB's, Capacitors, etc with the following accessories A set of R-Y-B LED indicating lamp at incomer 63A, TPN MCCB, 35kA as incomer - 1No 2 No. A 3P contactor for 10 KVAR, 1 Nos. 32A 3P contactor for 5 KVAR, 2 Nos, 25A, 3P contactor for 2 KVAR and 1 No, 16A, 3P contactor for 1 KVAR 2 No. 10 KVAR, 1 Nos. 5 KVAR, 2 Nos. 2 KVAR and 1 No. 1 KVAR. 1 no. 6-step APFC relay of minimum size 150 MM X 150 MM suitable for above arrangement ON/OFF push button for each capacitor ON/OFF LED type indication lamp for each capacitor</p>	SET	1		
2	<p>Sub-main line:- Wiring in MS conduit of IS specification of Proper size with core PVC insulated stranded copper wire 11KV grade (Finolex/Havells/Polycab/RR Kabel/ Richa/KEI or equivalent) and with supply ,installation, commissioning of all the materials required including proper termination, connection in complete as required from main DB to various DBs:-</p>				
	i) with 3nos 4sq.mm (1ECC) (Raw power line)	RM	180		
	ii) with 3nos 6sq.mm (1ECC)	RM	120		
3	Supply ,installation ,testing and commissioning of distribution board manufactures made sheet steel enclosure With the following MCBs (DB, MCB and MCCB Make - Legrands/ Havells/L&T/SIEMENS or equivalent) and connecting the same to the system.				
	i) Computer/Raw power DB, SPN double door with 40A (30mA)DP RCCB as incomer & 5 nos 10A SP MCB as outgoing.(for raw and UPS)	No.s	2		
	ii) DB with 16 A DP MCB(Sinage/Security light)	Nos.	2		
	iii) DB with 32A DP MCB (for UPS)	No.s	4		
	iv) DB with 32A MCB Changeover	Nos.	1		
	v) DB with 32A RCCB FOR AC	Nos.	2		
	Vi) Modular 5 pin Socket With 20A SP MCB protected switch(Each Table for Power Plug).	No.s	10		
	Vii) VTPN Double Door Distribution Board with 100A 4 Pole MCCB (36kA) as incomer and 1 No. of 63A SP MCB, 6 nos. of 32 A SP MCB, 2 nos of 16A SP MCB at outgoing	Set	1		
	viii) VTPN Double Door Distribution Board with 125 A 4 Pole MCCB (36kA) as incomer and 16 nos. of 25 A SP MCB, at outgoing	Set	1		

Sl.No	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
ix)	Light DB SPN double door with 40A (30mA)DP RCCB as incomer & 5 nos 10A SP MCB as outgoing.(for raw and UPS)	No.s	2		
x)	TPN DB with 63 4P MCB as incoming and 4 nos. of 20A SP MCB, 4 Nos 10A SP MCB as outgoing.(for ATM)	Set	1		
4	Supplying, installing and commissioning of PVC Armored cable complete with proper cable glands and two nos. of 8SWG GI wire (Havell's/Richa/RR kebel/KEI or equivalent) alongwith all the other materials required including proper connection in complete as required from main Panel, Power Distribution Board to various DBs .				
i)	With 3.5 core x 25 sq. mm cable	RM	20		
ii)	With 3.5 core x 35 sq. mm cable	RM	80		
iii)	With 3.5 core x 70 sq. mm cable	RM	60		
5.a)	Supply, installing and commissioning of earth station including digging and refilling back the pit with black soil and with 3.15mm x300mm size copper plate duly finned through out the surface of the plate, placed at least 1.5Mtr,below the ground level with 2nos 10sq.mm PVC insulated stranded copper conductor in 20mm GI pipe, fixed to the plate and providing 40mm,2mtr,long GI pipe with reducer and funnel at top for watering pipe with supplying and laying earth continuity wire of 2x10sq.mm copper stranded PVC green color in heavy duty MS conduit on the wall from earth plate to starting point of the line earth connector. (Video proof of the earthing should be kept for final billing) Earth pit for UPS will be separate)	Set	3		
b)	Maintenance Free Chemical Earth Stations: The items listed below shall be undertaken directly by Agencies providing Ashlock/ or True Power or, equivalent of approve Make Chemical earthing. The contractor shall provide the rates of getting the same executed by the agency. The representative of the agency shall measure and submit the test report of the earth directly to the branch and one copy to the Elect. Engr. along with their bill. The agency may also require to test and provide the test report of the earthing measurement if required to the branch and Elect. Engr. for monitoring upto a period of three years.				
i)	Supply and installation of pipe-in-pipe technology Ashlok Earthing / True Power system or equivalent of approve make Model T-19 with outer diameter of 50 mm, length 2000 mm embedded in the soil with masonry inspection pit with cover , which can be easily removed abd placed. complete in all respect. Earth pit installation test certificate to be submitted after measurement of earth resistance as per the provision in IS3043. (UPSs and Panel earthing)	Set	2		
ii)	Supplying and fixing 25x3 mm copper strip, insulated by heat pressurized heavy gauge PVC sleeve, duly jointed by full lap brazing and drawn underground in 40 mm class B GI pipe from the inspection pit to the inside of the branch premises.	RM	30		
iii)	Supplying and fixing 2X8 SWG dia copper earth wire in PVC conduit on surface or in recess for loop earthing from panel to DB	RM	40		
6	Computer/Raw Power point wiring in MS conduit of IS specification of proper size with 3nos 2.5sq.mm single core PVC insulated stranded copper wire 1.1KV grade(Finolex/Havells/Polycab/ RR Kabel/ Richa/KEI or equivalent) and with all material supply installation and commissioning complete from CDB/PDB(Raw) .The wiring shall be carried out on surface above false ceiling by chiseling the existing surface and plastering the same with cement etc. after fixing the MS conduit with all accessories like saddles screws, bends T-joint etc. 2 coats of painting Matching to the surface including supply installing, testing, commissioning of modular plate type switch and socket (Legrands / MK or equivalent) for computer terminal on sheet steel enclosure (cadmium plated),duly fitted with screw to the steel conduit and fixed to the wall partition furniture with all interconnection and proper earthing .All the opening shall be covered with blank plate and be sealed to make the box vermin proof.B48(maximum three points in single circuit)				
i)	With 3nos 6A socket with single 16A switch.	No.s	17		
ii)	With 2nos 16A socket with individual switch.	No.s	16		
iii)	With 1nos 16A socket with individual switch.	No.s	5		

Sl.No	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
7	Supply, installation testing and commissioning of recessed mounted circular LED downlighter with 15W LED lamp. Make :- Bajaj/Havels/Phillips/Wipro/Crompton or equivalent. (Make - as in tender make list)	Nos	32		
8	Supply, installation testing and commissioning of surface mounted circular LED downlighter with 15W LED lamp. Make :- Bajaj/Havels/Phillips/Wipro/Crompton or equivalent. (Make - as in tender make list)	Nos	10		
9	Supply, installation testing and commissioning of recessed type LED luminaire with complete PMMA Difuser with 36W LED lamp (size 2'X 2')(Model:PLUTONEO2X2PLR42WLED857S or equivalent) . (Make - as in tender make list)	Nos	20		
10	Supply and installation of BLDC 5 SATR Ceiling fan 1200 mm (Make - as in tender make list)	No.s	2		
11	Supply and installation of Wall Mounted fan 400 mm Metallic body and metallic Blade ,1400 rpm. (Make - as in tender make list)	No.s	9		
12	Supply installation testing and commissioning of LED batten Single Tube light fittings with 20W with glare free light distribution wall mounted at ceiling/false ceiling level/. (Make - as in tender make list)	Nos	16		
13	Supply and installation of Exhaust Fan 300 mm (Make - as in tender make list)	No.s	6		
14	Supplying, installation, testing & commissioning of Security light with 25W LED lamps with pressure die cast housing with epoxy coated dark graphite grey colour finish and prismatic polycarbonates cover with individual LED lenses, including necessary GI bracket with clamp. (Make - as in tender make list)	Nos.	5		
15	Supply and Installation of 10 meter roll 55W, IP20 flexible LED strip surface mounted along with required LED driver as back lightinh (Make - as in tender make list)	Nos.	20		
16	Wiring for light/fan/exhaust fan points using 3 X 1.5 1.1 kV grade PVC insulated stranded copper conductor wire (Finolex/Havell's/Richa/RR kebel/KEI or equivalent) for phase, neutral and earth in 25 mm dia heavy duty MS conduit along with associated accessories like MS junction boxes, bends, saddles, screws et. concealed in wall, floor, under flooring, below false ceiling or on surface as well as suspended from ceiling with 25mm X 3 mm MS flat suspenders duly painted above false ceiling from individual light/Fan/Exhaust Fan point outlet. etc. to individual modular type switch boards, 10 Amp modular plate type switches etc.(MK/Legrand's/Havel's or equivalent), as required complete including circuit wiring with 3 X 2.5 sqmm. 1.1 kV grade PVC insulated stranded copper conductor wire and as per site requirement and as instructed by SBI Engineer.				
i)	one switch control one light/fan point (5 light point in UPS)	No.s	40		
ii)	one switch control two light/fan point	No.s	10		
iii)	6A socket & switch at same board	No.s	8		
iv)	16A, 5 pin industrail plug & Socket with 16 SP A MCB protected (for Safe room & Record room)	Nos.	2		
v)	Modular type DB with 6A/9A SP MCB.(for wall fan and exhaust fan)	No.s	15		
vi)	Fan Point with electronic modular type regulator.	No.s	2		
17	AIR CONDITIONING WORK				
i)	Supply of 1.5 TR Capacity Hi Wall mounting Hot & Cool 5-star rated Inverter Split AC with cordless remote and Copper Condensor Coil. AC Make, Voltas/Bluestar /Carrier/Daikin /LG/Godrej(Branch Manager)	No.	1		
ii)	Installation charges of the 1.5/2.0 TR Split AC including outdoor frame / stands to withstand the full load of outdoor units and making good all the damage.	No.	1		
iii)	Supply, Installation testing and commissioning of 4 KVA Stabilizer for 1.5 TR Split type Acs	No.	1		
iv)	Timer for alternate operation of air conditioning in ATM	No.	1		
			Total		

GST on work contract will be extra as applicable.