

BOQ FOR ANNUAL MAINTENANCE CONTRACT FOR ELECTRICAL INSTALLATIONS (HT/LT) AND OPERATION OF ELECTRICAL INSTALLATION/ DG OPERATION/ MOTOR/PUMP MAINTENANCE & REPAIRING AT SYNERGY, BKC,STATE BANK OF INDIA, LOCAL HEAD OFFICE AND ANNEX BUILDING

Sr. No	Description	Number of personnel to be	Rate per as per minimum wages (With Basic, DA,EPF,ESIC, Bonus,HRS & LWF)	Amount per month (Rs.)	Unit	Amount per Year
Part -A	Operation & Maintenance of Electrical Installations					
1	Electrical Engineer/LiceneSupervisor (Highly Skilled)	1			Rs	
2	Licensed Electrician (Skilled)	5			Rs.	
3	Helper (Semi Skilled)	3			Rs	
4	DG Operator/ Electrician (Skilled)	1			Rs	
5	Contractor's Over Heads & Profits percentage	0%			Rs.	
Part -B	Additional Works					
1	Servicing &testing of all parameters of ACB panels, Bus coupler situated at AC plant room, DG set and electrical room through company's authorised service centre (Once a year) with submission of test reports.	1 Job			Rs.	
2	Servicing &testing of all parameters of 11KV ALSTOM make VCB panels (HT Feeder 1,2,3) through OEM/company's authorized service centre(Once a year) with submission of test reports.	1 Job			Rs.	
3	Servicing &testing of all parameters of 11KV 1250 KVA Dry transformer -2 nos through OEM/company's authorized service centre (Once a year) with submission of test reports.	1 Job			Rs.	

	measurement or earth resistance, Testing of lightning arrester, Maintenance of SFUs & APFC Panel etc. once in a Year through OEM/company's authorized service centre (Once a year) with submission of test reports.	4	1 Job	Rs.	
Part -C	DG Set Maintenance AMC				
1	B- Check of 3 Nos. of 600 KVA DG Set with all the required material once in a Year through OEM's/ authorized service centre/authorised distributor (Once a year) with submission of test reports		1 Job	Rs	
Part -D	Electric Motor/ Pump Repairing AMC				
1	Repair & maintenance of pump & motor with free of cost with spare part including following : (i) Mechanical Seal (ii) Oil Seal (iii) Bearing pump& motor side (iv) Coupling (v) Spider Bush (vi) Oil/lubricant (vii) Motor terminal Plate (viii) Motor winding (Excluded) (ix) Fan Blade (X) (Servicing Twice in a year) : Details are below: 100 HP- 1 No, 75 HP- 1No, 50 HP-4Nos, 40 HP-01No, 20 HP-5 Nos, 10 HP-5 Nos , 7.5 HP-2Nos, 5.5 HP-7Nos, 3.0 HP-14 Nos, 2.0 HP-06 Nos, 1.0 HP-10No.		Total 673 HP	1 Job	Rs.
	Total (A+B+C+D)			Rs.	
	GST EXTRA				