

**CORRIGENDUM-1**

**PRE BID MEETING DATED : 29.01.2025**

**HIRING OF SOLAR POWERED UPS SYSTEMS ON MONTHLY RENTAL BASIS FOR 344 SBI ATMs IN LUCKNOW CIRCLE.**

Please refer tender no LUC202501001 dated 22.01.2025 for captioned work and read as under:-

<b>S. No.</b>	<b>Queries</b>	<b>Revised description/ Reply</b>
a)	battery back up in 3.0 KVA Solar Powered true online UPS system is <b>19200 Vah.</b> which is to be reduced <b>9600 Vah</b> , as ATM sites with this battery back up are already running satisfactory.	battery back up in 3.0 KVA Solar Powered true online UPS system will be <b>9600 Vah.</b>
b)	The Bidder should have minimum average annual turnover of <b>Rs. 13.83 Lacs</b> during last 3(three) Financial years ( 2021-22, 2022-23 2023-24) is lower side. That to be as per capacity of work. ( copy of profit & loss , balance sheet to be submitted)	The Bidder should have minimum average annual turnover of <b>Rs. 13.83 lacs x 12 months = Rs 165.96 lacs</b> during last 3(three) Financial years ( 2021-22, 2022-23 2023-24). ( copy of profit & loss , balance sheet to be submitted)
c)	undertaking to be obtained by Bank. that bidder should not be blacklisted from any organization.	Undertaking to be given by participating bidder as part of technical bid that firm is not Black listed from any organization.

**ASST GENERAL MANAGER ( PREMISES & ESTATE )**